

ST. CLOUD VA - BUILDING 59

ASBESTOS-CONTAINING MATERIAL ASSESSMENT DATABASE

APPENDIX II

FLOOR	FUNCTIONAL SPACE/ROOM	HOMOG. MATERIAL	INCIDENT	TYPE	DESCRIPTION	QUANTITY	HEIGHT (FEET)	CONDITION	DISTURBANCE POTENTIAL	AHERA CATEGORY	REMOVAL COST	DATE ABATED
BSMT	FEMALE BATH ROOM 1	2	MASTIC	MISC	MASTIC UNDER 12"X12" FLOOR TILE	130 SF	0	G	L	NF	\$650	
BSMT	MALE BATH ROOM 3	2	MASTIC	MISC	MASTIC UNDER 12"X12" FLOOR TILE	168 SF	0	G	L	NF	\$840	
BSMT	FEMALE LOCKER RM 8	7	MASTIC	MISC	MASTIC UNDER 12"X12" FLOOR TILE	255 SF	0	G	L	NF	\$1,275	
BSMT	MALE LOCKER ROOM 9	4	MASTIC	MISC	MASTIC UNDER 12"X12" FLOOR TILE	260 SF	0	G	L	NF	\$1,300	
1	ELEVATOR	19	MASTIC	MISC	MASTIC UNDER 12"X12" FLOOR TILE	56 SF	0	G	L	NF	\$280	Abated 8.18.10
1	EXTERIOR	20	WINDOW GLAZING	MISC	WHITE WINDOW GLAZING	41 WDW	0-20	G	L	NF	\$10,250	
1	EXTERIOR	21	WINDOW AND DOOR CAULK	MISC	WINDOW AND DOOR GRAY	2 DOORS	0-8	G	L	NF	\$800	
1	ROOM 100	18	VIBRATION DAMPER	MISC	VIBRATION DAMPER	2 EACH	15	G	L	NF	\$500	
1	ROOM 101	18	VIBRATION DAMPER	MISC	VIBRATION DAMPER	2 EACH	15	G	L	NF	\$500	
1	ROOM 11 STAIRS	ASSUMED	FIRE DOOR	MISC	FIRE DOORS	2 DOORS	0-8	G	L	NF	\$200	

DISTURBANCE POTENTIAL CODE: L=LOW M=MODERATE H=HIGH
 CONDITION CODE: G=GOOD F=FAIR P=POOR

TYPE CODE: TS=THERMAL SYSTEM INSULATION
 SURF=SURFACING MATERIAL MISC=MISCELLANEOUS

LF=LINEAR FEET
 SF=SQUARE FEET
 CF=CUBIC FEET