GENERAL SHEET NOTES

A. SHADED AREAS INDICATE PORTION OF PROJECT OCCUPIED BY CONTRACTOR IN THIS PHASE. SOME ACCESSORY WORK IS REQUIRED OUTSIDE OCCUPIED AREA TO COMPLETE PHASE.

B. REFER TO OTHER DISCIPLINE DRAWINGS FOR WORK RELATED TO THIS PHASE.

C. I.T. CLOSET A289 TO SERVE TELECOMMUNICATIONS FOR AREA "D". I.T. CLOSET A247A TO SERVE TELECOMMUNICATIONS FOR AREA "A". I.T. CLOSET AA240 TO SERVE TELECOMMUNICATIONS FOR AREA "D".

D. PROVIDE DATA OUTLET LABELING: ROOM NUMBER AND JACK NUMBER. JACK NUMBER IN ROOM MUST MATCH NUMBER AT PATCH PANEL.

E. CABLING STANDARDS:
   a. BIOMED/PATIENT MONITORING : CAT 6 RED
   b. DATA CABLE: BLUE
   c. WIRELESS: GREY
   d. CABLE TV: BLACK COAX
   e. ANALOG PHONE: GREEN

F. CONTRACTOR TO PROVIDE I.T. RACKS (OPEN FACE), PATCH PANELS AND WIRING MANAGEMENT.

G. CONTRACTOR TO SET UP A PRE-SUBMITTAL TO DISCUSS ALL "IT" CABLING.

SHEET KEYNOTES

1. COORDINATE ROUTING OF 4" CONDUITS ABOVE CEILING TO LOCATION(S) AS INDICATED. STUB CONDUITS 6" ON EACH SIDE.
2. TERMINATE NEW 50 PAIR CABLES TO EXISTING TELEPHONE RACKS. PROVIDE 10' SLACK COILED CABLE. COORDINATE WITH I.T. DEPARTMENT FOR ALL NEEDED CONNECTIONS. MAKE ALL FINAL CONNECTIONS. PROVIDE REQUIRED 110 PUNCH DOWN BLOCKS, LIGHTNING PROTECTION ISOLATORS AND INTERCONNECTING WIRING.
3. PROVIDE NEW 24 PORT PATCH PANEL AND INTERCONNECTION WIRING.
4. DISCONNECT AND TAKE DOWN EXISTING LIGHT FIXTURES, ETC. AND REINSTALL AFTER WORK ABOVE CEILING IS COMPLETE. REMOVE CEILING TILE AND GRID FOR WORK ABOVE CEILING. REINSTALL GRID AND TILE. REPLACE ANY DAMAGED TILES AND GRID.
5. PROVIDE RACK MOUNTED FIBER PATCH PANEL AND TERMINATE MULTI-MODE FIBER. COORDINATE WITH I.T. DEPARTMENT FOR TERMINATION POINT, REQUIRED PATCH PANELS AND FINAL CONNECTIONS.
6. ALL NEW TELEPHONE AND DATA CABLES TERMINATING IN ROOM A247 TO HAVE MINIMUM 10 COILED SLACK. AFTER NEW I.T. RACKS HAVE BEEN INSTALLED AND ELECTRICAL PANELS AND TRANSFORMERS HAVE BEEN REMOVED, RELOCATE PATCH PANELS TO NEW RACKS AND RECONNECT TELEPHONE/DATA CABLES.

BARRIER / WALL LEGEND

REFER TO SHEET PD-102 FOR REQUIRED RATINGS

- EXISTING ELEMENT TO BE REMOVED
- EXISTING ELEMENT TO REMAIN
- NEW PARTITION / BARRIER / WALL
- SMOKE-RESISTIVE WALL
- 1-HOUR RATED FIRE BARRIER
- 2-HOUR RATED FIRE BARRIER
- 1-HOUR RATED FIRE SMOKE BARRIER
- 2-HOUR RATED FIRE SMOKE BARRIER
- HATCHING INDICATES AREAS OUTSIDE PRIMARY PROJECT LIMITS. SOME ACCESSORY WORK WILL OCCUR IN SHADED AREAS. REFER TO ALL DISCIPLINE DRAWINGS FOR COMPLETE SCOPE.
- CONCRETE SHEAR WALL

COORDINATION DRAWINGS

SEE COVER SHEET FOR COORDINATION NOTES.

KEYPLAN



F3 SECOND FLOOR TELE/DATA CONDUIT PLAN

SCALE: 3/32" = 1'-0"

0 5' 10' 20'

REVISION NO.	REVISION DESCRIPTION	
1	CLARIFICATION #1	07/20/2015

Revisions By Date

Department of Veterans Affairs
Ralph H Johnson VA Medical Center
109 Bee Street
Charleston, SC 29401

SEAL

Architect/Engineer Address

HARRELL
• DESIGN GROUP, PC •
formerly HARRELL, SALTRICK & HOPPER, PC

8016 TOWER POINT DRIVE
CHARLOTTE, NC 28227
P 704.814.1320
F 704.321.0833
WWW.HARRELLDG.COM

COPYRIGHT © 2014 HARRELL DESIGN GROUP, PC
HDG PROJECT # 13026

Recommended Approvals:	
1. CHIEF, ENGINEERING SERVICE	
2. PROJECT MANAGER	

Drawing Title: SECOND FLOOR TELE/DATA CONDUIT ROUTING PLAN

Project Title: EXPAND/REPAIR INTENSIVE CARE UNIT, STEP DOWN UNIT, AND PULMONARY

Date: 05/29/2015

Project Number: 534-325

BUILDING IS FULLY SPRINKLERED

CONSTRUCTION DOCUMENTS

Drawn	Building Number	AutoCAD File Name
WAO	1	

Checked	Reviewed	Const. Contract No.

DRAWING No. E-122

Veterans Affairs