

Calibration of Pressure Monitors and Air Balancing - Attachment A

Room #	Area Description	Calibration Interval	Pressure Relationship to Adjacent Areas	Ideal Pressure (Inches Water Column)	Minimum Pressure (Inches Water Column)	Air Changes per Hour (ACH)	Reference section ASHRAE 170
A4-50	Operating room	Quarterly	Positive	-	0.01	15	7.4.1
A4-54	Operating room	Quarterly	Positive	-	0.01	15	7.4.1
A4-55	Operating room	Quarterly	Positive	-	0.01	15	7.4.1
A4-56	Operating room	Quarterly	Positive	-	0.01	15	7.4.1
N4-114	Sterile Processing Service	Quarterly	Positive	-	0.005	4	
N4-112	Sterile Processing Service	Quarterly	Positive	-	0.005	4	
N4-113	Sterile Processing Service	Quarterly	Positive	-	0.005	4	
N4-111	Sterile Processing Service	Quarterly	Positive	-	0.005	4	
N4-107	Sterile Processing Service	Quarterly	Positive	-	0.005	4	
N4-104	Sterile Processing Service	Quarterly	Positive	-	0.005	4	
N4-102	Sterile Processing Service	Quarterly	Positive	-	0.005	4	
N4-101	Sterile Processing Service	Quarterly	Positive	-	0.005	10	
N4-94	Sterile Processing Service	Quarterly	Negative	-	0.005	6	
N4-97	Sterile Processing Service	Quarterly	Negative	-	0.005	6	
N4-106	Sterile Processing Service	Quarterly	Negative	-	0.005	6	
N4-98	Sterile Processing Service	Quarterly	Negative	-	0.005	10	
N4-103	Sterile Processing Service	Quarterly	Negative	-	0.005	10	
N4-100	Sterile Processing Service	Quarterly	Negative	-	0.005	10	
N4-95	Sterile Processing Service	Quarterly	Negative	-	0.005	10	
N4-92	Sterile Processing Service	Quarterly	Negative	-	0.005	10	
N4-93	Sterile Processing Service	Quarterly	Negative	-	0.005	10	
A4-21A	Intensive Care Isolation Rm	Semi annual	Negative	-	0.01	12	7.2.1 Note a.
A4-21	Intensive Care Isolation Ante Rm	Semi annual	Negative	0.01	0.005	10	7.2.1 Note a.
A4-20A	Intensive Care Isolation Rm	Semi annual	Negative	-	0.01	12	7.2.1 Note a.
A4-20	Intensive Care Isolation Ante Rm	Semi annual	Negative	0.01	0.005	10	7.2.1 Note a.
A4-16	Intensive Care Isolation Rm	Semi annual	Negative	-	0.01	12	7.2.1 Note a.
A4-16A	Intensive Care Isolation Ante Rm	Semi annual	Negative	0.01	0.005	10	7.2.1 Note a.
A4-17	Intensive Care Isolation Ante Rm	Semi annual	Negative	0.01	0.005	10	7.2.1 Note a.
A4-31	Intensive Care Isolation Rm	Semi annual	Negative	-	0.01	12	7.2.1 Note a.
C4-44	4E In-Patient Airborne Isolation Rm	Semi annual	Negative	-	0.01	12	7.2.1 NOTE a.
C4-44B	4E In-Patient Airborne Isolation Ante Rm	Semi annual	Negative	0.01	0.005	10	7.2.1 NOTE a.
C4-44D	4E In-Patient Airborne Isolation Rm	Semi annual	Negative	-	0.01	12	7.2.1 NOTE a.
C4-44C	4E In-Patient Airborne Isolation Ante Rm	Semi annual	Negative	0.01	0.005	10	7.2.1 NOTE a.
4-105	Hemo-Dialysis (Airborne Isolation Isolation Rm)	Semi annual	Negative	-	0.01	12	7.2.1 Note a.
4-104	Hemo-Dialysis (Sterile Supply Rm)	Semi annual	Positive	-	0.005	4	
4-120	Hemo-Dialysis (Soiled Utility Rm)	Semi annual	Negative	-	0.005	10	
4-109	Hemo-Dialysis (Soiled Equipment Rm)	Semi annual	Negative	-	0.005	10	
4-111	Hemo-Dialysis (Clean Utility Rm)	Semi annual	Positive	-	0.005	4	
4-102	Hemo-Dialysis (HAC)	Semi annual	Negative	-	0.005	4	
Cath Recovery Room	Cardiac Cath. Area (Cath Recovery Rm)	Semi annual	-	-	-	6	
Clean Utility	Cardiac Cath. Area	Semi annual	Positive	-	0.005	4	
4-138	Cardiac Cath. Area (Soiled Utility)	Semi annual	Negative	-	0.005	4	
4-148	Cardiac Cath. Area (Sterile Supply)	Semi annual	Positive	-	0.005	4	
4-146	Cardiac Cath. Area (Procedure Rm)	Semi annual	Positive		0.01	20	7.5.2
Bronchoscopy room	3rd Floor Repertory Therapy	Semi annual	Negative		0.01	12	
Pulmonary Function lab	3rd Floor Repertory Therapy	Semi annual	Negative		0.005	12	
EB-57	Morgue	Annual	Negative	-	0.01	12	7.5.1
C4-70A	SPS Endoscope cleaning	Annual	Negative	-	0.01	10	
C4-70	SPS Endoscope Ante Rm	Annual	Negative	0.01	0.005	10	
C4-63	GI Clean storage		Positive	0.01	0.005	4	
C4-64	GI Dirty storage		Negative	0.01	0.005	10	
Airborne Isolation Room	Emergency Department	Annual	Negative		0.005	10	

7.2.1 NOTE a. - ASHE Standard 170 edition 2008 or 2013 are identical for pressure requirements