

KEYED NOTES:

1 - 30A/3P-NON FUSIBLE STARTER TO BE FVNR-SIZE 1 WITH CONTROL TRANSFORMER HAND-OFF-AUTO SELECTOR SWITCH AND RED-RUNNING PILOT LIGHT - NEMA 12.

2 - VFD BY MECHANICAL CONTRACTOR.

1 FOURTH FLOOR PRIMARY PENTHOUSE PLAN-POWER

1/8" = 1'-0"



KEY PLAN

BUILDING PARTIALLY SPRINKLERED (RENOVATED SPACES/ NEW PENTHOUSES IN THIS SCOPE OF WORK 100% SPRINKLERED)

BID SET 06/12/2015

NO	REVISIONS	DATE
	ADDENDUM 1	07/07/2015
	BID SET	06/12/2015

CONSULTANTS:

GAUTIER de TORRES ARQUITECTOS
Apartado 19357, San Juan, Puerto Rico 00910-1357

DEGENKOLB ENGINEERS
235 MONTGOMERY ST, SAN FRANCISCO, CA 94104

SAQ ENVIROMENTAL ENGINEERS, INC
PO.BOX 155, MANATI, PR 00674

LASALLE ENGINEERING, LLC
1000 YORK ROAD WILLOW GROVE, PA 19090

M.A + ASSOCIATES, LLC
8655 CHERRY LANE, LAUREL, MD 20707

CT + ASSOCIATES, LLC
86 THOMAS LEIGHTON BLVD, CUMBERLAND, RHODE ISLAND 02864

ARCHITECTS/ENGINEERS

HDR

1101 King Street Suite 406, Alexandria, VA 22314

LEONARDO J. VIDAL INGENIERO LICENCIADO LIC. 4842 EXPIRA 31 MARZO, 2016 PUERTO RICO

Drawing Title: **FOURTH FLOOR PRIMARY PENTHOUSE PLAN-POWER**

Approved : Project Director

Project Title: **PHASE 3 BUILDING ONE-SEISMIC CORRECTIONS AND RENOVATIONS**

Location: **VA Caribbean Healthcare Systems 10 Casia Street, San Juan, PR 00921-3201**

Date: **06/12/2015** | Checked by: **LJV** | Drawn: **WBR**

Project Number: **672-085A**

Building Number: **1**

Drawing number: **ES1-204D**

0

Office of Construction and Facilities Management

Department of Veterans Affairs

C:\Users\user\Documents\174534E-GDTVASJ-CENTRAL_wblanco.rvt
7/7/2015 4:05:40 PM