

CONSULTANTS:

  
**MAZZETTI**  
220 Montgomery Street, Suite 650  
San Francisco, CA 94104  
TEL: 415.632.3266  
[www.mazzetti.com](http://www.mazzetti.com)

---

PROJECT NUMBER: 130-055



**POLYTECH ASSOCIATES INC.**  
235 Pine Street, 17th Floor  
San Francisco, CA 94104  
TEL (415) 397-3117  
FAX (415) 397-1517

Approved: Project Director

Location	150 MUIR ROAD, MARTINEZ, CA 94553
----------	-----------------------------------

Building Number

Drawing Number

MH101



Office of  
Construction  
and Facilities  
Management



### GENERAL SHEET NOTES

1. SHADED AREAS ARE PART OF THE OPEN OFFICE BASE PLAN. HVAC ZONING HAS BEEN DESIGNED BASED ON OWNER FURNISHED DEMOUNTABLE WALLS. SEE 1/A102 FOR REFERENCE.
2. REFER TO M4.01 FOR DUCT DETAILS.
3. SEE ZONING PLAN 1/M201 FOR THERMOSTAT LOCATIONS.

## KEY NOTES

- 1 EF-2 TO EXHAUST 125 CFM OUT OF MECH. RM. 138  
CONNECT EF-2 TO ROOM TEMPERATURE SENSOR  
AND TO SIEMENS APOGEE CONTROL SYSTEM.  
EF-2 TO OPERATE WHEN ROOM TEMPERATURE  
EXCEEDS 86 DEGREES AND SHUT OFF WHEN  
ROOM TEMPERATURE IS BELOW 86 DEGREES.  
8"6" RA UP TO FCU-2.4 IN 2ND FLOOR. 
- 2 WAITING ATRIUM RM. 102 TO BE SERVED BY  
FCU-2.11 FROM SECOND FLOOR BY FCU-2.11.
- 4 OFFSET TRANSITION TO AVOID W18x35  
BEAM BEAM. 
- 5 PROVIDE 4" WATER HEATER FLUE UP TO ROOF.  
COORDINATE WITH APPROVED WATER HEATER.  
6 LOUVERED DOOR TO ALLOW MAKE-UP AIR FOR  
EF-2. SEE ARCH. DWG. A5801 FOR DOOR DETAILS

100% CONSTRUCTION DOCUMENT SUBMISSION  
APRIL 20, 2015