

FLOOR PLAN NOTES

- REFERENCE LIGHTING CONTROL SHEET AND ROOM CONTROL DETAIL SHEET FOR ADDITIONAL CONTROLS AND INFORMATION.
- FIXTURE IN THIS AREA IS CONTROLLED BY MOTION SENSOR ONLY WITH 50% LIGHT OUTPUT WHEN UNOCCUPIED. WHEN OCCUPIED LIGHT SHALL COME ON TO 100% FULL OUTPUT. UPON EMERGENCY ACTIVATION EMERGENCY BALLAST SHALL OVER-RIDE MOTION SENSOR AND BE POWERED BY THE EMERGENCY BALLAST.
- PROVIDE AND INSTALL SENSOR HLIGHT rPODM-SX-X (ON/OFF-RAISE LOWER BUTTON) DIMMING WALL SWITCH.
- ROUGH-IN AND PROVIDE AND INSTALL SENSOR HLIGHT rPODM-SX-X (ON/OFF-RAISE LOWER BUTTON) DIMMING WALL SWITCH.
- INSTALL NEW LOW VOLTAGE LED MINI COVE LIGHT COMPLETELY AROUND THE MIRROR. INSTALL DRIVE ABOVE ACCESSIBLE CEILING. CONNECT TO EXISTING LIGHT CIRCUIT MAINTAIN DURING DEMOLITION WORK.
- HALL/ROOM CONTROLLED BY MOTION SENSOR ONLY.
- PROVIDE AND INSTALL INTERMATIC E215X (HOLD, 15/30/60 MIN 2/4 HOUR) TIMER OR EQUAL BY SENSOR SWITCH TIMER SWITCH.

SECOND FLOOR PLAN-LIGHTING NEW WORK

SCALE: 1/8"=1'-0"



Lankford + Fendler  
+ associates

1730 Walnut Street, Kansas City, Missouri 64108  
3032 Franklin Avenue, St. Joseph, Missouri 64501  
7001 College Boulevard, Suite 450, Overland Park, Kansas 66211  
Phone: 816.221.1411 | Fax: 816.221.1429  
LANKFORD | FENDLER + ASSOCIATES CONSULTING ENGINEERS, INC.  
COPYRIGHT © 2015. Project No. 4884


CENTRAL  
ARKANSAS VA  
HEALTH CARE  
SYSTEM



Revision	Date
100% For Construction	02.20.15

CONSULTANTS:

Lankford | Fendler  
and Associates  
1730 Walnut Street  
Kansas City, MO  
64108  
816.221.1411



ARCHITECT / ENGINEER:

TOMPKINS  
ARCHITECTS  
507 Walnut Street, Suite 200, Kansas City, MO 64106  
p. 816.472.5656 f. 816.472.5637 www.tom-arch.com

COPYRIGHT 2015 BY TOMPKINS ARCHITECTS, INC. ALL RIGHTS RESERVED. NO PART OF THESE DOCUMENTS MAY BE REPRODUCED, STORED IN A RETRIEVAL SYSTEM, OR TRANSMITTED IN ANY FORM OR BY ANY MEANS, ELECTRONIC, MECHANICAL, PHOTO COPYING, RECORDING, OR OTHERWISE, WITHOUT THE PRIOR WRITTEN PERMISSION OF TOMPKINS ARCHITECTS, INC.

Drawing Title

SECOND FLOOR PLAN  
LIGHTING NEW WORK

Approved: Project Director

Project Title

BUILDING 65  
BUILDING DESIGN FOR LIGHTING  
IMPROVEMENT

Date

February 20, 2015

Checked

GJF

Drawn

BCD

Project Number

VA101V-14C-0104

Building Number

65

Drawing Number

E203