







Dead Leg Criteria Checklist					
	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture	
Dead Leg #	1-BASEMENT-001-001				
Dead Leg Type		X			
Termination	Valve				
Fixture served					
Valve Type	Ball				
Pipe Length	4'				
Pipe Size	2"				
Pipe Function	DCW				
Pipe Material	Copper				
Length of non insulated pipe	-				
Building #	1		Comments 10' in on the main.		
Floor Number	BASEMENT				
Room Number	1				
Location in Room	Center				
Demo Needed? Y/N	N				
Drawing #					
Picture of Dead Leg (or area of termination)					
					
Date of Inspection: 07/02/2014					


Dead Leg Criteria Checklist					
	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture	
Dead Leg #	1-BASEMENT-001-002				
Dead Leg Type		X			
Termination	Valve/Cap				
Fixture served					
Valve Type	Ball				
Pipe Length	3'				
Pipe Size	2"				
Pipe Function	DHW				
Pipe Material	Copper				
Length of non insulated pipe	2'-6"				
Building #	1		Comments		
Floor Number	BASEMENT				
Room Number	1				
Location in Room	Back Right				
Demo Needed? Y/N	N				
Drawing #					
Picture of Dead Leg (or area of termination)					
					
Date of Inspection: 07/02/2014					


Dead Leg Criteria Checklist					
	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture	
Dead Leg #	1-BASEMENT-001-003				
Dead Leg Type		X			
Termination	Cap				
Fixture served					
Valve Type	Gate				
Pipe Length	5'-6"				
Pipe Size	2"				
Pipe Function	DHW				
Pipe Material	Copper				
Length of non insulated pipe	Less than 6"				
Building #	1		Comments		
Floor Number	BASEMENT				
Room Number	1				
Location in Room	Above hot water pumps				
Demo Needed? Y/N	N				
Drawing #					
Picture of Dead Leg (or area of termination)					
					
Date of Inspection: 07/02/2014					


Dead Leg Criteria Checklist											
	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture							
Dead Leg #	1-BASEMENT-002-001										
Dead Leg Type		X									
Termination	Cap										
Fixture served											
Valve Type	Ball										
Pipe Length	25										
Pipe Size	1/2"										
Pipe Function	DHWR										
Pipe Material	Copper										
Length of non insulated pipe	1-1/2"										
Building #	1		Comments								
Floor Number	BASEMENT										
Room Number	1										
Location in Room	Back Center										
Demo Needed? Y/N	N										
Drawing #											
Picture of Dead Leg (or area of termination)											
											
Date of Inspection: 07/03/2014											


Dead Leg Criteria Checklist					
	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture	
Dead Leg #	1-BASEMENT-002-002				
Dead Leg Type		X			
Termination	Cap/Valve				
Fixture served					
Valve Type	Ball				
Pipe Length	6'				
Pipe Size	2"				
Pipe Function	DCW				
Pipe Material	Copper				
Length of non insulated pipe	-				
Building #	1		Comments South Side.		
Floor Number	BASEMENT				
Room Number	2				
Location in Room	By ELEVATOR				
Demo Needed? Y/N	N				
Drawing #					
Picture of Dead Leg (or area of termination)					
					
Date of Inspection: 07/07/2014					


Dead Leg Criteria Checklist					
	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture	
Dead Leg #	1-BASEMENT-002-003				
Dead Leg Type		X			
Termination	Cap				
Fixture served					
Valve Type	Ball				
Pipe Length	4'				
Pipe Size	3/4"				
Pipe Function	DHWR				
Pipe Material	Copper				
Length of non insulated pipe	-				
Building #	1		Comments		
Floor Number	BASEMENT				
Room Number	2				
Location in Room	FRONT SOUTH				
Demo Needed? Y/N	N				
Drawing #					
Picture of Dead Leg (or area of termination)					
					
Date of Inspection: 07/07/2014					


Dead Leg Criteria Checklist					
	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture	
Dead Leg #	1-BASEMENT-002-004				
Dead Leg Type		X			
Termination	Cap				
Fixture served					
Valve Type	Ball				
Pipe Length	19'				
Pipe Size	1/2"				
Pipe Function	DCW/DHW				
Pipe Material	Copper				
Length of non insulated pipe	Less the 1"				
Building #	1		Comments		
Floor Number	BASEMENT				
Room Number	2				
Location in Room	SOUTH WING				
Demo Needed? Y/N	N				
Drawing #					
Picture of Dead Leg (or area of termination)					
					
Date of Inspection: 07/07/2014					


Dead Leg Criteria Checklist					
	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture	
Dead Leg #	1-BASEMENT-002-005				
Dead Leg Type		X			
Termination	Valve				
Fixture served					
Valve Type	Ball				
Pipe Length	3',3',4'				
Pipe Size	3/4",3/4",1/2"				
Pipe Function	DCW/DHW/DHWR				
Pipe Material	Copper				
Length of non insulated pipe	-				
Building #	1		Comments No cap or plug.		
Floor Number	BASEMENT				
Room Number	2				
Location in Room	SOUTH WING				
Demo Needed? Y/N	N				
Drawing #					
Picture of Dead Leg (or area of termination)					
					
Date of Inspection: 07/07/2014					


Dead Leg Criteria Checklist					
	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture	
Dead Leg #	1-BASEMENT-002-006				
Dead Leg Type		X			
Termination	Cap				
Fixture served					
Valve Type	Gate				
Pipe Length	3'				
Pipe Size	1 1/2"				
Pipe Function	DHW				
Pipe Material	Copper				
Length of non insulated pipe	ALL				
Building #	1		Comments		
Floor Number	BASEMENT				
Room Number	2				
Location in Room	FRONT SOUTH				
Demo Needed? Y/N	N				
Drawing #					
Picture of Dead Leg (or area of termination)					
					
Date of Inspection: 07/08/2014					


Dead Leg Criteria Checklist					
	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture	
Dead Leg #	1-BASEMENT-002-007				
Dead Leg Type		X			
Termination	Cap				
Fixture served					
Valve Type	Gate				
Pipe Length	3'-6"				
Pipe Size	2"				
Pipe Function	DCW				
Pipe Material	Galv.				
Length of non insulated pipe	-				
Building #	1		Comments Copper cap.		
Floor Number	BASEMENT				
Room Number	2				
Location in Room	FRONT SOUTH				
Demo Needed? Y/N	N				
Drawing #					
Picture of Dead Leg (or area of termination)					
					
Date of Inspection: 07/08/2014					


Dead Leg Criteria Checklist					
	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture	
Dead Leg #	1-BASEMENT-002-008				
Dead Leg Type		X			
Termination	Cap				
Fixture served					
Valve Type	Ball				
Pipe Length	3'-6", 4'				
Pipe Size	3/4", 1/2"				
Pipe Function	DHW/DHWR				
Pipe Material	Copper				
Length of non insulated pipe	1'				
Building #	1		Comments Uninsulated DHWR only, DCW is 30"		
Floor Number	BASEMENT				
Room Number	2				
Location in Room	FRONT SOUTH				
Demo Needed? Y/N	N				
Drawing #					
Picture of Dead Leg (or area of termination)					
					
Date of Inspection: 07/08/2014					


Dead Leg Criteria Checklist					
	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture	
Dead Leg #	1-BASEMENT-002-009				
Dead Leg Type		X			
Termination	Cap				
Fixture served					
Valve Type	Gate				
Pipe Length	3',5',3'				
Pipe Size	3/4",3/4",1/2"				
Pipe Function	DCW/DHW/DHWR				
Pipe Material	Copper				
Length of non insulated pipe	All of DHW has no insulation				
Building #	1		Comments DCW not capped. DHWR has ball valve.		
Floor Number	BASEMENT				
Room Number	2				
Location in Room	FRONT SOUTH				
Demo Needed? Y/N	N				
Drawing #					
Picture of Dead Leg (or area of termination)					
					
Date of Inspection: 07/08/2014					


Dead Leg Criteria Checklist					
	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture	
Dead Leg #	1-BASEMENT-002-010				
Dead Leg Type		X			
Termination	Cap				
Fixture served					
Valve Type	Ball				
Pipe Length	43'				
Pipe Size	1 1/2", 1"				
Pipe Function	DCW/DHW				
Pipe Material	Copper				
Length of non insulated pipe	-				
Building #	1		Comments		
Floor Number	BASEMENT				
Room Number	2				
Location in Room	FRONT SOUTH				
Demo Needed? Y/N	N				
Drawing #					
Picture of Dead Leg (or area of termination)					
					
Date of Inspection: 07/08/2014					


Dead Leg Criteria Checklist					
	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture	
Dead Leg #	1-BASEMENT-002-011				
Dead Leg Type		X			
Termination	Cap				
Fixture served					
Valve Type	Ball				
Pipe Length	77'				
Pipe Size	3/4"				
Pipe Function	DHWR				
Pipe Material	Copper				
Length of non insulated pipe	-				
Building #	1		Comments		
Floor Number	BASEMENT				
Room Number	2				
Location in Room	FRONT SOUTH				
Demo Needed? Y/N	N				
Drawing #					
Picture of Dead Leg (or area of termination)					
					
Date of Inspection: 07/08/2014					


Dead Leg Criteria Checklist					
	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture	
Dead Leg #	1-BASEMENT-002-012				
Dead Leg Type		X			
Termination	Cap				
Fixture served					
Valve Type	Ball				
Pipe Length	5'				
Pipe Size	3/4"				
Pipe Function	DCW				
Pipe Material	Copper				
Length of non insulated pipe	-				
Building #	1		Comments		
Floor Number	BASEMENT				
Room Number	2				
Location in Room	FRONT SOUTH				
Demo Needed? Y/N	N				
Drawing #					
Picture of Dead Leg (or area of termination)					
					
Date of Inspection: 07/08/2014					


Dead Leg Criteria Checklist											
	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture							
Dead Leg #	1-BASEMENT-002-013										
Dead Leg Type		X									
Termination	Cap										
Fixture served											
Valve Type	Ball										
Pipe Length	16'										
Pipe Size	1/2"										
Pipe Function	DCW/DHW										
Pipe Material	Copper										
Length of non insulated pipe	-										
Building #	1		Comments								
Floor Number	BASEMENT										
Room Number	2										
Location in Room	BY ELEVATOR										
Demo Needed? Y/N	N										
Drawing #											
Picture of Dead Leg (or area of termination)											
											
Date of Inspection: 07/08/2014											


Dead Leg Criteria Checklist					
	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture	
Dead Leg #	1-BASEMENT-002-014				
Dead Leg Type		X			
Termination	None				
Fixture served					
Valve Type	None				
Pipe Length	4'				
Pipe Size	1/2"				
Pipe Function	DCW				
Pipe Material	Copper				
Length of non insulated pipe	2'				
Building #	1		Comments		
Floor Number	BASEMENT				
Room Number	2				
Location in Room	AT ENTRANCE				
Demo Needed? Y/N	N				
Drawing #					
Picture of Dead Leg (or area of termination)					
					
Date of Inspection: 07/08/2014					


Dead Leg Criteria Checklist											
	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture							
Dead Leg #	1-BASEMENT-002-015										
Dead Leg Type		X									
Termination	Cap										
Fixture served											
Valve Type	None										
Pipe Length	12'-6"										
Pipe Size	3/4"										
Pipe Function	DCW										
Pipe Material	Copper										
Length of non insulated pipe	-										
Building #	1		Comments								
Floor Number	BASEMENT										
Room Number	2										
Location in Room	FRONT NORTH										
Demo Needed? Y/N	N										
Drawing #											
Picture of Dead Leg (or area of termination)											
											
Date of Inspection: 07/08/2014											


Dead Leg Criteria Checklist					
	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture	
Dead Leg #	1-BASEMENT-002-016				
Dead Leg Type		X			
Termination	Valve				
Fixture served					
Valve Type	Ball				
Pipe Length	3'-6"				
Pipe Size	1/2"				
Pipe Function	DHWR				
Pipe Material	Copper				
Length of non insulated pipe	-				
Building #	1		Comments		
Floor Number	BASEMENT				
Room Number	2				
Location in Room	FRONT NORTH				
Demo Needed? Y/N	N				
Drawing #					
Picture of Dead Leg (or area of termination)					
					
Date of Inspection: 07/08/2014					


Dead Leg Criteria Checklist					
	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture	
Dead Leg #	1-BASEMENT-002-017				
Dead Leg Type		X			
Termination	Cap				
Fixture served					
Valve Type	Gate				
Pipe Length	18'				
Pipe Size	2 1/2"				
Pipe Function	DCW				
Pipe Material	Black Pipe				
Length of non insulated pipe	-				
Building #	1		Comments		
Floor Number	BASEMENT				
Room Number	2				
Location in Room	FRONT NORTH				
Demo Needed? Y/N	N				
Drawing #					
Picture of Dead Leg (or area of termination)					
					
Date of Inspection: 07/08/2014					


Dead Leg Criteria Checklist					
	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture	
Dead Leg #	1-BASEMENT-002-018				
Dead Leg Type		X			
Termination					
Fixture served					
Valve Type	Gate				
Pipe Length	8',8',9'-6"				
Pipe Size	3/4",3/4",1/2"				
Pipe Function	DCW/DHW/DHWR				
Pipe Material	Copper				
Length of non insulated pipe	-				
Building #	1		Comments Termination is all open.		
Floor Number	BASEMENT				
Room Number	2				
Location in Room	FRONT NORTH				
Demo Needed? Y/N	N				
Drawing #					
Picture of Dead Leg (or area of termination)					
					
Date of Inspection: 07/09/2014					


Dead Leg Criteria Checklist					
	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture	
Dead Leg #	1-BASEMENT-002-019				
Dead Leg Type		X			
Termination	Cap				
Fixture served					
Valve Type	Ball				
Pipe Length	6',6',6'				
Pipe Size	1 1/2",1",1/2"				
Pipe Function	DCW/DHW/DHWR				
Pipe Material	Copper				
Length of non insulated pipe	3'				
Building #	1		Comments		
Floor Number	BASEMENT				
Room Number	2				
Location in Room	FRONT NORTH				
Demo Needed? Y/N	N				
Drawing #					
Picture of Dead Leg (or area of termination)					
					
Date of Inspection: 07/09/2014					


Dead Leg Criteria Checklist					
	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture	
Dead Leg #	1-BASEMENT-002-020				
Dead Leg Type		X			
Termination	Cap				
Fixture served					
Valve Type	Gate				
Pipe Length	3'-5"				
Pipe Size	3/4"				
Pipe Function	DCW				
Pipe Material	Copper				
Length of non insulated pipe	3"				
Building #	1		Comments		
Floor Number	BASEMENT				
Room Number	2				
Location in Room	FRONT NORTH				
Demo Needed? Y/N	N				
Drawing #					
Picture of Dead Leg (or area of termination)					
					
Date of Inspection: 07/09/2014					


Dead Leg Criteria Checklist					
	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture	
Dead Leg #	1-BASEMENT-002-021				
Dead Leg Type		X			
Termination					
Fixture served					
Valve Type	Gate,Ball,Ball				
Pipe Length	3'				
Pipe Size	3/4",3/4",1/2"				
Pipe Function	DCW/DHW/DHWR				
Pipe Material	Copper				
Length of non insulated pipe	3',None,1'				
Building #	1		Comments DCW is capped. DHW/DHWR are both open.		
Floor Number	BASEMENT				
Room Number	2				
Location in Room	FRONT NORTH				
Demo Needed? Y/N	N				
Drawing #					
Picture of Dead Leg (or area of termination)					
					
Date of Inspection: 07/09/2014					


Dead Leg Criteria Checklist											
	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture							
Dead Leg #	1-BASEMENT-002-022										
Dead Leg Type		X									
Termination	Capped										
Fixture served											
Valve Type											
Pipe Length	6',3'										
Pipe Size	1 1/2",1"										
Pipe Function	DCW/DHWR										
Pipe Material	Copper										
Length of non insulated pipe	2'										
Building #	1		Comments								
Floor Number	BASEMENT										
Room Number	2										
Location in Room	FRONT NORTH										
Demo Needed? Y/N	N										
Drawing #											
Picture of Dead Leg (or area of termination)											
											
Date of Inspection: 07/09/2014											


Dead Leg Criteria Checklist					
	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture	
Dead Leg #	1-BASEMENT-002-023				
Dead Leg Type		X			
Termination	Capped				
Fixture served					
Valve Type					
Pipe Length	5'-6"				
Pipe Size	3/4"				
Pipe Function	DCW				
Pipe Material	Copper				
Length of non insulated pipe	5'-6"				
Building #	1		Comments		
Floor Number	BASEMENT				
Room Number	2				
Location in Room	FRONT NORTH				
Demo Needed? Y/N	N				
Drawing #					
Picture of Dead Leg (or area of termination)					
					
Date of Inspection: 07/09/2014					


Dead Leg Criteria Checklist					
	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture	
Dead Leg #	1-BASEMENT-002-024				
Dead Leg Type		X			
Termination	Capped				
Fixture served					
Valve Type	Gate				
Pipe Length	9'				
Pipe Size	1"				
Pipe Function	DCW				
Pipe Material	Galv.				
Length of non insulated pipe	9'				
Building #	1		Comments		
Floor Number	BASEMENT				
Room Number	2				
Location in Room	FRONT NORTH				
Demo Needed? Y/N	N				
Drawing #					
Picture of Dead Leg (or area of termination)					
					
Date of Inspection: 07/09/2014					


Dead Leg Criteria Checklist					
	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture	
Dead Leg #	1-BASEMENT-002-025				
Dead Leg Type		X			
Termination	Capped				
Fixture served					
Valve Type	Gate				
Pipe Length	3'-4"				
Pipe Size	3/4"				
Pipe Function	DCW				
Pipe Material	Copper				
Length of non insulated pipe	3'-4"				
Building #	1		Comments		
Floor Number	BASEMENT				
Room Number	2				
Location in Room	FRONT NORTH				
Demo Needed? Y/N	N				
Drawing #					
Picture of Dead Leg (or area of termination)					
					
Date of Inspection: 07/09/2014					


Dead Leg Criteria Checklist					
	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture	
Dead Leg #	1-BASEMENT-002-026				
Dead Leg Type		X			
Termination	Capped				
Fixture served					
Valve Type	Gate				
Pipe Length	5'				
Pipe Size	1/2"				
Pipe Function	DCW				
Pipe Material	Copper				
Length of non insulated pipe	5'				
Building #	1		Comments		
Floor Number	BASEMENT				
Room Number	2				
Location in Room	FRONT NORTH				
Demo Needed? Y/N	N				
Drawing #					
Picture of Dead Leg (or area of termination)					
					
Date of Inspection: 07/09/2014					


Dead Leg Criteria Checklist											
	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture							
Dead Leg #	1-BASEMENT-002-027										
Dead Leg Type		X									
Termination	Capped										
Fixture served											
Valve Type	Ball										
Pipe Length	22'										
Pipe Size	1/2"										
Pipe Function	DCW										
Pipe Material	Copper										
Length of non insulated pipe	1'										
Building #	1		Comments								
Floor Number	BASEMENT										
Room Number	2										
Location in Room	FRONT SOUTH										
Demo Needed? Y/N	N										
Drawing #											
Picture of Dead Leg (or area of termination)											
											
Date of Inspection: 07/10/2014											


Dead Leg Criteria Checklist					
	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture	
Dead Leg #	1-BASEMENT-002-028				
Dead Leg Type		X			
Termination	Capped				
Fixture served	-				
Valve Type	Ball				
Pipe Length	22'				
Pipe Size	1/2"				
Pipe Function	DHW				
Pipe Material	Copper				
Length of non insulated pipe	1'				
Building #	1		Comments		
Floor Number	BASEMENT				
Room Number	2				
Location in Room	FRONT SOUTH				
Demo Needed? Y/N	N				
Drawing #					
Picture of Dead Leg (or area of termination)					
					
Date of Inspection: 07/10/2014					


Dead Leg Criteria Checklist					
	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture	
Dead Leg #	1-BASEMENT-002-029				
Dead Leg Type		X			
Termination	Capped				
Fixture served	-				
Valve Type	Ball				
Pipe Length	12' / 12'				
Pipe Size	1/2" / 1/2"				
Pipe Function	DCW / DHW				
Pipe Material	Copper				
Length of non insulated pipe	-				
Building #	1		Comments		
Floor Number	BASEMENT				
Room Number	2				
Location in Room	FRONT SOUTH				
Demo Needed? Y/N	N				
Drawing #					
Picture of Dead Leg (or area of termination)					
					
Date of Inspection: 07/10/2014					


Dead Leg Criteria Checklist					
	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture	
Dead Leg #	1-G-55-001				
Dead Leg Type		X			
Termination	Capped / Valve				
Fixture served	-				
Valve Type	Gate				
Pipe Length	25'				
Pipe Size	3/4"				
Pipe Function	DHW				
Pipe Material	Copper				
Length of non insulated pipe	15'				
Building #	1		Comments End's in Basement.		
Floor Number	Ground Floor				
Room Number	55				
Location in Room	LEFT OF ENTRANCE				
Demo Needed? Y/N	N				
Drawing #					
Picture of Dead Leg (or area of termination)					
					
Date of Inspection: 07/10/2014					

Dead Leg Criteria Checklist					
	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture	
Dead Leg #	1-G-014-001				
Dead Leg Type		X			
Termination	Capped				
Fixture served	-				
Valve Type	-				
Pipe Length	16'				
Pipe Size	3/4"				
Pipe Function	DCW				
Pipe Material	Copper				
Length of non insulated pipe					
Building #	1		Comments		
Floor Number	Ground				
Room Number	14				
Location in Room	Right of Entrance				
Demo Needed? Y/N	Y				
Drawing #					
Picture of Dead Leg (or area of termination)					
					
Date of Inspection: 07/10/2014					

Dead Leg Criteria Checklist					
	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture	
Dead Leg #	1-G-051-001				
Dead Leg Type		X			
Termination	Capped				
Fixture served	-				
Valve Type	-				
Pipe Length	42'				
Pipe Size	1/2"				
Pipe Function	DCW				
Pipe Material	Copper				
Length of non insulated pipe					
Building #	1		Comments		
Floor Number	Ground				
Room Number	51				
Location in Room	Back Center				
Demo Needed? Y/N	Y				
Drawing #					
Picture of Dead Leg (or area of termination)					
					
Date of Inspection: 07/15/2014					

Dead Leg Criteria Checklist					
	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture	
Dead Leg #	1-G-041-001				
Dead Leg Type		X			
Termination	Capped				
Fixture served	-				
Valve Type	Ball				
Pipe Length	5'				
Pipe Size	1/2"				
Pipe Function	DCW / DWH				
Pipe Material	Copper				
Length of non insulated pipe	None				
Building #	1		Comments		
Floor Number	Ground				
Room Number	41				
Location in Room	Above Toilet				
Demo Needed? Y/N	Y				
Drawing #					
Picture of Dead Leg (or area of termination)					
					
Date of Inspection: 07/15/2014					

Dead Leg Criteria Checklist					
	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture	
Dead Leg #	1-1-132-001				
Dead Leg Type		X			
Termination	Capped				
Fixture served	-				
Valve Type	Ball				
Pipe Length	16'				
Pipe Size	3/4"				
Pipe Function	DCW / DHW				
Pipe Material	Copper				
Length of non insulated pipe	-				
Building #	1		Comments		
Floor Number	1				
Room Number	132				
Location in Room	Left of Pipe chase				
Demo Needed? Y/N	y				
Drawing #					
Picture of Dead Leg (or area of termination)					
					
Date of Inspection: 07/17/2014					

Dead Leg Criteria Checklist					
	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture	
Dead Leg #	1-1-149A-001				
Dead Leg Type		X			
Termination	Capped				
Fixture served	-				
Valve Type	-				
Pipe Length	12'				
Pipe Size	1", 3/4", 1/2"				
Pipe Function	DCW / DHW / DHWR				
Pipe Material	Galv., Cu, Cu				
Length of non insulated pipe	Less than 6"				
Building #	1		Comments		
Floor Number	1				
Room Number	149A				
Location in Room	Along Exterior Wall				
Demo Needed? Y/N	y				
Drawing #					
Picture of Dead Leg (or area of termination)					
					
Date of Inspection: 07/17/2014					


Dead Leg Criteria Checklist										
Description		Pipe Length greater than three feet terminating at a cap, valve, or fitting		Pipe length greater than three feet terminating at an infrequently used plumbing fixture		Pipe length greater than 25 feet terminating at a frequently used plumbing fixture				
Dead Leg #	1-1-113A-001									
Dead Leg Type					X					
Termination	Bathroom Group									
Fixture served	Water closet & sink									
Valve Type	NA									
Pipe Length	12'									
Pipe Size	1/2"									
Pipe Function	DCW, DHW									
Pipe Material										
Length of non insulated pipe										
Building #	1				Comments					
Floor Number	1									
Room Number	113A									
Location in Room										
Demo Needed? Y/N	Y									
Drawing #										
Picture of Dead Leg (or area of termination)										
Date of Inspection	19-Aug									




	Dead Leg Criteria Checklist						
	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture			
Dead Leg #	1-2-251-001						
Dead Leg Type				X			
Termination	sink						
Fixture served	mop sink						
Valve Type	NA						
Pipe Length	20'						
Pipe Size	1/2"						
Pipe Function	DCW, DHW						
Pipe Material	copper						
Length of non insulated pipe							
Building #	1		Comments				
Floor Number	2						
Room Number	251						
Location in Room							
Room	rear						
Demo Needed? Y/N	Y						
Drawing #							
Picture of Dead Leg (or area of termination)							
Date of Inspection							19-Aug


Dead Leg Criteria Checklist									
	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture					
Dead Leg #	1-4-426-001								
Dead Leg Type			X						
Termination	sink								
Fixture served	sink								
Valve Type	NA								
Pipe Length	25'								
Pipe Size	1/2"								
Pipe Function	DCW, DHW								
Pipe Material	copper								
Length of non insulated pipe									
Building #	1		Comments						
Floor Number	4								
Room Number	426								
Location in Room	corner								
Demo Needed? Y/N	Y								
Drawing #									
Picture of Dead Leg (or area of termination)									
						Date of Inspection	19-Aug		


Dead Leg Criteria Checklist									
	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture					
Dead Leg #	1-5-575-001								
Dead Leg Type			X						
Termination	sink								
Fixture served	hand sink								
Valve Type	ball								
Pipe Length	16'								
Pipe Size	1/2"								
Pipe Function	DCW, DHW								
Pipe Material									
Length of non insulated pipe									
Building #	1		Comments						
Floor Number	5								
Room Number	575								
Location in Room	center								
Demo Needed? Y/N	Y								
Drawing #									
Picture of Dead Leg (or area of termination)									
Date of Inspection	19-Aug								


Dead Leg Criteria Checklist									
	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture					
Dead Leg #	1-5-581-001								
Dead Leg Type			X						
Termination	sink								
Fixture served	sink								
Valve Type	ball								
Pipe Length	10'								
Pipe Size	1/2"								
Pipe Function	DCW, DHW								
Pipe Material									
Length of non insulated pipe									
Building #	1		Comments						
Floor Number	5								
Room Number	581								
Location in Room	rear								
Demo Needed? Y/N	Y								
Drawing #									
Picture of Dead Leg (or area of termination)									
						Date of Inspection	19-Aug		


Dead Leg Criteria Checklist					
	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture	
Dead Leg #	1-3-326-001				
Dead Leg Type		X			
Termination	Capped				
Fixture served	-				
Valve Type	-				
Pipe Length	3'				
Pipe Size	1/2"				
Pipe Function	DHW				
Pipe Material	Copper				
Length of non insulated pipe	None				
Building #	1		Comments DCW Cut on other Side of Wall		
Floor Number	3				
Room Number	326				
Location in Room	Left of Entrance				
Demo Needed? Y/N	Y				
Drawing #					
Picture of Dead Leg (or area of termination)					
					
Date of Inspection: 07/16/2014					


Dead Leg Criteria Checklist					
	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture	
Dead Leg #	1-4-407-001				
Dead Leg Type		X			
Termination	Capped				
Fixture served	-				
Valve Type	-				
Pipe Length	12'				
Pipe Size	1-1/2" / 3/4" / 1/2"				
Pipe Function	DCW / DHW / DHWR				
Pipe Material	Copper				
Length of non insulated pipe	None				
Building #	1		Comments 12' to floor below		
Floor Number	4				
Room Number	407				
Location in Room	Back Left				
Demo Needed? Y/N	Y				
Drawing #					
Picture of Dead Leg (or area of termination)					
					
Date of Inspection: 07/16/2014					


Dead Leg Criteria Checklist					
	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture	
Dead Leg #	1-5-567-001				
Dead Leg Type		X			
Termination	Capped				
Fixture served	-				
Valve Type	-				
Pipe Length	5'				
Pipe Size	1/2"				
Pipe Function	DCW / DHW				
Pipe Material	Copper				
Length of non insulated pipe	None				
Building #	1		Comments		
Floor Number	5				
Room Number	567				
Location in Room	Left of Entrance				
Demo Needed? Y/N	Y				
Drawing #					
Picture of Dead Leg (or area of termination)					
					
Date of Inspection: 07/17/2014					


Dead Leg Criteria Checklist					
	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture	
Dead Leg #	1-5-573-001				
Dead Leg Type		X			
Termination	Capped				
Fixture served	-				
Valve Type	-				
Pipe Length	5'				
Pipe Size	1/2"				
Pipe Function	DCW / DHW				
Pipe Material	Copper				
Length of non insulated pipe	None				
Building #	1		Comments		
Floor Number	5				
Room Number	573				
Location in Room	Back Wall from Entrance				
Demo Needed? Y/N	Y				
Drawing #					
Picture of Dead Leg (or area of termination)					
					
Date of Inspection: 07/17/2014					


Dead Leg Criteria Checklist					
	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture	
Dead Leg #	1-5-574-001				
Dead Leg Type		X			
Termination	Capped				
Fixture served	-				
Valve Type	-				
Pipe Length	5'				
Pipe Size	1/2"				
Pipe Function	DCW / DHW				
Pipe Material	Copper				
Length of non insulated pipe	None				
Building #	1		Comments		
Floor Number	5				
Room Number	574				
Location in Room	Left of Entrance				
Demo Needed? Y/N	Y				
Drawing #					
Picture of Dead Leg (or area of termination)					
					
Date of Inspection: 07/17/2014					


Dead Leg Criteria Checklist					
	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture	
Dead Leg #	1-5-576-001				
Dead Leg Type		X			
Termination	Capped				
Fixture served	-				
Valve Type	-				
Pipe Length	5'				
Pipe Size	1/2"				
Pipe Function	DCW / DHW				
Pipe Material	Copper				
Length of non insulated pipe	None				
Building #	1		Comments		
Floor Number	5				
Room Number	576				
Location in Room	Right of Entrance				
Demo Needed? Y/N	Y				
Drawing #					
Picture of Dead Leg (or area of termination)					
					
Date of Inspection: 07/17/2014					


Dead Leg Criteria Checklist					
	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture	
Dead Leg #	1-5-577-001				
Dead Leg Type		X			
Termination	Capped				
Fixture served	-				
Valve Type	-				
Pipe Length	5'				
Pipe Size	1/2"				
Pipe Function	DCW / DHW				
Pipe Material	Copper				
Length of non insulated pipe	None				
Building #	1		Comments		
Floor Number	5				
Room Number	577				
Location in Room	Back from Entrance				
Demo Needed? Y/N	Y				
Drawing #					
Picture of Dead Leg (or area of termination)					
					
Date of Inspection: 07/16/2014					


Dead Leg Criteria Checklist					
	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture	
Dead Leg #	1-5-578-001				
Dead Leg Type		X			
Termination	Capped				
Fixture served	-				
Valve Type	-				
Pipe Length	5'				
Pipe Size	1/2"				
Pipe Function	DCW / DHW				
Pipe Material	Copper				
Length of non insulated pipe	None				
Building #	1		Comments		
Floor Number	5				
Room Number	578				
Location in Room	In front of Entrance				
Demo Needed? Y/N	Y				
Drawing #					
Picture of Dead Leg (or area of termination)					
					
Date of Inspection: 07/16/2014					


Dead Leg Criteria Checklist					
	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture	
Dead Leg #	1-5-580-001				
Dead Leg Type		X			
Termination	Capped				
Fixture served	-				
Valve Type	-				
Pipe Length	5'				
Pipe Size	1/2"				
Pipe Function	DCW / DHW				
Pipe Material	Copper				
Length of non insulated pipe	None				
Building #	1		Comments		
Floor Number	5				
Room Number	580				
Location in Room	Back right from Entrance				
Demo Needed? Y/N	Y				
Drawing #					
Picture of Dead Leg (or area of termination)					
					
Date of Inspection: 07/16/2014					


Dead Leg Criteria Checklist											
	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture							
Dead Leg #	1-5-566-001										
Dead Leg Type		X									
Termination	Capped										
Fixture served	-										
Valve Type	-										
Pipe Length	5'										
Pipe Size	1/2"										
Pipe Function	DCW / DHW										
Pipe Material	Copper										
Length of non insulated pipe	None										
Building #	1		Comments								
Floor Number	5										
Room Number	566										
Location in Room	Back right from Entrance										
Demo Needed? Y/N	Y										
Drawing #											
Picture of Dead Leg (or area of termination)											
											
Date of Inspection: 07/16/2014											

Dead Leg Criteria Checklist											
	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture							
Dead Leg #	1-5-582-001										
Dead Leg Type		X									
Termination	Capped										
Fixture served	-										
Valve Type	-										
Pipe Length	5'										
Pipe Size	1/2"										
Pipe Function	DCW / DHW										
Pipe Material	Copper										
Length of non insulated pipe	None										
Building #	1		Comments								
Floor Number	5										
Room Number	582										
Location in Room	Back right from Entrance										
Demo Needed? Y/N	Y										
Drawing #											
Picture of Dead Leg (or area of termination)											
											
Date of Inspection: 07/16/2014											


Dead Leg Criteria Checklist					
	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture	
Dead Leg #	1-5-584-001				
Dead Leg Type		X			
Termination	Capped				
Fixture served	-				
Valve Type	-				
Pipe Length	5'				
Pipe Size	1/2"				
Pipe Function	DCW / DHW				
Pipe Material	Copper				
Length of non insulated pipe	None				
Building #	1		Comments		
Floor Number	5				
Room Number	584				
Location in Room	Right of Entrance				
Demo Needed? Y/N	Y				
Drawing #					
Picture of Dead Leg (or area of termination)					
					
Date of Inspection: 07/16/2014					

Dead Leg Criteria Checklist					
	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture	
Dead Leg #	1-5-585-001				
Dead Leg Type		X			
Termination	Capped				
Fixture served	-				
Valve Type	-				
Pipe Length	5'				
Pipe Size	1/2"				
Pipe Function	DCW / DHW				
Pipe Material	Copper				
Length of non insulated pipe	None				
Building #	1		Comments		
Floor Number	5				
Room Number	585				
Location in Room	Left of Entrance				
Demo Needed? Y/N	Y				
Drawing #					
Picture of Dead Leg (or area of termination)					
					
Date of Inspection: 07/16/2014					

Dead Leg Criteria Checklist					
	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture	
Dead Leg #	1-6-617-001				
Dead Leg Type		X			
Termination	Capped				
Fixture served	-				
Valve Type	Gate				
Pipe Length	50'				
Pipe Size	1/2"				
Pipe Function	DCW				
Pipe Material	Copper				
Length of non insulated pipe	None				
Building #	1		Comments		
Floor Number	6				
Room Number	617				
Location in Room	Right of Entrance				
Demo Needed? Y/N	N				
Drawing #					
Picture of Dead Leg (or area of termination)					
					
Date of Inspection: 07/17/2014					

Dead Leg Criteria Checklist					
	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture	
Dead Leg #	1-6-618-001				
Dead Leg Type		X			
Termination	Capped				
Fixture served	-				
Valve Type	Gate				
Pipe Length	10'				
Pipe Size	3/4"				
Pipe Function	DCW				
Pipe Material	Copper				
Length of non insulated pipe	None				
Building #	1		Comments See drawing for location.		
Floor Number	6				
Room Number	618				
Location in Room					
Demo Needed? Y/N	N				
Drawing #					
Picture of Dead Leg (or area of termination)					
					
Date of Inspection: 07/17/2014					

Dead Leg Criteria Checklist					
	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture	
Dead Leg #	1-6-603-001				
Dead Leg Type		X			
Termination	Capped				
Fixture served	-				
Valve Type	Ball,Ball,Gate				
Pipe Length	3'				
Pipe Size	1/2"				
Pipe Function	DCW / DHW				
Pipe Material	Copper				
Length of non insulated pipe	None				
Building #	1		Comments Can't access, but know what and where it is.		
Floor Number	6				
Room Number	603				
Location in Room	Back Left Wall				
Demo Needed? Y/N	Y				
Drawing #					
Picture of Dead Leg (or area of termination)					
	NO PICTURE				
Date of Inspection: 07/17/2014					

Dead Leg Criteria Checklist					
	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture	
Dead Leg #	1-6-613-001				
Dead Leg Type		X			
Termination	Capped				
Fixture served	-				
Valve Type	Ball,Ball,Gate				
Pipe Length	3'				
Pipe Size	3/4"				
Pipe Function	DCW / DCW / DHW				
Pipe Material	Copper				
Length of non insulated pipe	None				
Building #	1		Comments		
Floor Number	6				
Room Number	613				
Location in Room	Center Floor				
Demo Needed? Y/N	Y				
Drawing #					
Picture of Dead Leg (or area of termination)					
					
Date of Inspection: 07/17/2014					