




Dead Leg Criteria Checklist

	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture	
Dead Leg #	17-B-001-001				
Dead Leg Type		X			
Termination	CAPPED				
Fixture served	-				
Valve Type	BALL				
Pipe Length	5'				
Pipe Size	1"				
Pipe Function	DCW				
Pipe Material	COPPER				
Length of non insulated pipe	-				
Building #	17		Comments		
Floor Number	Basement				
Room Number	1				
Location in Room	Area A				
Demo Needed? Y/N	N				
Drawing #					
Picture of Dead Leg (or area of termination)					
					
Date of Inspection: 06/12/2014					


Dead Leg Criteria Checklist

	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture	
Dead Leg #	17-B-001-002				
Dead Leg Type		X			
Termination	CAPPED				
Fixture served	-				
Valve Type	BALL				
Pipe Length	5'				
Pipe Size	1"				
Pipe Function	DCW				
Pipe Material	COPPER				
Length of non insulated pipe	-				
Building #	17		Comments		
Floor Number	Basement		Valve less then 1' from main.		
Room Number	1				
Location in Room	Area A				
Demo Needed? Y/N	N				
Drawing #					
Picture of Dead Leg (or area of termination)					
					
Date of Inspection: 06/12/2014					


Dead Leg Criteria Checklist


	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture	
Dead Leg #	17-B-001-003				
Dead Leg Type		X			
Termination	CAPPED				
Fixture served	-				
Valve Type	BALL				
Pipe Length	4'				
Pipe Size	1/2"				
Pipe Function	DCW				
Pipe Material	COPPER				
Length of non insulated pipe	-				
Building #	17		Comments		
Floor Number	Basement				
Room Number	1				
Location in Room	Area A				
Demo Needed? Y/N	N				
Drawing #					
Picture of Dead Leg (or area of termination)					
					
Date of Inspection: 06/12/2014					


Dead Leg Criteria Checklist

	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture	
Dead Leg #	17-B-001-004				
Dead Leg Type		X			
Termination	CAPPED				
Fixture served	-				
Valve Type	BALL				
Pipe Length	4'				
Pipe Size	1/2"				
Pipe Function	DCW / DHW				
Pipe Material	COPPER				
Length of non insulated pipe	30"				
Building #	17		Comments		
Floor Number	Basement				
Room Number	1				
Location in Room	Area A				
Demo Needed? Y/N	N				
Drawing #					
Picture of Dead Leg (or area of termination)					
					
Date of Inspection: 06/12/2014					


Dead Leg Criteria Checklist

	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture	
Dead Leg #	17-B-001-005				
Dead Leg Type		X			
Termination	CAPPED				
Fixture served	-				
Valve Type	BALL				
Pipe Length	8'				
Pipe Size	2-1/2"				
Pipe Function	DCW				
Pipe Material	COPPER				
Length of non insulated pipe	-				
Building #	17		Comments		
Floor Number	Basement				
Room Number	1				
Location in Room	Area A				
Demo Needed? Y/N	N				
Drawing #					
Picture of Dead Leg (or area of termination)					
					
Date of Inspection: 06/12/2014					

Dead Leg Criteria Checklist					
	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture	
Dead Leg #	17-B-001-006				
Dead Leg Type		X			
Termination	CAPPED				
Fixture served	-				
Valve Type	BALL				
Pipe Length	3'-6"				
Pipe Size	1-1/2"				
Pipe Function	DCW				
Pipe Material	COPPER				
Length of non insulated pipe	-				
Building #	17		Comments		
Floor Number	Basement				
Room Number	1				
Location in Room	Area A				
Demo Needed? Y/N	N				
Drawing #					
Picture of Dead Leg (or area of termination)					
					
Date of Inspection: 06/12/2014					


Dead Leg Criteria Checklist					
	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture	
Dead Leg #	17-B-001-007				
Dead Leg Type		X			
Termination	CAPPED				
Fixture served	-				
Valve Type	BALL				
Pipe Length	11'-4"				
Pipe Size	2"				
Pipe Function	DCW				
Pipe Material	COPPER				
Length of non insulated pipe	-				
Building #	17		Comments		
Floor Number	Basement				
Room Number	1				
Location in Room	Area A				
Demo Needed? Y/N	N				
Drawing #					
Picture of Dead Leg (or area of termination)					
					
Date of Inspection: 06/12/2014					


Dead Leg Criteria Checklist

	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture	
Dead Leg #	17-B-001-008				
Dead Leg Type		X			
Termination	CAPPED				
Fixture served	-				
Valve Type	GATE				
Pipe Length	6'				
Pipe Size	1 1/4"				
Pipe Function	DHW				
Pipe Material	COPPER				
Length of non insulated pipe	3"				
Building #	17		Comments		
Floor Number	Basement				
Room Number	1				
Location in Room	Area A				
Demo Needed? Y/N	N				
Drawing #					
Picture of Dead Leg (or area of termination)					
					
Date of Inspection: 06/13/2014					


Dead Leg Criteria Checklist					
	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture	
Dead Leg #	17-B-001-009				
Dead Leg Type		X			
Termination	CAPPED				
Fixture served	-				
Valve Type	BALL				
Pipe Length	3'				
Pipe Size	2"				
Pipe Function	DCW				
Pipe Material	COPPER				
Length of non insulated pipe	-				
Building #	17		Comments		
Floor Number	Basement		NO PHOTO AT THIS TIME		
Room Number	1				
Location in Room					
Room	Area A				
Demo Needed? Y/N	N				
Drawing #					
Picture of Dead Leg (or area of termination)					
Date of Inspection: 06/13/2014					


Dead Leg Criteria Checklist


	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture	
Dead Leg #	17-B-MECH-001				
Dead Leg Type		X			
Termination	CAPPED				
Fixture served	-				
Valve Type	BALL				
Pipe Length	7'				
Pipe Size	1/2"				
Pipe Function	DCW				
Pipe Material	COPPER				
Length of non insulated pipe	-				
Building #	17		Comments		
Floor Number	Basement		NO PHOTO AT THIS TIME		
Room Number	MECH.				
Location in Room	Center				
Demo Needed? Y/N	N				
Drawing #					
Picture of Dead Leg (or area of termination)					
					
Date of Inspection: 06/12/2014					


Dead Leg Criteria Checklist					
	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture	
Dead Leg #	17-B-001-010				
Dead Leg Type		X			
Termination	Cap				
Fixture served	-				
Valve Type	Ball				
Pipe Length	3'				
Pipe Size	2"				
Pipe Function	DCW				
Pipe Material	Copper				
Length of non insulated pipe	-				
Building #	17		Comments		
Floor Number	BASEMENT				
Room Number	2				
Location in Room	Center				
Demo Needed? Y/N	N				
Drawing #					
Picture of Dead Leg (or area of termination)					
					
Date of Inspection: 07/18/2014					


Dead Leg Criteria Checklist

	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture	
Dead Leg #	17-B-001-011				
Dead Leg Type		X			
Termination	Cap				
Fixture served	-				
Valve Type	Ball				
Pipe Length	3'				
Pipe Size	2'				
Pipe Function	DCW				
Pipe Material	Copper				
Length of non insulated pipe	-				
Building #	17		Comments		
Floor Number	BASEMENT				
Room Number	2				
Location in Room	CENTER				
Demo Needed? Y/N	N				
Drawing #					
Picture of Dead Leg (or area of termination)					
					
Date of Inspection: 07/18/2014					


Dead Leg Criteria Checklist					
	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture	
Dead Leg #	17-B-001-012				
Dead Leg Type		X			
Termination	Cap				
Fixture served	-				
Valve Type	Gate				
Pipe Length	22'				
Pipe Size					
Pipe Function	DHW				
Pipe Material	Copper				
Length of non insulated pipe	-				
Building #	17		Comments		
Floor Number	BASEMENT				
Room Number	2				
Location in Room	CENTER				
Demo Needed? Y/N	N				
Drawing #					
Picture of Dead Leg (or area of termination)					
					
Date of Inspection: 07/18/2014					


Dead Leg Criteria Checklist					
	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture	
Dead Leg #	17-B-001-013				
Dead Leg Type		X			
Termination	Cap				
Fixture served	-				
Valve Type	Ball				
Pipe Length	8'				
Pipe Size	3/4"				
Pipe Function	DCW				
Pipe Material	Copper				
Length of non insulated pipe	-				
Building #	17		Comments		
Floor Number	BASEMENT				
Room Number	3				
Location in Room	CENTER				
Demo Needed? Y/N	N				
Drawing #					
Picture of Dead Leg (or area of termination)					
					
Date of Inspection: 07/18/2014					

Dead Leg Criteria Checklist					
	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture	
Dead Leg #	17-B-001-014				
Dead Leg Type		X			
Termination	Cap				
Fixture served	-				
Valve Type	Gate				
Pipe Length	7'				
Pipe Size	3/4"				
Pipe Function	DHW				
Pipe Material	Copper				
Length of non insulated pipe	-				
Building #	17		Comments		
Floor Number	BASEMENT				
Room Number	3				
Location in Room	BETWEEN CENTER AND B Area				
Demo Needed? Y/N	N				
Drawing #					
Picture of Dead Leg (or area of termination)					
					
Date of Inspection: 07/18/2014					


Dead Leg Criteria Checklist					
	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture	
Dead Leg #	17-B-001-015				
Dead Leg Type		X			
Termination	Cut				
Fixture served	-				
Valve Type	Gate				
Pipe Length	3'				
Pipe Size	3/4"				
Pipe Function	DHW				
Pipe Material	Copper				
Length of non insulated pipe	-				
Building #	17		Comments		
Floor Number	BASEMENT				
Room Number	3				
Location in Room	AREA B				
Demo Needed? Y/N	N				
Drawing #					
Picture of Dead Leg (or area of termination)					
					
Date of Inspection: 07/18/2014					


Dead Leg Criteria Checklist


	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture	
Dead Leg #	17-B-001-016				
Dead Leg Type		X			
Termination	Open				
Fixture served	-				
Valve Type	Gate				
Pipe Length	5' / 6'				
Pipe Size	3/4" / 1/2"				
Pipe Function	DHW / DHWR				
Pipe Material	Copper				
Length of non insulated pipe	All				
Building #	17		Comments		
Floor Number	BASEMENT				
Room Number	3				
Location in Room	AREA B				
Demo Needed? Y/N	N				
Drawing #					
Picture of Dead Leg (or area of termination)					
					
Date of Inspection: 07/18/2014					

Dead Leg Criteria Checklist					
	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture	
Dead Leg #	17-B-001-017				
Dead Leg Type		X			
Termination	Cap				
Fixture served	-				
Valve Type	Gate				
Pipe Length	4'				
Pipe Size	3/4"				
Pipe Function	DHW				
Pipe Material	Copper				
Length of non insulated pipe	-				
Building #	17		Comments		
Floor Number	BASEMENT				
Room Number	3				
Location in Room	AREA B				
Demo Needed? Y/N	N				
Drawing #					
Picture of Dead Leg (or area of termination)					
					
Date of Inspection: 07/18/2014					


Dead Leg Criteria Checklist

	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture	
Dead Leg #	17-B-001-018				
Dead Leg Type		X			
Termination	Cap				
Fixture served	-				
Valve Type	Ball				
Pipe Length	25'				
Pipe Size	1 1/2"				
Pipe Function	DCW				
Pipe Material	Copper				
Length of non insulated pipe	-				
Building #	17		Comments		
Floor Number	BASEMENT				
Room Number	3				
Location in Room	AREA B				
Demo Needed? Y/N	N				
Drawing #					
Picture of Dead Leg (or area of termination)					
					
Date of Inspection: 07/18/2014					

Dead Leg Criteria Checklist					
	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture	
Dead Leg #	17-B-001-019				
Dead Leg Type		X			
Termination	Cap				
Fixture served	-				
Valve Type	Gate				
Pipe Length	12'				
Pipe Size	3/4"				
Pipe Function	DHW				
Pipe Material	Copper				
Length of non insulated pipe	Less than 1'				
Building #	17		Comments		
Floor Number	BASEMENT				
Room Number	3				
Location in Room	AREA B				
Demo Needed? Y/N	N				
Drawing #					
Picture of Dead Leg (or area of termination)					
					
Date of Inspection: 07/18/2014					


Dead Leg Criteria Checklist											
	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture							
Dead Leg #	17-B-001-020										
Dead Leg Type		X									
Termination	Cap										
Fixture served	-										
Valve Type	Ball, Gate, Gate										
Pipe Length	4', 23', 15'										
Pipe Size	1/2"										
Pipe Function	DCW / DHW / DHWR										
Pipe Material	Copper										
Length of non insulated pipe	Yes										
Building #	17		Comments								
Floor Number	BASEMENT										
Room Number	3										
Location in Room	AREA B										
Demo Needed? Y/N	N										
Drawing #											
Picture of Dead Leg (or area of termination)											
											
Date of Inspection: 07/18/2014											

Dead Leg Criteria Checklist


	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture	
Dead Leg #	17-2-203-001				
Dead Leg Type		X			
Termination	CAPPED				
Fixture served	-				
Valve Type	NA				
Pipe Length	4', 4'				
Pipe Size	1 1/2", 3/4"				
Pipe Function	DCW, DHW				
Pipe Material	GALV, GALV				
Length of non insulated pipe	-				
Building #	17		Comments		
Floor Number	2ND FLOOR				
Room Number	MECH.				
Location in Room	Center				
Demo Needed? Y/N	N				
Drawing #					
Picture of Dead Leg (or area of termination)					
					
Date of Inspection: 06/25/2014					

Dead Leg Criteria Checklist

	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture							
Dead Leg #	17-2-217-001										
Dead Leg Type		X									
Termination	CAPPED										
Fixture served	-										
Valve Type	NA										
Pipe Length	10', 8'										
Pipe Size	1", 1"										
Pipe Function	DCW, DHW										
Pipe Material	CU, CU										
Length of non insulated pipe	-										
Building #	17		Comments								
Floor Number	2ND FLOOR										
Room Number	217										
Location in Room	CHASE										
Demo Needed? Y/N	Y										
Drawing #											
Picture of Dead Leg (or area of termination)											
Date of Inspection: 06/25/2014											


Dead Leg Criteria Checklist					
	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture	
Dead Leg #	17-2-220-001				
Dead Leg Type		X			
Termination	CAPPED				
Fixture served	-				
Valve Type	NA				
Pipe Length	3', 3'				
Pipe Size	3/4", 1/2'				
Pipe Function	DCW, DHW				
Pipe Material	GALV, CU				
Length of non insulated pipe	-				
Building #	17		Comments		
Floor Number	2ND FLOOR				
Room Number	220				
Location in Room	CLG				
Demo Needed? Y/N	N				
Drawing #					
Picture of Dead Leg (or area of termination)					
					
Date of Inspection: 06/25/2014					

Dead Leg Criteria Checklist


	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture	
Dead Leg #	17-2-267-001				
Dead Leg Type		X			
Termination	CAP/ VALVE/CAP				
Fixture served	-				
Valve Type	NA/GATE				
Pipe Length	4', 4'				
Pipe Size	3/4", 3/4"				
Pipe Function	DCW, DHW				
Pipe Material	GALV, CU				
Length of non insulated pipe	-				
Building #	17		Comments		
Floor Number	2ND FLOOR				
Room Number	267				
Location in Room	CLG				
Demo Needed? Y/N	N				
Drawing #					
Picture of Dead Leg (or area of termination)					
					
Date of Inspection: 06/25/2014					

Dead Leg Criteria Checklist					
	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture	
Dead Leg #	17-3-372-001				
Dead Leg Type		X			
Termination	CAP				
Fixture served	-				
Valve Type	-				
Pipe Length	3'				
Pipe Size	1"				
Pipe Function	DCW				
Pipe Material	COPPER				
Length of non insulated pipe	-				
Building #	17		Comments		
Floor Number	3RD FLOOR				
Room Number	372				
Location in Room					
Room	BACK				
Demo Needed? Y/N	Y				
Drawing #					
Picture of Dead Leg (or area of termination)					
Date of Inspection: 06/30/2014					


Dead Leg Criteria Checklist

	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture	
Dead Leg #	17-3-398B-001				
Dead Leg Type		X			
Termination	VALVE/CAP				
Fixture served	-				
Valve Type	BALL				
Pipe Length	14'				
Pipe Size					
Pipe Function	DCW/DHW/DHWR				
Pipe Material					
Length of non insulated pipe	-				
Building #	17		Comments		
Floor Number	3RD FLOOR				
Room Number	398B				
Location in Room	BACK WALL				
Demo Needed? Y/N	Y				
Drawing #					
Picture of Dead Leg (or area of termination)					
					
Date of Inspection: 06/30/2014					


Dead Leg Criteria Checklist

	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture	
Dead Leg #	17-3-308-001				
Dead Leg Type		X			
Termination	VALVE/CAP				
Fixture served	-				
Valve Type	GATE				
Pipe Length	12'				
Pipe Size					
Pipe Function	DCW/DHW				
Pipe Material					
Length of non insulated pipe	1'				
Building #	17		Comments		
Floor Number	3RD FLOOR				
Room Number	308				
Location in Room	ENTRANCE				
Demo Needed? Y/N	Y				
Drawing #					
Picture of Dead Leg (or area of termination)					
					
Date of Inspection: 06/30/2014					


Dead Leg Criteria Checklist

	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture	
Dead Leg #	17-3-318-001				
Dead Leg Type		X			
Termination	VALVE/CAP				
Fixture served	-				
Valve Type	NONE				
Pipe Length	4'				
Pipe Size					
Pipe Function	DCW				
Pipe Material					
Length of non insulated pipe	-				
Building #	17		Comments		
Floor Number	3RD FLOOR		4' FROM THE DECK BELOW. DEMO NEEDED DEPENDING ON CHASE BELOW.		
Room Number	318 PIPE CHASE				
Location in Room					
Room	ENTRANCE				
Demo Needed? Y/N	Y				
Drawing #					
Picture of Dead Leg (or area of termination)					
					
Date of Inspection: 06/30/2014					

Dead Leg Criteria Checklist

	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture	
Dead Leg #	17-3-318-002				
Dead Leg Type		X			
Termination	VALVE/CAP				
Fixture served	-				
Valve Type	NONE				
Pipe Length	4'				
Pipe Size					
Pipe Function	DCW				
Pipe Material					
Length of non insulated pipe	-				
Building #	17		Comments		
Floor Number	3RD FLOOR		4' FROM THE DECK BELOW. DEMO NEEDED DEPENDING ON CHASE BELOW.		
Room Number	318 PIPE CHASE				
Location in Room					
Room	ENTRANCE				
Demo Needed? Y/N	Y				
Drawing #					
Picture of Dead Leg (or area of termination)					
					
Date of Inspection: 06/30/2014					


Dead Leg Criteria Checklist

	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture	
Dead Leg #	17-3-316-001				
Dead Leg Type		X			
Termination	VALVE/CAP				
Fixture served	-				
Valve Type	NONE				
Pipe Length	4'				
Pipe Size					
Pipe Function	DCW				
Pipe Material					
Length of non insulated pipe	-				
Building #	17		Comments		
Floor Number	3RD FLOOR		4' FROM THE DECK BELOW. DEMO NEEDED DEPENDING ON CHASE BELOW.		
Room Number	316 PIPE CHASE				
Location in Room					
Room	ENTRANCE				
Demo Needed? Y/N	Y				
Drawing #					
Picture of Dead Leg (or area of termination)					
					
Date of Inspection: 06/30/2014					


Dead Leg Criteria Checklist

	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture							
Dead Leg #	17-3-316-002										
Dead Leg Type		X									
Termination	VALVE/CAP										
Fixture served	-										
Valve Type	NONE										
Pipe Length	4'										
Pipe Size											
Pipe Function	DCW										
Pipe Material											
Length of non insulated pipe	-										
Building #	17		Comments								
Floor Number	3RD FLOOR		4' FROM THE DECK BELOW. DEMO NEEDED DEPENDING ON CHASE BELOW.								
Room Number	316 PIPE CHASE										
Location in Room	ENTRANCE										
Demo Needed? Y/N	Y										
Drawing #											
Picture of Dead Leg (or area of termination)											
Date of Inspection: 06/30/2014											


Dead Leg Criteria Checklist

	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture	
Dead Leg #	17-3-322-001				
Dead Leg Type		X			
Termination	CAP				
Fixture served	-				
Valve Type	NONE				
Pipe Length	13'				
Pipe Size					
Pipe Function	DCW				
Pipe Material					
Length of non insulated pipe	-				
Building #	17		Comments		
Floor Number	3RD FLOOR		GO TO 2ND FLOOR FOR VERIFICATION.		
Room Number	322				
Location in Room	IN PIPE CHASE				
Demo Needed? Y/N	Y				
Drawing #					
Picture of Dead Leg (or area of termination)					
					
Date of Inspection: 06/30/2014					



Dead Leg Criteria Checklist

	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture	
Dead Leg #	17-4-409-001				
Dead Leg Type		X			
Termination	Valved / Capped				
Fixture served	-				
Valve Type	Ball				
Pipe Length	4'				
Pipe Size	1" / 3/4"				
Pipe Function	DCW / DHW				
Pipe Material	Galv. / Copper				
Length of non insulated pipe	4'				
Building #	17		Comments		
Floor Number	4th Floor		Domestic Hot Water and Domestic Hot Water Return are connected		
Room Number	409				
Location in Room					
Demo Needed? Y/N	Y				
Drawing #					
Picture of Dead Leg (or area of termination)					
					
Date of Inspection: 07/01/2014					


Dead Leg Criteria Checklist


	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture	
Dead Leg #	17-4-413-001				
Dead Leg Type		X			
Termination	Capped				
Fixture served	-				
Valve Type	Ball				
Pipe Length	10'				
Pipe Size	3/4"				
Pipe Function	DCW				
Pipe Material	Copper				
Length of non insulated pipe	-				
Building #	17		Comments		
Floor Number	4th Floor		Domestic Hot Water and Domestic Hot Water Return are connected		
Room Number	413				
Location in Room	Back left corner from Entrance				
Demo Needed? Y/N	Y				
Drawing #					
Picture of Dead Leg (or area of termination)					
					
Date of Inspection: 07/01/2014					

Dead Leg Criteria Checklist



	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture	
Dead Leg #	17-4-424-001				
Dead Leg Type		X			
Termination	CAP				
Fixture served	-				
Valve Type	-				
Pipe Length	18'				
Pipe Size	3/4"				
Pipe Function	DCW / DHW				
Pipe Material	copper				
Length of non insulated pipe	-				
Building #	17		Comments		
Floor Number	4th Floor				
Room Number	424				
Location in Room					
Demo Needed? Y/N	Y				
Drawing #					
Picture of Dead Leg (or area of termination)					
					
Date of Inspection: 07/01/2014					

Dead Leg Criteria Checklist



	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture	
Dead Leg #	17-4-436-001				
Dead Leg Type		X			
Termination	Capped / Valved				
Fixture served	-				
Valve Type	Ball				
Pipe Length	3'-6"				
Pipe Size	1"				
Pipe Function	DCW				
Pipe Material	Galv.				
Length of non insulated pipe	-				
Building #	17		Comments		
Floor Number	4th Floor				
Room Number	436				
Location in Room					
Demo Needed? Y/N	Y				
Drawing #					
Picture of Dead Leg (or area of termination)					
					
Date of Inspection: 07/01/2014					

Dead Leg Criteria Checklist					
	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture	
Dead Leg #	17-4-442-001				
Dead Leg Type		X			
Termination	CAP				
Fixture served	-				
Valve Type	-				
Pipe Length	12'				
Pipe Size	1"				
Pipe Function	DCW				
Pipe Material	copper				
Length of non insulated pipe	-				
Building #	17		Comments		
Floor Number	4th Floor		Verify Length on floor below.		
Room Number	442				
Location in Room					
Demo Needed? Y/N	Y				
Drawing #					
Picture of Dead Leg (or area of termination)					
					
Date of Inspection: 07/01/2014					


Dead Leg Criteria Checklist

	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture	
Dead Leg #	17-4-463-001				
Dead Leg Type		X			
Termination	Capped				
Fixture served	-				
Valve Type	-				
Pipe Length	10'				
Pipe Size	3/4"				
Pipe Function	DCW / DHW / DHWR				
Pipe Material	Galv. / Copper				
Length of non insulated pipe	1'				
Building #	17		Comments		
Floor Number	4th Floor		Room 464 was the end of the return.		
Room Number	463				
Location in Room					
Demo Needed? Y/N	Y				
Drawing #					
Picture of Dead Leg (or area of termination)					
					
Date of Inspection: 07/01/2014					

Dead Leg Criteria Checklist

	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture	
Dead Leg #	17-4-481-001				
Dead Leg Type		X			
Termination	Capped				
Fixture served	-				
Valve Type	Ball				
Pipe Length	3'				
Pipe Size	1-1/2" / 3/4"				
Pipe Function	DCW / DHW				
Pipe Material	Copper				
Length of non insulated pipe	3'				
Building #	17		Comments		
Floor Number	4th Floor		Ball Valve only on Cold.		
Room Number	481				
Location in Room					
Demo Needed? Y/N	Y				
Drawing #					
Picture of Dead Leg (or area of termination)					
					
Date of Inspection: 07/01/2014					

Dead Leg Criteria Checklist

	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture	
Dead Leg #	17-5-578-001				
Dead Leg Type		X			
Termination	Capped				
Fixture served	-				
Valve Type	-				
Pipe Length	10'				
Pipe Size	1/2"				
Pipe Function	DCW				
Pipe Material	Galv.				
Length of non insulated pipe	-				
Building #	17		Comments		
Floor Number	5th Floor		Ball Valve only on Cold.		
Room Number	578				
Location in Room	Back left corner from Entrance				
Demo Needed? Y/N	Y				
Drawing #					
Picture of Dead Leg (or area of termination)					
					
Date of Inspection: 07/01/2014					

Dead Leg Criteria Checklist											
	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture							
Dead Leg #	17-ATTIC-001-001										
Dead Leg Type		X									
Termination	Gate										
Fixture served	-										
Valve Type	Ball										
Pipe Length	66'-6"										
Pipe Size	3/4"										
Pipe Function	DCW										
Pipe Material	Copper										
Length of non insulated pipe	-										
Building #	17		Comments								
Floor Number	ATTIC		End of line in elevator room.								
Room Number	1										
Location in Room	Left of Entrance Round Corner										
Demo Needed? Y/N	N										
Drawing #											
Picture of Dead Leg (or area of termination)											
Date of Inspection: 07/02/2014											