




Dead Leg Criteria Checklist

	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture	
Dead Leg #	22-B-001-001				
Dead Leg Type		x			
Termination	Cap				
Fixture served	None				
Valve Type	None				
Pipe Length	7.5'				
Pipe Size	3/4"				
Pipe Function	DHWR				
Pipe Material	GALV.				
Length of non insulated pipe	1'				
Building #	22		Comments		
Floor Number	Basement				
Room Number	1				
Location in Room	Center				
Demo Needed? Y/N	N				
Drawing #					
Picture of Dead Leg (or area of termination)					
					
Date of Inspection: 06/05/2014					


Dead Leg Criteria Checklist

	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture	
Dead Leg #	22-B-001-002				
Dead Leg Type		x			
Termination	Cap				
Fixture served	None				
Valve Type	None				
Pipe Length	8'				
Pipe Size	3/4"				
Pipe Function	DHWR				
Pipe Material	GALV.				
Length of non insulated pipe	1'				
Building #	22		Comments		
Floor Number	Basement				
Room Number	1				
Location in Room	Center				
Demo Needed? Y/N	N				
Drawing #					
Picture of Dead Leg (or area of termination)					
					
Date of Inspection: 06/05/2014					

Dead Leg Criteria Checklist


	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture	
Dead Leg #	22-B-001-003				
Dead Leg Type		x			
Termination	Cap				
Fixture served	None				
Valve Type	Gate				
Pipe Length	4'				
Pipe Size	1"				
Pipe Function	DCW/ DHW/ DHWR				
Pipe Material	GALV.				
Length of non insulated pipe	None				
Building #	22		Comments		
Floor Number	Basement				
Room Number	1				
Location in Room	Center				
Demo Needed? Y/N	N				
Drawing #					
Picture of Dead Leg (or area of termination)					
					
Date of Inspection: 06/05/2014					

Dead Leg Criteria Checklist

	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture	
Dead Leg #	22-1-104-001				
Dead Leg Type		x			
Termination	Capped				
Fixture served	-				
Valve Type	-				
Pipe Length	30'				
Pipe Size	3/4" / 3/4" / 1/2"				
Pipe Function	DCW / DHW / DHWR				
Pipe Material	Copper				
Length of non insulated pipe	-				
Building #	22		Comments		
Floor Number	1				
Room Number	104				
Location in Room	Chase				
Demo Needed? Y/N	Y				
Drawing #					
Picture of Dead Leg (or area of termination)					
					
Date of Inspection: 06/09/2014					

Dead Leg Criteria Checklist					
	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture	
Dead Leg #	22-2-217-001				
Dead Leg Type				x	
Termination	sink				
Fixture served	sink				
Valve Type	Ball				
Pipe Length					
Pipe Size	1/2" / 1/2"				
Pipe Function	DCW / DHW				
Pipe Material	Copper				
Length of non insulated pipe	-				
Building #	22		Comments		
Floor Number	2				
Room Number	217				
Location in Room	Wall				
Demo Needed? Y/N	Y				
Drawing #					
Picture of Dead Leg (or area of termination)					
Date of Inspection: 06/09/2014					

Dead Leg Criteria Checklist

	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture	
Dead Leg #	22-3-326-001				
Dead Leg Type			X		
Termination	-				
Fixture served	Lavatory				
Valve Type					
Pipe Length	56'				
Pipe Size	1/2" / 1/2"				
Pipe Function	DHW / DCW				
Pipe Material	Copper				
Length of non insulated pipe	-				
Building #	22		Comments		
Floor Number	3		Fixture Used Infrequently per Librarian.		
Room Number	320				
Location in Room	Wall				
Demo Needed? Y/N	N				
Drawing #					
Picture of Dead Leg (or area of termination)					
					
Date of Inspection: 06/09/2014					

Dead Leg Criteria Checklist

	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture	
Dead Leg #	22-3-318-001				
Dead Leg Type				x	
Termination	-				
Fixture served	sink				
Valve Type	Ball				
Pipe Length					
Pipe Size	1/2" / 1/2"				
Pipe Function	DCW / DHW				
Pipe Material	Copper				
Length of non insulated pipe	-				
Building #	22		Comments		
Floor Number	3				
Room Number	318				
Location in Room	Wall				
Demo Needed? Y/N	Y				
Drawing #					
Picture of Dead Leg (or area of termination)					
Date of Inspection: 06/09/2014					