






Dead Leg Criteria Checklist					
	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture	
Dead Leg #	23-B-001-001				
Dead Leg Type		X			
Termination	Cap				
Fixture served	-				
Valve Type	-				
Pipe Length	5'				
Pipe Size	3/4"				
Pipe Function	DCW				
Pipe Material	Copper				
Length of non insulated pipe	-				
Building #	23		Comments		
Floor Number	Basement				
Room Number	1				
Location in Room					
Demo Needed? Y/N	N				
Drawing #					
Picture of Dead Leg (or area of termination)					
					
Date of Inspection: 06/10/2014					

Dead Leg Criteria Checklist					
	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture	
Dead Leg #	23-B-001-002				
Dead Leg Type		X			
Termination	Cap				
Fixture served	-				
Valve Type	-				
Pipe Length	5'				
Pipe Size	3/4"				
Pipe Function	DCW				
Pipe Material	Copper				
Length of non insulated pipe	-				
Building #	23		Comments		
Floor Number	Basement				
Room Number	1				
Location in Room					
Demo Needed? Y/N	N				
Drawing #					
Picture of Dead Leg (or area of termination)					
					
Date of Inspection: 06/10/2014					

Dead Leg Criteria Checklist					
	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture	
Dead Leg #	23-B-001-003				
Dead Leg Type		X			
Termination	Cap				
Fixture served	-				
Valve Type	-				
Pipe Length	15'				
Pipe Size	3/4"				
Pipe Function	DCW				
Pipe Material	Copper				
Length of non insulated pipe	-				
Building #	23		Comments		
Floor Number	Basement				
Room Number	1				
Location in Room					
Demo Needed? Y/N	N				
Drawing #					
Picture of Dead Leg (or area of termination)					
					
Date of Inspection: 06/10/2014					

Dead Leg Criteria Checklist					
	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture	
Dead Leg #	23-1-111-001				
Dead Leg Type		X			
Termination	Cap				
Fixture served	Hand Sink				
Valve Type	-				
Pipe Length	8' / 8'				
Pipe Size	1/2" / 1/2"				
Pipe Function	DCW / DHW				
Pipe Material	Copper				
Length of non insulated pipe	8'				
Building #	23		Comments		
Floor Number	First				
Room Number	111				
Location in Room	Wall				
Demo Needed? Y/N	Y				
Drawing #					
Picture of Dead Leg (or area of termination)					
					
Date of Inspection: 06/11/2014					

	Dead Leg Criteria Checklist						
	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture			
Dead Leg #	23-1-113B-001						
Dead Leg Type				X			
Termination	sink						
Fixture served	mop sink						
Valve Type	ball						
Pipe Length	20'						
Pipe Size	1/2"						
Pipe Function	DCW, DHW						
Pipe Material	copper						
Length of non insulated pipe							
Building #	23		Comments				
Floor Number	1						
Room Number	113B						
Location in Room							
Room	right of entrance						
Demo Needed? Y/N	Y						
Drawing #							
Picture of Dead Leg (or area of termination)							
Date of Inspection							19-Aug

Dead Leg Criteria Checklist					
	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture	
Dead Leg #	23-1-122-001				
Dead Leg Type		X			
Termination	Cap				
Fixture served	-				
Valve Type	-				
Pipe Length	5' / 5'				
Pipe Size	3/4" / 1/2"				
Pipe Function	DCW / DHW				
Pipe Material	Galv.				
Length of non insulated pipe					
Building #	23		Comments		
Floor Number	First		Behind the desk.		
Room Number	123				
Location in Room	Left of Door				
Demo Needed? Y/N	Y				
Drawing #					
Picture of Dead Leg (or area of termination)					
					
Date of Inspection: 06/11/2014					

