

CROSS CONNECTION CONTROL PLAN NOTES:

- 1. INSTALL DOUBLE CHECK VALVE ASSEMBLY, SEE TABLE 1.
- 2. INSTALL SINGLE REDUCED PRESSURE ZONE ASSEMBLY, SEE TABLE 1.
- 3. INSTALL DUPLEX REDUCED PRESSURE ZONE ASSEMBLY, SEE TABLE 1.
- 4. INSTALL SUMP PIT AND PUMP SYSTEM, SEE DETAIL CU-002.
- 5. INSTALL SUMP DISCHARGE PIPING AND CONCRETE DISCHARGE PAD, SEE DETAILS CU-002, CU-002.
- 6. PROVIDE SHRUB SCREEN AROUND OUTDOOR PROTECTIVE ENCLOSURE. COORDINATE SPECIES AND SIZE WITH COR.
- 7. CONNECTION LOCATION IS ASBESTOS CONTAMINATED CONFINED SPACE. PROPER PPE SHALL BE REQUIRED FOR ALL WORK IN THE SPACE.
- 8. CONSTRUCT OUTDOOR PROTECTIVE ENCLOSURE AND CONCRETE EQUIPMENT PAD, SEE DETAIL CU-002.
- 9. RECONFIGURE EXISTING CRAWLSPACE WATER SERVICE PIPING, SEE DETAIL CU-002.


GENERAL NOTES:

- 1. DOMESTIC WATER SERVICE LINES SHOWN ARE ONLY INTENDED TO INDICATE THE GENERAL LOCATION OF THE WATER SERVICE ENTRANCE IN RELATION TO THE BUILDING. ACTUAL WATER LINE LOCATIONS MUST BE FIELD VERIFIED BY THE CONTRACTOR.
- 2. PLUMBING CONTRACTOR SHALL PRODUCE COORDINATION DRAWINGS FOR ALL PLUMBING DEMOLITION AND NEW PLUMBING TO BE PERFORMED AND SUBMIT FOR APPROVAL PRIOR TO BEGINNING WORK.
- 3. COORDINATE LOCATIONS OF ALL OUTDOOR PROTECTIVE ENCLOSURES, SUMP PITS, AND SUMP DISCHARGE PADS WITH COR.

CONSULTANTS:

ARCHITECT/ENGINEERS:

**TOLMAN ENGINEERING, PLLC**  
3610 LAWSON ROAD  
JAMESTOWN, NEW YORK 14701  
PHONE: (716) 484 - 1366  
FAX: (716) 484 - 1519



Drawing Title		Project Title		Date	
CROSS CONNECTION CONTROL - ENLARGED SITE PLAN		INSTALL CROSS CONNECTION CONTROLS		01/12/2015	
Approved Eng. Project Supervisor	Date	Building No.	Checked	Drawn	
Approved Medical Center Director	Date	N/A	BFP	EHA/JLE	
Location		BATH, NEW YORK		Dwg	9 of 10

CU-103

Office of Construction and Facilities Management  
Department of Veterans Affairs

