

PROPOSAL REQUEST FOR INFORMATION (RFI) FORM

SOLICITATION: VA261-15-B-0435-EXPAND BUILDING 700 HVAC

NOTE: ALL PRE-PROPOSAL INQUIRIES SHALL BE SUBMITTED VIA EMAIL TO karen.smith3@va.gov BY AN EDITABLE USE OF THIS FORM. Please identify, in numerical sequence, each set of inquiries that you send.

Question(s) is/are on the solicitation [☐]

Question(s) is/are on the drawings, specifications, technical data [☒]

Company Name and Bidder: Patriot Construction

From (person submitting question):

Jake Wight

Date of Proposal Inquiry: 9-1-15

Phone Number: 209-982-9900

Proposal Inquiry: (Type inquiry below)

Proposal RFI #1 – The specified mechanical equipment has long lead times from the manufacturer. In order to meet the scheduled work window as specified on the drawings it will be necessary to expedite shipping. This is a substantial extra cost. Should this cost be included in the bid?
No- VA will remove the 9 days shutdown restrictions to allow sufficient time for long lead items. VA will provide 9 calendar days shutdown for AHU installation.

Proposal RFI #2 –