

## PROPOSAL REQUEST FOR INFORMATION (RFI) FORM

SOLICITATION: VA261-15-B-0480- Elevator Repair and Replacement Bldg. 200 and & 7

**NOTE:** ALL PRE-PROPOSAL INQUIRIES SHALL BE SUBMITTED VIA EMAIL TO [karen.smith3@va.gov](mailto:karen.smith3@va.gov) BY AN EDITABLE USE OF THIS FORM. Please identify, in numerical sequence, each set of inquiries that you send.

Question(s) is/are on the solicitation [  ]

Question(s) is/are on the drawings, specifications, technical data [  ]

Company Name and Offeror: \_\_\_Anthem  
Builders\_\_\_\_\_

From (person submitting question):

\_\_\_Steve\_\_\_\_\_

Date of Proposal Inquiry: \_\_\_\_\_09/09/2015\_\_\_\_\_

Phone Number: \_\_\_916-224-8716\_\_\_\_\_

Proposal Inquiry: (Type inquiry below)

Proposal RFI #1 – plan sheet 700-EP-106 references to make a connection from existing MCC QMC61A, but there is no location for QMC61A, please provide where QMC61A is located

-

Add additional as necessary

---

Location of 'QMCC61A' is located in Roof Penthouse at northwest corner of Building 700.

MCC 'QMCC61A' incorrectly labeled as 'QMCC51A' on Plan 1, Sheet 700-EP-106.

Answered by Mark Valenzuela of AEI on 09/09/15