PROPOSAL REQUEST FOR INFORMATION (RFI) FORM

SOLICITATION: VA261-15-B-0958- Elevator Repair and Replacement Bldg. 200 and & 7

NOTE: ALL PRE-PROPOSAL INQUIRIES SHALL BE SUBMITTED VIA EMAIL TO karen.smith3@va.gov BY AN EDITABLE USE OF THIS FORM. Please identify, in numerical sequence, each set of inquiries that you send.

Question(s) is/are on the solicitation [ ]
Question(s) is/are on the drawings, specifications, technical data [ ]

Company Name and Offeror: ___Anthem Builders
_____

From (person submitting question):
Steve_____

Date of Proposal Inquiry: _____09-10-2015_____

Phone Number: ____916-224-8716_____

Proposal Inquiry: (Type inquiry below)

Proposal RFI #1 – Please reference sheet ES001, where is existing panel RA located in the building?

-

Add additional as necessary

VA Response:
Panel RA is located in building 200 penthouse, plan south of MCC-E