

PROPOSAL REQUEST FOR INFORMATION (RFI) FORM

SOLICITATION: VA261-15-B-0958- Elevator Repair and Replacement Bldg. 200 and & 7

NOTE: ALL PRE-PROPOSAL INQUIRIES SHALL BE SUBMITTED VIA EMAIL TO karen.smith3@va.gov BY AN EDITABLE USE OF THIS FORM. Please identify, in numerical sequence, each set of inquiries that you send.

Question(s) is/are on the solicitation []

Question(s) is/are on the drawings, specifications, technical data []

Company Name and Offeror: _Industrial Maintenance Services, Inc.

From (person submitting question): Dale LaMarche

Date of Proposal Inquiry: 9-16-2015

Phone Number: 906-789-9021

Proposal Inquiry: (Type inquiry below)

Proposal RFI #1 – There are some spec sections included in bld. 200 and bld. 7 spec that do not appear to apply to the project such as 07 13 52 and 07 16 16.

Is there any work required on existing elevator pit or shaft in relation to these spec sections that would apply to this project?

Answer: Keep this Spec. section "[07 16 16 – Crystalline waterproofing](#)", this will cover what's actually preformed on the elevator projects.

Deleted "[07 13 52 – Modified Bituminous Sheet waterproofing](#)" not needed.

Add additional as necessary