Drawing: H:\PROJECTS\2015\2015007\2015007_MMOD_MECH.DWG
March 27, 2015 11:03:16 am
Xrefs: HVA-MAIN.DWG, MAS-BASE.DWG, MAS-BKGD.DWG, MAS-BORD.DWG,

THE USE OF THESE PLANS AND SPECIFICATIONS SHALL BE RESTRICTED TO THE ORIGINAL SITE FOR WHICH THEY WERE PREPARED AND PUBLICATION THEREOF IS EXPRESSLY LIMITED TO SUCH USE. RE-USE, REPRODUCTION, OR PUBLICATION BY ANY METHOD, IN WHOLE OR IN PART, IS PROHIBITED. TITLE TO THE PLANS AND SPECIFICATIONS REMAINS WITH THE ENGINEER WITHOUT PREJUDICE. VISUAL CONTACT WITH THESE PLANS AND SPECIFICATIONS SHALL CONSTITUTE PRIMA FACIE EVIDENCE OF THE ACCEPTANCE OF THESE RESTRICTIONS. AXIOM ENGINEERS INC.- LEE & ASSOCIATES CONSULTING ENGINEERS

one inch = one foot
three quarters inch = one foot
one half inch = one foot
three eighths inch = one foot
one quarter inch = one foot
one eighth inch = one foot
three inches = one foot
one and one half inches = one foot



GENERAL DEMOLITION NOTES

1. CONTRACTOR IS RESPONSIBLE FOR DISCONNECTING AND RECONNECTING ALL DUCTWORK.
2. CAP (E) CONTROL ROOM DUCTWORK ABOVE THE CEILING, DO NOT INTERRUPT OPERATION OF ADJACENT SPACE.
3. ANY PIPING AND/OR DUCTWORK THAT WILL INTERFERE WITH NEW CEILING COMPONENTS MUST BE DROPPED AND RE-HUNG. SEE ARCHITECTURAL DRAWING A4.1 FOR NEW CEILING COMPONENTS.
4. DEMOLITION OF NEW WORK IN PHASE I SHALL NOT INTERFERE WITH THE PHASE II OCCUPANTS.
5. PROVIDE TEMPORARY EXHAUST DUCT CONNECTION TO ROOM C158 TO MAINTAIN ROOM EXHAUST AIRFLOW AND PRESSURE RELATIONSHIP

1 / M2.1

PHASE 1 PARTIAL GROUND FLOOR - MECHANICAL DEMOLITION

SCALE: 1/4" = 1'-0"



GENERAL NOTES

1. EXTEND (E) REFRIGERANT PIPING TO NEW INDOOR UNIT LOCATION, TYP. OF 2. REFRIGERANT PIPING SHALL BE BRAZED. PROVIDE ALL REQUIRED PURGING, CHARGING, TESTING AND RESTART OF EQUIPMENT.
2. VERIFY NEW DUCTWORK AND PROPOSED EQUIPMENT LOCATIONS DO NOT INTERFERE WITH SKY CEILING OR BODY LIFTING MECHANISM. SEE ARCHITECT'S DRAWING A4.1 FOR EXACT LOCATION.
3. CONTRACTOR SHALL VERIFY THAT PROPOSED ACCESS PANEL LOCATION MEETS MANUFACTURER'S LITERATURE FOR SERVICE ACCESS TO CEILING CASSETTE COOLING UNIT (TYP. OF 2).
4. CONTRACTOR SHALL VERIFY NEW LEAD SHIELDING REQUIREMENTS. SEE ARCHITECTURAL DRAWING A4.3 FOR LOCATION OF NEW LEAD SHIELDING.

2 / M2.1

PHASE 1 GROUND FLOOR NEW ROOMS C156 & C157- MECHANICAL NEW

SCALE: 1/4" = 1'-0"

100% CONSTRUCTION DOCUMENTS

Revisions:	Date

CONSULTANTS:

vc. (831) 649-8000
fx. (855) 649-8038
email: mail@axiomengineers.com
AXIOM ENGINEERS SM
LEE & ASSOCIATES
CONSULTING ENGINEERS
AE Project # : 20150017
22 Lower Ragsdale Dr., Suite A
Monterey, California 93940-5788

RICHARD M. LEE REGISTERED PROFESSIONAL ENGINEER No. M24908 EXP. SEPT 30, 2015 MECHANICAL STATE OF CALIFORNIA

ARCHITECT/ENGINEERS: HFP JOB #01-13

hfp architects
209 w. alamar ave
santa barbara, ca 93105
805-969-6887 fax: 805 969-6888

Drawing Title: PHASE 1 PARTIAL GROUND FLOOR PLANS - DEMO AND NEW MECHANICAL

Approved: Project Director

Project Title: CT SCANNER PREP VA NORTHERN CALIFORNIA HEALTHCARE SYSTEM

Location: MARTINEZ, CA

Date: 06/26/2015 | Checked: WME | Drawn: CADD

Project Number: 612-14-037

Building Number: 19

Drawing Number: M2.1

Dwg. 20 of 44

Office of Construction and Facilities Management

Department of Veterans Affairs

VA FORM 08-6231