


- GENERAL NOTE:  
A.-UNIT SHALL BE KNOCK DOWN CONSTRUCTION.  
B.- PROVIDE NECESSARY LIGHTING, SWITCHES AND CONVENIENCE OUTLET AS INDICATED IN SPECIFICATION 237300.
- NOTES:  
1.- 2" MERV 8 FILTER.  
2.- RELIEF AIR DAMPER.  
3.- HEAT EXCHANGER.  
4.- RETURN AIR OPENING (52"X20").  
5.- 2" DOUBLE WALL CASING.  
6.- SUPPLY FAN (TYPICAL OF TWO).  
7.- RELIEF FAN (TYPICAL OF TWO).  
8.- STEAM COIL (HEATING).  
9.- CHILLED WATER COIL.  
10.- HUMIDIFIER.  
11.- INTEGRAL FACE AND BYPASS STEAM COIL (PRE-HEAT).  
12.- ACCESS DOOR.  
13.- 1-1/4" DRAINS.  
14.- 2" MERV 8 FILTER.  
15.- VFD, SHOWN FOR REFERENCE. VFD'S SHIPPED LOOSE AND WILL NEED TO ENSURE PROPER NEC CLEARANCES PRIOR TO FINAL MOUNTING LOCATION.  
16.- 6" MERV 14 FILTER.

SCALE: NONE



COPYRIGHT  
DYNAMIX ENGINEERING LTD.  
ALL RIGHTS RESERVED

**Dynamix**  
Engineering Ltd.  
Facility Engineering Consultants  
855 Grandview Avenue, 3rd Floor Columbus, Ohio 43215  
Phone: (614)443-1178 Fax: (614)443-1594  
Email: dynamix@dynamix-ltd.com

REPLACE OUTDATED EQUIPMENT  
DEPARTMENT OF VETERNANS AFFAIRS  
CHILlicothe, OHIO

DATE: 12-09-15  
PROJECT NO.: 130121  
DWN BY: DEL

SHEET TITLE  
AIR HANDLER  
DETAILS  
BUILDING 31

SHEET NUMBER

R1-H0-04-2

DEL Revision #1  
ADDENDUM Date: 12-09-15