


Dead Leg Criteria Checklist					
	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used	Pipe length greater than 25 feet terminating at a frequently used	
Dead Leg #	102-1-100-001				
Dead Leg Type		X			
Termination	Capped				
Fixture served	-				
Valve Type	Gate				
Pipe Length	5'				
Pipe Size	3/4"				
Pipe Function	DHW				
Pipe Material	Copper				
Length of non insulated pipe	All				
Building #	102		Comments		
Floor Number	FIRST FLOOR				
Room Number	100				
Location in Room	Receptionist office				
Demo Needed? Y/N	Y				
Drawing #					
Picture of Dead Leg (or area of termination)					
					
Date of Inspection: 07/10/2014					


Dead Leg Criteria Checklist									
	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture					
Dead Leg #	102-1-115-001								
Dead Leg Type			X						
Termination	sink								
Fixture served	hand sink								
Valve Type	ball								
Pipe Length	25'								
Pipe Size	1/2"								
Pipe Function	DCW, DHW								
Pipe Material	copper								
Length of non insulated pipe									
Building #	102		Comments						
Floor Number	1								
Room Number	115								
Location in Room	west wall								
Demo Needed? Y/N	Y								
Drawing #									
Picture of Dead Leg (or area of termination)									
Date of Inspection	19-Aug								

Dead Leg Criteria Checklist									
	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture					
Dead Leg #	102-1-117-001								
Dead Leg Type			X						
Termination	sink								
Fixture served	hand sink								
Valve Type	ball								
Pipe Length	8'								
Pipe Size	1/2"								
Pipe Function	DCW, DHW								
Pipe Material	copper								
Length of non insulated pipe									
Building #	102		Comments						
Floor Number	1								
Room Number	117								
Location in Room	right of entrance								
Demo Needed? Y/N	Y								
Drawing #									
Picture of Dead Leg (or area of termination)									
Date of Inspection	19-Aug								

Dead Leg Criteria Checklist									
	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture					
Dead Leg #	102-1-110B-001								
Dead Leg Type			X						
Termination	sink								
Fixture served	hand sink								
Valve Type	ball								
Pipe Length	16'								
Pipe Size	1/2"								
Pipe Function	DCW, DHW								
Pipe Material	copper								
Length of non insulated pipe									
Building #	102		Comments						
Floor Number	1								
Room Number	110B								
Location in Room	left of entrance								
Demo Needed? Y/N	Y								
Drawing #									
Picture of Dead Leg (or area of termination)									
Date of Inspection	19-Aug								

Dead Leg Criteria Checklist									
	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used plumbing fixture	Pipe length greater than 25 feet terminating at a frequently used plumbing fixture					
Dead Leg #	102-1-111-001								
Dead Leg Type			X						
Termination	sink								
Fixture served	hand sink								
Valve Type	ball								
Pipe Length	15'								
Pipe Size	1/2"								
Pipe Function	DCW, DHW								
Pipe Material	copper								
Length of non insulated pipe									
Building #	102		Comments						
Floor Number	1								
Room Number	111								
Location in Room	left of entrance								
Demo Needed? Y/N	Y								
Drawing #									
Picture of Dead Leg (or area of termination)									
						Date of Inspection	19-Aug		

Dead Leg Criteria Checklist

	Description	Pipe Length greater than three feet terminating at a cap, valve, or fitting	Pipe length greater than three feet terminating at an infrequently used	Pipe length greater than 25 feet terminating at a frequently used	
Dead Leg #	102-1-G006-001				
Dead Leg Type		X			
Termination	Capped				
Fixture served	-				
Valve Type	-				
Pipe Length	6'				
Pipe Size	3/4" / 3/4"				
Pipe Function	DCW / DHW				
Pipe Material	BLACK PIPE				
Length of non insulated pipe	All				
Building #	102		Comments		
Floor Number	FIRST FLOOR		Possibly cut in basement, also unable to verify other end.		
Room Number	G006				
Location in Room	Right of Entrance				
Demo Needed? Y/N	Y				
Drawing #					
Picture of Dead Leg (or area of termination)					
					
Date of Inspection: 07/10/2014					