

SOLICITATION NO. VA258-16-Q-0154,

PROJECT NO. 504-16-501 ABATE ASBESTOS BLDG 1, 2ND FLOOR

REQUEST FOR INFORMATION

Q1. In regards to the POP of 7 days from NTP. Please note that the State of Texas requires a min 10 day notification period before the project can begin. Once notice to proceed is given to the winning contractor, and appropriate information is gathered the notification process can begin.

A1. The Government is acknowledges the State of Texas minimum 10 day notification before the project can commence. After the project is awarded, the Notice to Proceed Date and Construction Start Date will be discussed during the Pre-Construction Conference. Once the dates are settled the NTP will be issued and will account for the time needed for the contractor to notify the state of Texas.

Q2. If terrazzo is found under the carpet who is responsible for the removal of the non ACM carpet mastic that is remaining on the terrazzo?

A2. The removal of terrazzo shall be completed by the demolition crew for this project where needed in order to remove all asbestos from the floor as well as to create a smooth surface throughout. Terrazzo is confirmed at the Cove Base and is assumed only at the Cove Base.