

- NEW WORK NOTES**
1. 5/8" X 1 5/8" - 14 GA ELECTRO-GALVANIZED UNISTRUT CHANNELS @ 1'-6" O.C.
  2. 3 5/8" METAL FRAMING AT 16" O.C. WITH ONE LAYER 5/8" FIRE RATED GWB EACH SIDE.
  3. 4'-0" X 4'-0" HOLLOW METAL WINDOW FRAME WITH THE SAME ATTENUATION AS 1/16" LEAD EQUIVALENT W/ 1/16" LEAD EQUIVALENT AT 130 KEV LEAD GLASS.
  4. LEAD SHIELD ON 5/8" GWB IN WALL.
  5. NEW 24"x24" ACOUSTICAL CEILING TILE SYSTEM.
  6. PATCH WALL WITH 5/8" GWB.
  7. LEAD SHIELD ON FLOOR SLAB.
  8. 1/16" LEAD SHIELD ON 5/8" GWB ATTACHED TO UNISTRUT SYSTEM.
  9. INSTALL PATIENT LIFT AND CEILING MOUNTED RAILS FROM ROOM 3A-125 CEILING IN ROOM 3A-127.
  10. NEW FLOORING - SEE FINISH SCHEDULE.
  11. 3 5/8" METAL FRAMING @ 16" O.C. WITH ONE LAYER OF 5/8" FIRE RATED GWB ON 3A-121 SIDE ONLY. SHIELDING GWB INSTALLED ON 3A-123 SIDE DURING PHASE 3.
  12. UNSEAL DOOR AFTER CONSTRUCTION COMPLETED.
  13. REMOVE CEILING GRID TO ADJUST FOR MECHANICAL NEW WORK.
  14. NEW HANDRAILS MEETING CURRENT PHILADELPHIA VAMC INTERIOR REQUIREMENTS SHALL BE MOUNTED TO MATCH CURRENT HANDRAIL LOCATIONS AND HEIGHTS.
  15. NEW 14'-6" X 2'-1" SOLID SURFACE COUNTERTOP WITH SOLID SURFACE BASE.

**LEGEND**

AREA OF DEMOLITION  
OR  
AREA OF NEW WORK

NEW WALL

EXISTING WALL TO REMAIN

DEMO WALL OR ITEMS ABOVE OR BELOW

WALL SHIELDING @ ROOM 3A 125

EXISTING DOOR

DEMO DOOR

NEW DOOR

ROOM NUMBER  
DOOR TAG

REVISION TAG


SECTION OR WALL  
SECTION NUMBER

**ABBREVIATIONS**





ACT	ACOUSTICAL TILE CEILING	PNT	PAINT
ACT-S	ACOUSTICAL TILE CEILING	PTD	PAINTED
A.F.F.	WI SMOOTH WASHABLE SURFACE	SB	SIMILAR
CLG	CEILING	SV	RUBBER BASE
CT	CERAMIC TILE	TME	SHEET VINYL
CORR	CORRIDOR	VCT	TO MATCH EXISTING VINYL COMPOSITION TILE
ETR	EXITING TO REMAIN	VERT	VERTICAL
EXST	EXISTING	WSEF	WELDED SEAM SHEET FLOORING
GWB	GYPSUM WALLBOARD	WSF	FLOORING (HEAT WELDED WITH ROD)
MTL	METAL		AT
NIC	NOT IN CONTRACT		
PLAM	PLASTIC LAMINATE		

- GENERAL NOTES**
1. CONTRACTOR SHALL FIELD VERIFY ALL DIMENSIONS AND CONDITIONS PRIOR TO THE START OF CONSTRUCTION. ANY DISCREPANCIES SHALL BE BROUGHT TO THE IMMEDIATE ATTENTION OF THE ARCHITECT FOR A RESOLUTION. ADJUSTMENTS TO DIMENSIONS AND CONDITIONS SHOWN MAY BE REQUIRED.
  2. ALL DIMENSIONS ARE REFERENCED FROM FACE OF FINISH AT NEW CONSTRUCTION UNLESS OTHERWISE NOTED.
  3. ALL DIMENSIONS INDICATED +/- ARE APPROXIMATE AND MUST BE FIELD VERIFIED PRIOR TO THE START OF CONSTRUCTION.
  4. PROVIDE ALL MEANS TO SUPPLY, TO FURNISH AND TO INSTALL COMPLETE WITH ALL ACCESSORIES, PARTS AND/OR SERVICES TO BE READY FOR ITS INTENDED USE.
  5. WHERE WORK ABUTS OR ADJOINS EXISTING SURFACES WHICH WILL REMAIN EXPOSED, ALIGN NEW WORK FLUSH WITH EXISTING ADJACENT SURFACES.
  6. THE CONTRACTOR SHALL MAINTAIN THE EXISTING BUILDING IN A WATER TIGHT CONDITION THROUGHOUT THE ENTIRE CONSTRUCTION PERIOD. REPAIR DAMAGE CAUSED BY CONSTRUCTION OPERATIONS. TAKE ALL PRECAUTIONS NECESSARY TO PROTECT THE BUILDING AND ITS OCCUPANTS DURING THE CONSTRUCTION PERIOD.
  7. CONTRACTOR SHALL PROVIDE BARRIERS TO PREVENT ENTRY TO THE CONSTRUCTION AREA. BARRIERS SHALL NOT INTERFERE WITH THE OWNERS USE OF THE SITE.
  8. THE CONTRACTOR SHALL PROVIDE NEGATIVE PRESSURE IN THE AREA OF RENOVATION TO PREVENT THE SPREAD OF DUST TO OCCUPIED AREAS OF THE BUILDING.
  9. ALL NOTES, REMARKS AND/OR SCHEDULES ON THIS SHEET ARE FOR THIS ONLY UNLESS OTHERWISE NOTED.
  10. CONTRACTOR SHALL PATCH EXISTING SURFACES TO MATCH EXISTING WHERE NEW MECHANICAL OR ELECTRICAL WORK DISTURBS EXISTING FINISHES.
  11. CONTRACTOR TO KEEP DOOR 122-2 FROM 3A 101C TO CA 122 CLOSED AT ALL TIMES DURING CONSTRUCTION AND EQUIPMENT INSTALLATION PROCESS EXCEPT AS REQUIRED TO INSTALL NEW WORK SEAL DOOR TO FRAME.
  12. CONTRACTOR TO COORDINATE WITH OWNER FOR ACCESS, DELIVERY AND REMOVAL OF MATERIALS.
  13. CONTRACTOR SHALL PROVIDE ALL MEANS NECESSARY TO PREVENT THE SPREAD OF DUST TO EXISTING SPACES AND PROVIDE TACKY MATS AS REQUIRED.
  14. CONTRACTOR TO KEEP DOOR 101B - 1 FROM 3A 101B TO 3A 101B CLOSED AT ALL TIMES DURING CONSTRUCTION AND EQUIPMENT INSTALLATION PROCESS EXCEPT AS REQUIRED TO INSTALL NEW WORK SEAL DOOR TO FRAME.

**3RD FLOOR NEW WORK PLAN**  
**1/4" = 1'-0"**



**CONSTRUCTION BID DOCUMENTS - BIDDER QUESTION RESPONSES FULLY SPRINKLERED**

<b>CONSULTANTS:</b>			<b>ARCHITECT/ENGINEERS:</b>			<b>SKETCH Title</b> <b>THIRD FLOOR NEW WORK PLAN - COMPLETE</b>		<b>Project Title</b> <b>NEW SPECT-CT INSTALLATION</b>		<b>Project Number</b> <b>642-13-120</b>		<b>Office of Construction and Facilities Management</b>	
 PF&A DESIGN ARCHITECTURE, PLANNING, INTERIORS World Trade Center 101 West Main Street, Suite 7000 Norfolk, VA 23510 Phone: 757-471-4637 Fax: 757-471-4205 www.pfa-architect.com • Project No: 2194.144			 Miller-Remick LLC M.E.P. & Structural Engineering A Service Disabled Veteran Owned Small Business 1010 KINGS HIGHWAY SOUTH CHERRY HILL, NEW JERSEY 08034 PHONE: (856)420-4000 FAX: (856)420-5002 M-R PROJECT NO: 0489-0030			Approved: Project Director		Location V.A.M.C. PHILADELPHIA, PA		Building Number 2		Department of Veterans Affairs	
NO. DESCRIPTION DATE						Sketch Number <b>SK-A2</b>		Date 02-02-2016		Checked <b>JSG</b>		BID DWG Revised <b>A-101</b>	
						Drawn <b>KOR</b>							