

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT			BPA NO.	1. CONTRACT ID CODE	PAGE 1	OF PAGES 2
2. AMENDMENT/MODIFICATION NO. A00002		3. EFFECTIVE DATE 02/09/2016	4. REQUISITION/PURCHASE REQ. NO. 675-16-2-6637-0094		5. PROJECT NO.(If applicable) None	
6. ISSUED BY Department of Veterans Affairs Orlando VA Medical Center 13800 Veteran's Way Orlando FL 32827		CODE	7. ADMINISTERED BY (If other than Item 6) Department of Veterans Affairs Network Contracting Activity 8 (NCO 8) Orlando VA Medical Center 13800 Veteran's Way Orlando FL 32827		CODE	00675
8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code) To all Offerors/Bidders			(X)	9A. AMENDMENT OF SOLICITATION NO. VA248-16-Q-0514		
			X	9B. DATED (SEE ITEM 11)		
				10A. MODIFICATION OF CONTRACT/ORDER NO.		
				10B. DATED (SEE ITEM 13)		
CODE			FACILITY CODE			
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS						
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers <input type="checkbox"/> is extended, <input checked="" type="checkbox"/> is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing Items 8 and 15, and returning <u>1</u> copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.						
12. ACCOUNTING AND APPROPRIATION DATA (If required)						
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.						
CHECK ONE	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.					
	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).					
	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:					
	D. OTHER (Specify type of modification and authority)					
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.						
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) The purpose of this amendment is to: Post the questions and answers from the site visit						
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.						
15A. NAME AND TITLE OF SIGNER (Type or print)			16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print) Joseph Boudreau NCO815L2-7078			
15B. CONTRACTOR/OFFEROR (Signature of person authorized to sign)		15C. DATE SIGNED	16B. UNITED STATES OF AMERICA BY (Signature of Contracting Officer)		16C. DATE SIGNED	

CONTINUATION PAGE

- 1) The manhole is in a roadway at entry to facility. Is it acceptable to block that lane during regular daytime work hours in order to complete work?
Yes. The single lane may be blocked in the immediate area of the manhole for not more than 4 hours and not within peak hours. 7:00am to 10:00am
- 2) SOW #7, what type of system will be interfacing with the new monitoring system? Is this interface required to be a Johnson Controls interface?
Yes. The JCI system shall interface with the sewer monitoring equipment.
- 3) Where will the interface be installed?
A JCI box will need to be installed in the sewer monitoring equipment room that connects to the JCI network and interfaces with the JCI Metasys system at the Lake Nona central energy plant. A JCI box in the CEP will need to retrieve the sewer monitoring equipment readings.
- 4) SOW #8 states that sampling data monitoring is to be integrated to the CEP Johnson Controls system. What sampling parameters are to be included?
pH, flow, and temperature
- 5) What type of training (SOW #8) is to be provided to end-users?
How to retrieve sampling parameters from the JCI system and generate reports and graphs.
And how to retrieve water samples from the equipment.
- 6) Sizes of pipes within the manhole (inflow & discharge)?
Wastewater monitor room manhole has a 12" inflow sanitary PVC pipe coming from the hospital. The outflow from this manhole is also 12" PVC sanitary pipe.
- 7) Minimum and maximum flow rates?
No previous or current flow rate readings available. City of Orlando Ordinance Chapter 30 - REGULATION OF SEWER USE AND RATES specifies maximum amount of byproducts/toxins in wastewater.
- 8) Depth of the manhole?
See provided manhole detail. Drawing H-CG5.04
- 9) Temperature of discharge water? (ambient?)
No previous or current temperature readings available.
- 10) Is one sampling port sufficient for use by the owner and city or are two separate ports required?
This will depend on the equipment that will be specified and installed. This will need to be decided by the vendor that provides the equipment. There are three 2 inch PVC pipes that have been run and capped from the manhole to the room

11) Will a refrigerated sampler be required?

The vendor that provides the equipment will need to determine if any of the required sampling parameters from the City of Orlando Ordinance Chapter 30 - REGULATION OF SEWER USE AND RATES requires refrigeration.

12) Is composite sampling acceptable?

Lab samples will be collected by third party and sent to a laboratory. Required sampling parameters from the City of Orlando must be attainable from samples.

13) Will the sampler be permanently installed on site for drawing samples if the discharge goes out of compliance?

Sampler must be permanently installed onsite.

14) Are 4/20mA outputs acceptable for pH, temperature and flow?

This will need to be addressed by the equipment requirements once the equipment is specified.

15) Is there a drawing that shows the piping details within the manhole? See provided manhole detail. Drawing H-CG5.04

16) Is there an existing flume installed? See provided manhole detail. Drawing H-CG5.04

17) If there is an existing flume, is there a detailed drawing that shows accessories such as the sampling port, stilling well, bubble tube or ultrasonic mounting bracket? See provided manhole detail. Drawing H-CG5.04