

PROPOSAL REQUEST FOR INFORMATION (RFI) FORM

SOLICITATION: VA261-16-R-0326

NOTE: ALL PRE-PROPOSAL INQUIRIES SHALL BE SUBMITTED VIA EMAIL TO parvinder.brar@va.gov and/or denise.groves@va.gov BY AN EDITABLE USE OF THIS FORM. Please identify, in numerical sequence, each set of inquiries that you send.

Question(s) is/are on the solicitation []

Question(s) is/are on the drawings, specifications, technical data []

Company Name and Offeror: Patriot construction, Inc.

From (person submitting question):
Kristen McIlrath kristen@patriotbuilds.com

Date of Proposal Inquiry: 2-19-16

Phone Number: 209-982-9900

Proposal Inquiry: (Type inquiry below)

Proposal RFI #1 – In the SOW it states that the new roof is to be Built up Bituminous. The specs include sections for Built up Bituminous and also a section for PVC Roofing. Will the VA please confirm if a PVC overlay roof is acceptable for this project and if so please provide an updated SOW.

Proposal RFI #2 – PVC roofing will be allowed. Under 4.8 DEMO, remove and replace any visually damaged BUR or sub-material up to 1200sf, as approved by the COR.

Proposal RFI #3 -

Add additional as necessary