

PROPOSAL REQUEST FOR INFORMATION (RFI) FORM

SOLICITATION: VA261-16-R-0326

NOTE: ALL PRE-PROPOSAL INQUIRIES SHALL BE SUBMITTED VIA EMAIL TO parvinder.brar@va.gov and/or denise.groves@va.gov BY AN EDITABLE USE OF THIS FORM.

Please identify, in numerical sequence, each set of inquiries that you send.

Question(s) is/are on the solicitation [X]

Question(s) is/are on the drawings, specifications, technical data [X]

Company Name and Offeror: Talion Construction

From (person submitting question): Paul Leue- Cool Roofing Systems Inc

Date of Proposal Inquiry: February 17, 2016

Phone Number: 559-360-1294

Proposal Inquiry: (Type inquiry below)

Proposal RFI #1 – Will the VA allow the usage of Division 07 54 19 - Polyvinyl-Chloride Roofing specification for both Building 722 and 802 instead of the SOW specified BUR?

Proposal RFI #2 – Please define the after hour requirement for the roofing of B 802 mentioned at the pre-proposal meeting February 17, 2016. It was discussed this modular building is utilized as the Audiology clinic and any noise during "regular" hours is a problem.

Proposal RFI #3

Contractor will remove or replace any visually damaged BUR or sub-material up to 1200sf and repair any damaged mechanical curls up to 320sf. Once complete the contractor will place PVC material over the existing BUR. The re-roof project for Bldg 802 & Bldg 722 will require evening/night time shifts (5:00 PM-2:00AM) due to the audiology testing services and other patient services being performed Monday-Friday from 8:00 AM -4:30 PM.

Add additional as necessary