

REQUEST FOR INFORMATION (RFI)

VA251-16-R-0049

PROJECT NUMBER:	610-15-113	Please ensure that before submitting questions or requests for clarification that you thoroughly read the solicitation, specifications, drawings and other pertinent documents. When submitting questions on this project the Government requires contractors to specifically identify the specification and/or solicitation section(s) or drawing number(s) in reference to the question or request for clarification submitted. No question or request for clarification will be answered by the Government unless the above requirements are met. Failure to comply may prevent the Government from responding in a timely manner.	
PROJECT TITLE:	Replace Roofs, Various Buildings		
PROJECT LOCATION:	VA Northern Indiana-Marion Health Care System 1700 East 38 th Street Marion, IN 46953		
SUBMITTED BY:	<i>Kentuckiana General Construction</i>	CITY/STATE:	<i>New Albany IN 47150</i>
PHONE:	<i>812.913.0875</i>		

TO:

Felecia Beamen, Contracting Officer
Department of Veterans Affairs
NCO10 West Contracting Office
8888 Keystone Crossing, Suite 1100
Indianapolis, IN 46240
Felecia.beamen@va.gov

RFI NO.:	DATE: <i>3-4-16</i>	SPEC/DWG. REFERENCE(s): <i>073140-2</i> <i>PART 2 - Products 2.1 Materials</i>
REPLY NEEDED BY:		

INFORMATION NEEDED:

Metal Shingle Plus is a discontinued shingle. Can you provide us with what stone coated metal shingle you would want to use.

REPLY:

RFIs will be answered by amendment(s).

The Buildings we have that have steel shingles on them now are "Decra-Stone Coated Steel Shingles".
Thanks.

REPLY FROM:	Zachary McDaniel - COR	DATE:	3/8/2016
ATTACHMENTS:	NA	COPY TO:	