

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT			BPA NO.	1. CONTRACT ID CODE	PAGE 1	OF PAGES 4
2. AMENDMENT/MODIFICATION NO. A00011		3. EFFECTIVE DATE 03-10-2016	4. REQUISITION/PURCHASE REQ. NO. 675-16-1-3218-0003		5. PROJECT NO.(If applicable) 675-13-635	
6. ISSUED BY Department of Veterans Affairs Orlando VA Medical Center 5201 Raymond Street Orlando FL 32803		CODE	7. ADMINISTERED BY (If other than Item 6) Department of Veterans Affairs Network Contracting Activity 8 (NCO 8) Orlando VA Medical Center 5201 Raymond Street Orlando FL 32803		CODE	00675
8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code) To all Offerors/Bidders			(X)	9A. AMENDMENT OF SOLICITATION NO. VA248-15-R-1927		
				9B. DATED (SEE ITEM 11) 10-15-2015		
			X	10A. MODIFICATION OF CONTRACT/ORDER NO.		
				10B. DATED (SEE ITEM 13)		
CODE		FACILITY CODE				
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS						
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers <input type="checkbox"/> is extended, <input checked="" type="checkbox"/> is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing Items 8 and 15, and returning <u>1</u> copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.						
12. ACCOUNTING AND APPROPRIATION DATA (If required)						
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.						
CHECK ONE	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.					
	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).					
	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:					
	D. OTHER (Specify type of modification and authority)					
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.						
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) This modification serves to provide Answers to RFIs submitted for the revised proposal submissions. Please review continuation pages & attachments ***** Last Item *****						
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.						
15A. NAME AND TITLE OF SIGNER (Type or print)			16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)			
			Cory Pfenning NCO815L2-71927 Contracting officer			
15B. CONTRACTOR/OFFEROR		15C. DATE SIGNED	16B. UNITED STATES OF AMERICA		16C. DATE SIGNED	
(Signature of person authorized to sign)			BY (Signature of Contracting Officer)		03/10/2016	

CONTINUATION PAGE

RFIs submitted for proposal revisions

- 1. Is it the intent to have the Central Control System be compatible with the Lake Nona VA Central Control System or will a different manufacturer's Central Control System be acceptable?**

A1. A Different manufacturer's with a central Control system that meets specifications shall be acceptable.

- 2. Proposal discussion instructions (issued with Amendment 9) indicate that 1) submissions may be submitted via email and 2) a revised price response must be submitted, including the price schedule and SF1442.**

Please advise if administrative price proposal documents (reps and certifications, copies of acknowledged amendments, VetBiz certification) must also be included with revisions.

A2. Reps & certifications, copies of previously acknowledged amendments, and Vetbiz certification are not a required component of the revised price proposal.

- 3. Amendment A00009, drawing LP102 shows deletion of ground cover and extending sod into the area previously scheduled for ground cover. This area matchlines onto sheet LP103 where the same original construction details are specified for ground cover and sod, however LP103 has not been included in Amendment A0009 as requiring any revision to replace ground cover with sod. Is the ground cover supposed to be replaced with sod south of Raymond St on drawing LP103 similar to LP102?**

A3. A revised copy of Drawing LP103 was previously not provided. The updated drawing is attached to this amendment. The Summary of revisions has been updated and attached to annotate the changes on drawing LP103 that were previously omitted.

- 4. The area marked "Sod 1" on the extreme left side of drawing LP102 has the same issue as described above. Should sod 1 be deleted from LP103 to the east of modular building #505 to the match line?**

A4. A revised copy of Drawing LP103 was previously not provided. The updated drawing is attached to this amendment. The Summary of revisions has been updated and attached to annotate the changes on drawing LP103 that were previously omitted.

IMPROVE LANDSCAPING, IRRIGATION & RECLAIMED WATER STUDY

VA Medical Center Baldwin Park, Orlando, FL

VA PROJECT 675-13-635

Addendum # 03, dated Feb. 26, 2016

Rev. 03/08/2016, RFI # 03

SUMMARY OF REVISIONS

Specification Revisions

None.

Drawing Revisions

1. Dwg LI100, Rev. 2, dated 02/26/2016 Deleted requirement for maintenance and replace spray heads at parking lot (1) location, plan northeast.
2. Dwg LI101, Rev.3, dated 02/26/2016 Deleted requirement for removal of spray heads, etc. along east property line.
3. Dwg LI102, Rev. 2, dated 02/26/2016 Deleted requirement for maintenance and replace spray heads at parking lots (2) locations, (1) plan west, (1) plan north.
4. Dwg LI103, Rev. 2, dated 02/26/2016 Deleted requirement for maintenance and replace spray heads at parking lot (1) location, plan southeast.
5. Dwg LP101, Rev. 2, dated 02/26/2016 Deleted trees type QV at (1) location, building to remain, plan east.
6. Dwg LP102, Rev. 2, dated 02/26/2016 Deleted *sod*, trees type QV at (1) location, building to remain, plan northeast. *Deleted ground cover type JC, extended Sod type 2 where ground cover shown*
7. *Dwg LP103, Rev. 1, dated 02/26/2016 Deleted ground cover type JC, extended Sod type 2 where ground cover shown. Deleted sod, trees type QV at (1) location, building to remain.*

