

Building 257



Please Reply To:

AmeriSci Los Angeles

24416 S. Main Street, Ste 308
Carson, California 90745
TEL: (310) 834-4868 • FAX: (310) 834-4772

FACSIMILE TELECOPY TRANSMISSION

To: Jack McCubbin
MECA Consulting Inc dba Millennium Consulti
Fax #:
Email: Lgosselin@mecaenviro.com, mnoel@mecaenviro.com, frontdesk@mecaenviro.com

From: Paola Ducoing
AmeriSci Job #: 913101533
Subject: PLM 48 hour Results
Client Project: 22015-2030; VALA Asbestos Survey; Bldg. 257 Bulk Sampling

Date: Friday, October 18, 2013

Time: 08:41:06

Comments:

Number of Pages: 6
(including cover sheet)

CONFIDENTIALITY NOTICE: Unless otherwise indicated, the information contained in this communication is confidential information intended for use of the individual named above. If the reader of this communication is not the intended recipient, you are hereby notified that any dissemination, distribution or copying of this communication is prohibited. If you have received this communication in error, please immediately notify the sender by telephone and return the original message to the above address via the US Postal Service at our expense. Preliminary data reported here will be verified before final report is issued. Samples are disposed of in 60 days or unless otherwise instructed by the protocol or special instructions in writing. Thank you.

Certified Analysis Service 24 Hours A Day • 7 Days A Week Competitive Prices
visit our web site - www.amerisci.com

Boston • Los Angeles • New York • Richmond

**AmeriSci Los Angeles**

24416 S. Main Street, Ste 308

Carson, California 90745

TEL: (310) 834-4868 • FAX: (310) 834-4772

PLM Bulk Asbestos Report

MECA Consulting Inc dba Millennium Co
Attn: Jack McCubbin
620 Contra Costa Blvd
Ste 102
Pleasant Hill, CA 94523

Date Received 10/17/13**Date Examined** 10/18/13**AmeriSci Job #** 913101533**P.O. #** 8329**Page** 1 of 3**RE: 22015-2030; VALA Asbestos Survey; Bldg. 257 Bulk Sampling**

Client No. / HGA	Lab No.	Asbestos Present	Total % Asbestos
131003-361 1 Location: DW & TJ - Rm 116 Analyst Description: White, Homogeneous, Non-Fibrous, Drywall Asbestos Types: Other Material: Cellulose 5 %, Non-fibrous 95 %	913101533-01	No	NAD (by CVES) by Paola Ducoing on 10/18/13
131003-365 1 Location: DW & TJ - Restroom Entry Analyst Description: White/Brown, Heterogeneous, Fibrous, Drywall Asbestos Types: Other Material: Cellulose 10 %, Non-fibrous 90 %	913101533-02	No	NAD (by CVES) by Paola Ducoing on 10/18/13
131003-360 2 Location: Plaster - Rm 116 Analyst Description: White, Homogeneous, Non-Fibrous, Drywall Asbestos Types: Other Material: Cellulose 5 %, Non-fibrous 95 %	913101533-03	No	NAD (by CVES) by Paola Ducoing on 10/18/13
131003-366 2 Location: Plaster - Rm 26 Analyst Description: White/Grey, Heterogeneous, Non-Fibrous, Cementitious, Plaster Asbestos Types: Other Material: Non-fibrous 100 %	913101533-04	No	NAD (by CVES) by Paola Ducoing on 10/18/13
131003-362 3 Location: Ceramic Grout - Rm 116 Analyst Description: Beige, Homogeneous, Non-Fibrous, Grout Asbestos Types: Other Material: Non-fibrous 100 %	913101533-05	No	NAD (by CVES) by Paola Ducoing on 10/18/13

PLM Bulk Asbestos Report

22015-2030; VALA Asbestos Survey; Bldg. 257 Bulk Sampling


Client No. / HGA	Lab No.	Asbestos Present	Total % Asbestos
131003-366 3	913101533-06 Location: Ceramic Grout - Rm 18	No	NAD (by CVES) by Paola Ducoing on 10/18/13
Analyst Description: Grey, Heterogeneous, Non-Fibrous, Cementitious, Grout Asbestos Types: Other Material: Non-fibrous 100 %			
131003-364 4	913101533-07 Location: RSF & Mastic - Elevator Lobby Basement (Grey)	No	NAD (by CVES) by Paola Ducoing on 10/18/13
Analyst Description: Grey/Beige, Heterogeneous, Fibrous, Flooring Asbestos Types: Other Material: Cellulose 15 %, Non-fibrous 85 %			
131003-369 4	913101533-08L1 Location: RSF & Mastic - Entry Rm 2 (Grey)	No	NAD (by CVES) by Paola Ducoing on 10/18/13
Analyst Description: Grey/Beige, Heterogeneous, Fibrous, Flooring Asbestos Types: Other Material: Cellulose 15 %, Non-fibrous 85 %			
131003-369 4	913101533-08L2 Location: RSF & Mastic - Entry Rm 2 (Grey)	No	NAD (by CVES) by Paola Ducoing on 10/18/13
Analyst Description: Yellow, Homogeneous, Non-Fibrous, Mastic Asbestos Types: Other Material: Non-fibrous 100 %			
131003-363 5	913101533-09 Location: 2x4 ACT - Rm 117	No	NAD (by CVES) by Paola Ducoing on 10/18/13
Analyst Description: White/Grey, Heterogeneous, Fibrous, Ceiling Tile Asbestos Types: Other Material: Cellulose 45 %, Fibrous glass 25 %, Non-fibrous 30 %			
131003-368 5	913101533-10 Location: 2x4 ACT - Corridor Front Rm 26	No	NAD (by CVES) by Paola Ducoing on 10/18/13
Analyst Description: White/Grey, Heterogeneous, Fibrous, Ceiling Tile Asbestos Types: Other Material: Cellulose 45 %, Fibrous glass 25 %, Non-fibrous 30 %			

Client Name: MECA Consulting Inc dba Millennium Consulting


PLM Bulk Asbestos Report

22015-2030; VALA Asbestos Survey; Bldg. 257 Bulk Sampling

Reporting Notes:

Analyzed By: Paola Ducoing ; Date Analyzed: 10/18/2013 10/18/13

*NAD = no asbestos detected; Detection Limit <1%; Reporting Limits: CVES = 1%, 400 Pt Ct = 0.25%, 1000 Pt Ct = 0.1%; NA = not analyzed; NA/PS = not analyzed / positive stop; NVA = No Visible Asbestos; PLM (polarized light microscopy) Bulk Asbestos Analysis by EPA 600/M4-82-020 per 40 CFR 763 (NVLAP Lab #200346-0, CA ELAP lab #2322); Note: PLM is not consistently reliable in detecting asbestos in floor coverings and similar NOB materials. TEM is currently the only method that can be used to determine if this material can be considered or treated as non-asbestos-containing in New York State (also see EPA Advisory for floor tile, FR 59, 146, 38970, 8/1/94). NIST Accreditation requirements mandate that this report must not be reproduced except in full with the approval of the laboratory. This PLM report relates ONLY to the items tested.

Reviewed By:  10/12/13

10 samples

Asbestos, Lead Analysis Chain of Custody

AMERISCI

AmeriSci Job #:

913101533

Company: Millennium Consulting Associates		Address: 620 Contra Costa Blvd., Ste 102, Pleasant Hill, CA 94523				P.O #: 0329		
Project Information		Analysis Type		Turnaround Time			Air Filter Information:	
				Rush	24 HR	48 HR	72 HR	5 Day
Job Name: VALA Asbestos Survey		Asbestos TEM AHERA						
		Asbestos PLM Bulk				X		
Job Number: 22015-2030		Asbestos PCM Air						25 mm
		Asbestos PLM 1000 PC						37mm
Job Manager: W. Chase		Lead Air						0.45 um
		Lead Wipe						0.80 um
Job Description Bldg 257 Bulk Sampling		Lead Paint/Solid						TEMP:
		Other:						Other:
Initial Results Delivery: <input checked="" type="checkbox"/> Fax <input checked="" type="checkbox"/> Email <input type="checkbox"/> Verbal <input type="checkbox"/> Mail Only				Return Samples <input type="checkbox"/> Yes				
Reports To: frontdesk@mecaenviro.com; mnoc@mecaenviro.com				Phone: (925) 808-6700				
Invoice To:				Fax: (925) 808-6708				
Comments: * Analyze each bldg material on 1st positive stop #1's				Email:				
				Pager/Cell:				
Sample #	Sample Location	Start Time	End Time	Total Time X /Min. = Volume	Liters	Total	Area Square Ft.	
3100-311 DWGTT - Rm 116								
3105	↓ - Restroom Entry							
3100 Plaster - Rm 116								
3106	↓ - Rm 216							
3102 Ceramic Grad - Rm 116								
3106	↓ - Rm 18							
3104 RSF & Mask - Entrance Lobby								
3104 RSF	↓ - Entry Rm 12							
3103 2x4 AT - Rm 117								
3108 2x4	↓ - Corridor front Rm 216							

[illegible]

10/3/18

Feed Ex 10/3/13

K. M.

10/17/13 @1020