

KEYNOTES

1. INSTALL (N) 32" ID COMBINED BOILER FLUE AS SHOWN. SLOPE TOWARDS DRAINS. SUPPORT AS NECESSARY.
2. INSTALL ¾" STAINLESS STEEL DRAIN PIPING.
3. EXISTING 12" CONDENSER WATER PIPING TO REMAIN.
4. 32"ø ID DUCTS TO NEW INDUCED DRAFT FANS.
5. NEW VENTS THROUGH ROOF. SEE PLAN VIEWS FOR DETAILS.

BASE BID
MECHANICAL
EAST ELEVATION

A 0 4' 8' 3/16" = 1'-0"



DESIGN DEVELOPMENT - NOT FOR CONSTRUCTION

Revisions:	Date

CONSULTANTS:

ARCHITECT/ENGINEERS:

GLHN
ARCHITECTS & ENGINEERS, INC.
2939 E. Broadway Blvd. Tucson, Arizona 85716
PH: 520-881-4546 FAX: 520-795-1822 glhn.com

COPYRIGHT 2010 GLHN ARCHITECTS & ENGINEERS, INC. ALL RIGHTS RESERVED

Drawing Title: BASE BID: AREA G MECHANICAL EAST ELEVATION

Approved Project Director

Project Title: MIAMI UTILITY PLANT CORRECTIONS

Location: MIAMI UTILITY PLANT

Date: 08-05-11 | Checked: HWJ | Drawn: WMK

Project Number: 0555.118

Building Number: G/A

Drawing Number: MH201

Dwg. -- of --

Office of Construction and Facilities Management

Department of Veterans Affairs

VA FORM 08-6231