

Construct New Specialty Care Building #42  
RFI and VAMC Responses

| Item # | Questions   | Responses  |
|--------|---|--|
| 1      | Is there a preference or basis of design for the medical gas equipment such as Amico, Beacon Med etc.?  | No preference can be provided; however, contractor shall use only one manufacturer for all medical vacuum systems and equipment. |
| 2      | Will missing drawings PP303, PP501, PP601, M-001 & M-002 be provided?   | Yes, provided in amendment   |
| 3      | Will missing drawings PP303, PP501, PP601, M-001, M-002, EY501, EY601 & R-901 be provided?  | Yes, provided in amendment   |
| 4      | Spec section 00 01 15 "List of Drawing": The following plans are listed on the plans list but not included in the VA portal: PP303, PP501, PP601, M001, M002. | Missing plans are provided and specification section 00 01 15 has been revised.  |
| 5      | The following plans are NOT listed in the plans list but are included in the VA portal: CU105, FA101, FA102, FA501.   | Missing plans are provided and specification section 00 01 15 has been revised.  |
| 6      | Request to see the Pre Bid conference attendees.  | Will be provided in amendment.   |
| 7      | Is blast resistant glazing being used?  | No, provided revised specification section 081400 and 088000 as an amendment for clarification.                                  |
| 8      | Does the contractor need to install Linear Accelerator and other equipment?   | No, provided revised Level 0 equipment plan as an amendment for clarification.   |