

# PACKING SLIP

~~Hays Cleveland~~  
~~Division of UniControl Inc.~~  
~~1111 BROOK PARK ROAD~~  
~~CLEVELAND OHIO 44109~~  
~~216-398-0030/216-398-5568~~

Shipper No: 4296  
 Ship Date: 06/30/15  
 Page: 1

PACKING  
LIST

**B** HEAT TRANSFER SOLUTIONS  
~~10012 GOTHARD STREET~~  
~~HUNTINGTON BEACH, CA 92647~~

**S** ACCO ENG SYSTEMS JOB 810004  
**H** M/F GREG WALKER 818-780-5479  
**I** 6446 E WASHINGTON BLVD  
**P** COMMERCE, CA 90040

Sales Order No: 4296  
 Order Date: 10/29/14  
 Cust Code: HEATRA  
 Pmt Terms: 1%-10, N30

Purchase Order: HTS03305  
 Ship Via: SEE NOTES  
 FOB: PLANT  
 Salesperson: 0

Line	Part Number	Description	UM Bin Loc	Qty This Shipment	Qty Actually Shipped
A1	ADVANCE	ADVANCE PAYMENT 30% OF ORDER TOTAL AT TIME OF SUBMITTAL APPROVALS. JOB NAME: VA LONG BEACH BOILER #1, SO 4296	EA	1	1
THIS RELEASE FOR BOILER 1 PANEL, FIELD EQUIPMENT AND DOCUMENTATION- COMPLETE					
1	SYSTEM	MISC HARDWARE FOR MODULES AS SPECIFIED BY HC ENGINEERING	EA	1	1
2	42008	IO-CB-AI-08-HL-0-0	EA	4	4
2A	42010	ANALOG INPUT, VDC MADC IO-CB-AI-04-RT-0-0	EA	2	2
2B	42014	THERMOCOUPLE, RTD INPUT IO-CB-AO-08-HL-0-0	EA	2	2
2C	42074	ANALOG OUTPUT, VDC MADC AC INPUT MODULE, 16 CHANNEL SIGMA ASCON P/N: 10-CB-DI-16-HV-00 SIGMA 16 CHANNEL AC INPUT MODULE	EA	1	1
2D	42016	IO-CB-DO-16-TS-0-0	EA	1	1
2E	42023	DIGITAL OUTPUT IO-CB-DM-08-TS-0-0	EA	1	1

# PACKING SLIP

~~Jays Cleveland~~

~~Division of UniControl Inc.~~

~~1111 BROOK PARK ROAD~~

~~CLEVELAND, OHIO 44109~~

~~216-398-0330/216-398-8558~~

Shipper No: 4296

Ship Date: 06/30/15

Page: 2

**B** ~~HEAT TRANSFER SOLUTIONS~~  
**I** ~~16812 GOTHARD STREET~~  
**L** ~~HUNTINGTON BEACH, CA 92647~~  
**L**

**S** ~~7000 ENG SYSTEMS JOE 010001~~  
**H** ~~WALKER 818 700 379~~  
**I** ~~415 E WASHINGTON BLVD~~  
**P** ~~COMMERCIAL 90000~~

Sales Order No: 4296  
Order Date: 10/29/14  
Cust Code: HEATRA  
Pmt Terms: 1%-10, N30

Purchase Order: HTS03305  
Ship Via: SEE NOTES  
FOB: PLANT  
Salesperson: 0

Line	Part Number	Description	UM	Bin Loc	Qty This Shipment	Qty Actually Shipped
2F	ENGR	DIGITAL INPUT OR OUTPUT CONFIGURE ASCON I/O MODULES AS DESCRIBED IN SYSTEM SCHEMATIC DIAGRAMS B68511 SHEETS 1 THRU 8	EA		11	11
3	42026	CU02-5010	EA		1	1
3A	ENGR	SIGMA CPU CONTROL MODULE PROGRAM ASCON CONTROL MODULE PER SCOPE, AND AS DESCRIBED IN SYSTEM SCHEMATIC DIAGRAM B68576 SHEET 7	EA		1	1
4	42049	TOUCHSCREEN	EA		1	1
4A	42053	12.1" W/42053 RUNTIME LIC W/42049	EA		1	1
4B	ENGR	TOUCH SCREEN 7.1 VERSION CONFIGURE HMI TOUCHSCREEN	EA		1	1
5	42069	BOILER 1 POWER SUPPLY, 5V DC	EA		1	1
5A	42094	MEAN WELL MODEL MDR-10-5 5 VOLT DC POWER SUPPLY, 24VDC @ 1.00A 24VDC @ 1.00A OUTPUT DIN RAIL MOUNT	EA		1	1
5B	42096	24 WATT SINGLE OUTPUT MODEL POWER SUPPLY, 24VDC @ 2.50A 24VDC @ 2.50A OUTPUT DIN RAIL MOUNT	EA		1	1

# PACKING SLIP

Division of Control Inc.  
 16812 60TH STREET  
 CLEVELAND, OHIO 44109  
 216-398-0830/216-398-8558

Shipper No: 4296  
 Ship Date: 06/30/15  
 Page: 3

BULK TRANSFER SOLUTIONS  
 16812 60TH STREET  
 HUNTINGTON BEACH, CA 92647

SALES ENGINEERING SYSTEMS JOB 620001  
 MR GREG WALKER 714-200-5449  
 600 E WASHINGTON BLVD  
 COMMERCE, CA 90040

Sales Order No: 4296  
 Order Date: 10/29/14  
 Cust Code: HEATRA  
 Pmt Terms: 1%-10, N30

Purchase Order: HTS03305  
 Ship Via: SEE NOTES  
 FOB: PLANT  
 Salesperson: 0

Line	Part Number	Description	UM Bin Loc	Qty This Shipment	Qty Actually Shipped
5C	899	60 WATT SINGLE OUTPUT MODEL UL 508 CLASS 2 POWER SUPPLY, 2.5A	EA	3	3
6	42070	CONVERTER, 232/485 LDR C9	EA	1	1
7	42071	B & B ETHERNET SWITCH, 4 PORT 10/100M 4 PORT ETHERNET SWITCH	EA	1	1
8	31313	10/100M FULL/HALF DUPLEX CONTROLLER FAULT MODULE PCA	EA	1	1
9	42072	ISOLATOR, ACROMAG 4 CHANNEL 4-20 MADC	EA	2	2
9A	899	ACROMAG #674T-0600 4 CHANNEL 4-20 MADC ISOLATOR	EA	2	2
10	26624	API 4380G 3-WAY SIGNAL ISOLATOR, OCTAL SOCKET MTG	EA	5	5
10A	899	Relay, 10A DPDT 120 VAC AB700-HA32Z24, RELAY, 24 VDC	EA	7	7
10B	30868	COIL, DPDT Socket, Relay 8 Pin DIN Mount	EA	14	14
11	42073	Octal Base RELAY, SOLID STATE DIN RAIL MOUNTING	EA	10	10
11A	31320	SOLID STATE RELAY QUENCH ARCS	EA	10	10
12	899	STK #539-104MO6QC100 ASHCROFT DX-7-F01-42-ST-201W, DRAFT RANGE TRANSDUCER 0 TO +20" WC WINDBOX	EA	1	1

# PACKING SLIP

~~Hays Cleveland~~  
~~Division of UniControl Inc.~~  
~~1111 BROOK PARK ROAD~~  
~~CLEVELAND, OHIO 44109~~  
~~216-398-0336/216-398-8558~~

Shipper No: 4296  
 Ship Date: 06/30/15  
 Page: 4

**B** HEAT TRANSFER SOLUTIONS  
**I** 16812 GOTHARD STREET  
**L** HUNTINGTON BEACH, CA 92647  
**L**

**S** ACCO ENG SYSTEMS JOB 010201  
**H** M/F GREG WALKER 818-730-8470  
**I** 5416 E WASHINGTON BLVD  
**P** COMMERCE, CA 90040

Sales Order No: 4296  
 Order Date: 10/29/14  
 Cust Code: HEATRA  
 Pmt Terms: 1%-10, N30

Purchase Order: HTS03305  
 Ship Via: SEE NOTES  
 FOB: PLANT  
 Salesperson: 0

Line	Part Number	Description	UM	Bin Loc	Qty This Shipment	Qty Actually Shipped
12A	899	ASHCROFT DX-7-F01-42-ST-5IWL DRAFT RANGE TRANSDUCER -5/0/+5 IN WC OUTLET	EA	<i>Carton</i>	1	<u>1</u>
12B	899	ASHCROFT, DX-7-F01-42-ST-2IWL DRAFT RANGE TRANSDUCER, -2/0/+2 IN WC UPTAKE	EA		1	<u>1</u>
12C	00783	COCK, 3-WAY	EA		3	<u>3</u>
13	A08740A012	A08740A0-12 Opacity Monitor - NYC - FM INCLUDE WITH EACH UNIT: QTY 1 P/N 31180 LIGHT SOURCE QTY 1 P/N 31181 RECEIVER QTY 2 P/N 27367 SIGHT GLASS Purge Air System	EA		1	<u>1</u>
13D	31726	API CS-AC-2 CURRENT SWITCH	EA		1	<u>1</u>
13E	899	TAG: OPACITY MONITOR ITEMS 13A TO 13E SHIPPED LOOSE FOR FIELD MOUNTING	EA		1	<u>1</u>
14	899	HOFFMAN VENT.KIT PER DWG B68530,	EA		1	<u>1</u>
14A	899	SPARE FILTERS, HOFFMAN TFLT10UL12, 5-PACK	EA	<i>in panel</i>	1	<u>1</u>
15	899	APC 420 VA UPS FOR CONTROL SYSTEM SHIPPED IN ORIGINAL MANUFACTURERS CARTON	EA		1	<u>1</u>
16	ENGR	UL508 COMPLIANT WITH UL LABEL FOR CONTROL PANEL	EA		1	<u>1</u>
17	SYSTEM	SYSTEM BOILER CONTROLS WITH	EA		1	<u>1</u>

# PACKING SLIP

~~Hays Cleveland~~  
~~Division of LinControl Inc.~~  
~~1111 BROOKPARK ROAD~~  
~~CLEVELAND, OHIO 44109~~  
~~216-898-8330/216-398-8558~~

Shipper No: ~~4256~~  
 Ship Date: ~~06/30/15~~  
 Page: 5

**B** HEAT TRANSFER SOLUTIONS  
**I** 16812 GOTHARD STREET  
**L** HUNTINGTON BEACH, CA 92647  
**L**

**S** ~~ACCO ENG SYSTEMS JOB 570051~~  
**H** ~~MICHAEL WALKER 818-750-470~~  
**I** ~~6448 E WASHINGTON BLVD~~  
**P** ~~COMMERCE, CA 90040~~

Sales Order No: 4296  
 Order Date: 10/29/14  
 Cust Code: HEATRA  
 Pmt Terms: 1%-10, N30

Purchase Order: HTS03305  
 Ship Via: SEE NOTES  
 FOB: PLANT  
 Salesperson: 0

Line	Part Number	Description	UM	Bin Loc	Qty This Shipment	Qty Actually Shipped
ABOVE ITEMS. SUBPANEL PER PER LAYOUT DWG B68530 SHT 1 PANEL & SYSTEM PER APPROVED DRAWINGS: 18E ENGR B68580 PANEL LAYOUT DWGS 18A SYSTEMENGR B68581 SYSTEM CONFIG DWGS 18B SYSTEMENGR B68582 WIRING DWGS 18C SYSTEMENGR 19 ENGR SUBMITTED FOR APPROVAL TO JEFF WELTON AT HEAT TRANSFER SOLUTIONS ON 10/31/2014. SYSTEM APPROVED AND RELEASED BY THE CONTRACTOR, WITH NOTICE FROM DANIEL PEREZ AND JEFF WELTON TO RELEASE ORDER SHIPPING AND HANDLING CHARGE						
20	99996		EA		1	1
FOLLOWING ITEMS ARE FIELD MTD:						
21	899	ASHCROFT 1377 6-INCH DIAL PRESSURE GAUGE. TAG: BOILER 1 FEED WATER PRESSURE 0-300 PSIG. NOTE: MOUNT ABOVE EXISTING MAIN PANEL	EA		1	1
22	899	PYROMATION R1T185L483- S4D0609T2-SL-8HN31. 100-OHM LO TEMP RTD ASSY IN SS T-WELL; 3/4" NPT, U=2.5". ALUMINUM	EA		2	2

~~Hays Cleveland~~

~~Division of UniControl Inc.~~

~~1111 BROOKPARK ROAD~~

~~CLEVELAND, OHIO 44109~~

~~216-398-0330/216-398-8558~~

# PACKING SLIP

Shipper No: 4296

Ship Date: 06/30/15

Page: 6

**B** ~~HEAT TRANSFER SOLUTIONS~~  
~~16842 GOTHARD STREET~~  
**I** ~~HUNTINGTON BEACH, CA 92647~~  
**L**  
**L**

**S** ~~ACCO-ENG SYSTEMS JOB 616001~~  
~~M/E GREG WALKER 818-730-5479~~  
**H** ~~6448 E WASHINGTON BLVD~~  
**I** ~~COMMERCE, CA 90040~~  
**P**

Sales Order No: 4296  
Order Date: 10/29/14  
Cust Code: HEATRA  
Pmt Terms: 1%-10, N30

Purchase Order: HTS03305  
Ship Via: SEE NOTES  
FOB: PLANT  
Salesperson: 0

Line	Part Number	Description	UM	Bin Loc	Qty This Shipment	Qty Actually Shipped
		WIRING HEAD				
		TAG(1) BLR 1 ECON WATER INLET				
		TEMP				
		TAG(1) BLR 1 ECON WATER OUTLET				
		TEMP				
23	899	PYROMATION R1T185L483-	EA	①	1	1
		-S4D0422-SL-8HN31. 100 OHM				
		LO-TEMP RTD ASSY IN BRASS				
		WELL; 3/4" NPT, U=2.5". ALUM.				
		WIRING HEAD. TAG(1) BOILER				
		NATURAL GAS LINE TEMP				
		ELEMENT				
24	899	PYROMATION R1T185H683-018-00	EA	①	2	2
		-8HN31. 100-OHM HI TEMP RTD				
		ASSY; 1/2" NPT, 18" INSERTION.				
		ALUMINUM WIRING HEAD.				
		TAG(1) BLR 1 SCR REACTOR FLUE				
		GAS INLET TEMP				
		TAG(1) BLR 1 FLUE GAS ECON				
		OUTLET TEMP				
25	899	FOXBORO IGP10-T22D1F-L1,	EA	④, 5	4	4
		GAUGE PRESSURE TRANSMITTER				
		HART WITH OPT PUSH BUTTONS &				
		DISPLAY. WITH 4-20 MA OUTPUTS				
		PER TAGS:				
		TAG(1) BLR 1 NATURAL GAS LINE				

~~Hayes Cleveland~~

~~Division of Oil Control Inc.~~

~~1111 BROOK PARK ROAD~~

~~CLEVELAND, OHIO 44109~~

~~216-222-0000/216-222-0300~~

# PACKING SLIP

Shipper No: ~~4296~~

Ship Date: 06/30/15

Page: 7

**B** ~~HEAT TRANSFER SOLUTIONS~~  
**I** ~~16812 COTHARD STREET~~  
**L** ~~HUNTINGTON BEACH, CA 92647~~  
**L**

**S** ~~ACCO ENG SYSTEMS JOB 040001~~  
**H** ~~MR GREG WALKER 818-730-5479~~  
**I** ~~6440 E. WASHINGTON BLVD~~  
**P** ~~COMMERCE, CA 90048~~

Sales Order No: 4296  
Order Date: 10/29/14  
Cust Code: HEATRA  
Pmt Terms: 1%-10, N30

Purchase Order: ~~41508305~~  
Ship Via: SEE NOTES  
FOB: PLANT  
Salesperson: 0

Line	Part Number	Description	UM	Bin Loc	Qty This Shipment	Qty Actually Shipped
		PRESSURE 0-30 PSIG				
		TAG(1) BLR 1 STEAM PRESSURE				
		0-200 PSIG				
		TAG(1) BLR 1 SCR AMMONIA				
		LINE PRESSURE, 0-200 PSIG				
		TAG(1) BLR 1 FEED WATER				
26	899	PRESSURE, 0-300 PSIG				
		ANDERSON GREENWOOD	EA	(1)	1	1
		M9VIS-44, 0.5" NPT ISOLATION				
		VALVE WITH BLEED VENT				
		TAG(1) BOILER 1 STEAM				
27	899	PRESSURE XMTR VALVE				
		FOXBORO IDP10-T22A21F-LIMI,	EA	(1)	1	1
		LOW RANGE DIFF PRESSURE				
		TRANSMITTER. HART WITH OPT				
		PUSH BUTTONS & DISPLAY. PIPE				
		MTG BRKT. WITH 4-20 MA OUTPUT				
		PER THE FOLLOWING TAGS:				
		TAG(1) FURNACE DRAFT PRESS				
		-2/0/+2 IN WC				
28	899	FOXBORO IDP10-T22B21F-L1M1,	EA	(1)	1	1
		DIFF PRESSURE TRANSMITTER.				
		HART WITH OPT PUSH BUTTONS &				
		DISPLAY. PIPE MTG BRKT				
28A	899	BM-M4AVC 3- VALVE MANIFOLD	EA	(1)	1	1
		4-20 MA OUTPUT PER THE				
		FOLLOWING TAG(1) BOILER 1				

~~Haye Cleveland~~  
~~Division of UniControl Inc.~~  
~~1411 BROOKPARK ROAD~~  
~~CLEVELAND, OHIO 44109~~  
~~216-398-9330/216-398-8558~~

# PACKING SLIP

Shipper No: 4296  
Ship Date: 06/30/15  
Page: 8

B HEAT TRANSFER SOLUTIONS  
I 10000 CLEVELAND  
L  
L

S 7500 ENG SYSTEMS JOB 810004  
H M/REG WALKER 318-5305479  
I 6440 E. WASHINGTON BLVD  
P COMMERCE, CA 90040

Sales Order No: 4296  
Order Date: 10/29/14  
Cust Code: HEATRA  
Pmt Terms: 1%-10, N30

Purchase Order: ~~PT502305~~  
Ship Via: SEE NOTES  
FOB: PLANT  
Salesperson: ~~ea~~

Line	Part Number	Description	UM	Bin Loc	Qty This Shipment	Qty Actually Shipped
29	899	WATER LEVEL -20 TO 0 IN WC FOXBORO 84F-U06S2SSRJZ-G 6-INCH X 300 LB FLANGED VORTEX STEAM FLOW METER BODY WITH REMOTE MOUNTED TRANSMITTER; DISPLAY, HART. 50 FOOT CABLE. SIZED PER M300 DATA SHEET, WITH 4-20 MA OUTPUT CALIBRATED AS FOLLOWS: TAG(1) BOILER 1	EA	(10)	1	1
30	899	STEAM FLOW, 0-35,000 LB/HR FOXBORO 84F-UIHS2SSTJZ, 1.5 INCH X 300 LB FLANGED VORTEX WATER FLOW METER BODY WITH METER BODY MOUNTED TRANSMITTER. LOCAL DISPLAY AND HART. SIZED PER M300 DATA SHEET, WITH 4-20 MA OUTPUT CALIBRATED AS FOLLOWS: TAG(1) BOILER 1 FEED WATER	EA	(7)	1	1
31	899	FLOW, 0-46,000 LB/HR INFLOW ITM050G-C1D1-XX2AN2, INSERTION TURBINE FLOW METER, 1.5 INCH NPT FITTING WITH THREAD-O-LET. LOCAL DISPLAY OF FLOW. 24 VDC POWERED. LOCAL DISPLAY AND	EA	(3)	1	1



~~Hays Cleveland~~

~~Division of UniControl Inc.~~

~~1111 BROOKPARK ROAD~~

~~CLEVELAND, OHIO 44100~~

~~216-888-0330/216-338-8588~~

# PACKING SLIP

Shipper No: 4296

Ship Date: 06/30/15

Page: 9

**B** HEAT TRANSFER SOLUTIONS  
**L** 16812 GOTHARD STREET  
**L** HUNTINGTON BEACH, CA 92647  
**L**

**S** ACCO ENG SYSTEMS JOB 040001  
**H** M/ GREG WALKER 818-730-3479  
**I** 6440 E. WASHINGTON BLVD  
**P** COMMERCE, CA 90030

Sales Order No: 4296  
Order Date: 10/29/14  
Cust Code: HEATRA  
Pmt Terms: 1%-10, N30

Purchase Order: HTS03305  
Ship Via: SEE NOTES  
FOB: PLANT  
Salesperson: 0

Line	Part Number	Description	UM	Bin Loc	Qty This Shipment	Qty Actually Shipped
		4-20 MADC TRANMITTED FLOW IS IN ACFH FOR PRESS & TEMP COMPENSATION IN UPAC. NOMINAL GAS LINE CONDITIONS: 4" HORIZONTAL LINE, 10 PSIG, 60 DEG F. TAG(1) BOILER 1 GAS FLOW, 0-24,500 ACFH	EA		1	1
32	28401	AFS-952-55-B	EA	①	1	1
32A	60631	-344, FACTORY CALIBRATE SET A +4.0" WC PRV TAG(1) BOILER 1 HIGH DRAFT	EA		1	1
		SAFETY SWITCH PROBE W/O FLAME ARR	EA	⑫	1	1
33	A10018AA01	W/1048088 GASKET	EA	①	1	1
33A	2556074	FILTER,REGULATOR ASSY	EA	①	1	1
		C05 OPTION	EA	①	1	1
33B	3030374	PANEL ASSY,FLOW CONTRL	EA	①	1	1
		C06 OPTION	EA	②	1	1
33C	A10018AD02	CABLE ASSY, 20' LONG TAG(1) BOILER 1 02 ANALYZER COMPONENTS	EA		1	1
		FZ1 Calibration Gas (4.4/5.0%) (Disposable Cylinder)	EA	MSDS	1	1
33D	1182205					
33E	1196112	FZ2 Regulator, Cal. Gas Cyl TAG LINE 33D AND E BOILER 1 02 ANALYZER TEST GAS	EA		1	1

~~Flays Cleveland~~

~~Division of UniControl Inc.~~

~~111 BROOK PARK ROAD~~

~~CLEVELAND, OHIO 44109~~

~~216-398-0330/216-398-8558~~

# PACKING SLIP

Shipper No: ~~4296~~

Ship Date: 06/30/15

Page: 10

**B** ~~HEAT TRANSFER SOLUTIONS~~  
**I** ~~16812 COTHARD STREET~~  
**L** ~~HUNTINGTON BEACH, CA 92647~~  
**L**

**S** ~~ACCO ENG SYSTEMS JOB #10001~~  
**H** ~~M/F OREG WALKER 818-730-5429~~  
**I** ~~6446 E WASHINGTON BLVD~~  
**P** ~~COMMERCE, CA 90040~~

Sales Order No: 4296  
Order Date: 10/29/14  
Cust Code: HEATRA  
Pmt Terms: 1%-10, N30

Purchase Order: HTS03305  
Ship Via: SEE NOTES  
FOB: PLANT  
Salesperson: 0

Line	Part Number	Description	UM	Bin Loc	Qty This Shipment	Qty Actually Shipped
*NOTE* GAS AND REGULATOR WILL BE DIRECT SHIPPED FROM PRAXAIR TO ACCO ENGINEERED SYSTEMS						
34	A10050A0A03	SURFACE MOUNT, NEMA 4X ELECT. FOR MODELS A10007, A10018	EA	(2)	1	( )
34A	A10050A0Z00	FACTORY DEFAULT CONFIGURATION TAG(1) BLR 1 O2 ANALYZER ELECTRONICS	EA		1	( )
35	899	AB 802T-APD LIMIT SWITCH, 1 NO, 1 NC, WITH:	EA	(1)	1	( )
35A	899	AB802T-W1H LEVER, 1.5-INCH WITH ROLLER. TAG(1) BOILER OUTLET DAMPER PURGE	EA	(1)	1	( )
36	F00875KA02	POSITION SWITCH DIRECT 115 VAC INPUT INCLUDE WITH EACH UNIT IN SEPERATE BAG: QTY 1 BREATHER PLUG (NO P/N) QTY 1 P/N 1180133 WRENCH QTY 2 P/N 1138558 CLEVIS QTY 1 P/N 1052014 STUD QTY 1 P/N 1040014 STUD QTY 1 P/N 1034096 NUT QTY 1 P/N 1040099 COTTER PIN QTY 1 P/N 1034099 NUT	EA	(13)	1	( )
36A	F00875KC01	MOUNTING HARDWARE,POTS	EA	(13)	1	( )

~~Hays Cleveland~~

~~Division of UniControl Inc.~~

~~1111 BROOK PARK ROAD~~

~~CLEVELAND, OHIO 44109~~

~~216-398-0330/216-398-8558~~

# PACKING SLIP

Shipper No: 4296

Ship Date: 06/30/15

Page: 12

**B** HEAT TRANSFER SOLUTIONS  
**I** 16812 GOTHARD STREET  
**L** HUNTINGTON BEACH, CA 92647  
**L**

**S** ACCO ENG SYSTEMS JOB 610001  
**H** M/F GREG WALKER 818-730-5479  
**I** 6446 E. WASHINGTON BLVD  
**P** COMMERCE, CA 90040

Sales Order No: 4296  
Order Date: 10/29/14  
Cust Code: HEATRA  
Pmt Terms: 1%-10, N30

Purchase Order: HTS03305  
Ship Via: SEE NOTES  
FOB: PLANT  
Salesperson: 0

Line	Part Number	Description	UM Bin Loc	Qty This Shipment	Qty Actually Shipped
------	-------------	-------------	------------	-------------------	----------------------

SHIP COMPLETE, NO PARTIALS UNLESS AUTHORIZED BY CUSTOMER

Total Weight:	Freight:	Date Filled:
Total Cubic Ft:	Insurance:	Filled By: