

ALL COMPONENTS LOCATED IN THE GROUNDS MAINTENANCE STORAGE ROOM SHALL BE EXPLOSION PROOF

LOCKABLE WALL MOUNTED SWITCH BY E.C. TO SERVE 3003-IH-1, 3003-EF-1

3003-IH-1

3003-EF-1

3003-EF-2

3003-IH-2

REFER TO 1/3003-4.1 FOR ROOF MOUNTED FAN/HOOD DETAIL (TYP.)

3003-EF-3

TIMER SWITCH BY E.C. TO SERVE 3003-IH-2, 3003-EF-2

TIMER SWITCH BY E.C. TO SERVE 3003-IH-3, 3003-EF-3

3003-IH-3

Vehicle / Equipment Storage Building 1

S101

Vehicle / Equipment Storage Building 2

S102

FLAMMABLE SMALL STORAGE



1 VEHICLE STORAGE BUILDING FLOOR PLAN - HVAC

SCALE 1/4"=1'-0"

Revisions	Date

**KJW** ENGINEERING CONSULTANTS  
Experience you can build on.<sup>™</sup>  
623 25TH AVENUE  
ROCK ISLAND, IL 61201  
309.786.0673 FAX: 309.786.5967  
www.kjw.com  
KJW Project # 10.0356.00  
STRUCTURAL / MECHANICAL / ELECTRICAL /  
TECHNOLOGY / MEDICAL EQUIPMENT SOLUTIONS

I hereby certify that this Plan, Specification, or Report was prepared by me, or under my direct supervision and that I am a duly licensed Professional Engineer under the laws of the State of Oregon.  
Signature: Warren L. Lloyd  
Name: Mechanical  
Discipline: Mechanical  
Oregon Registration No. 78701PE Expiration date: 12.31.12  
Date Issued: \*\*/\*\*/11

Anderson Engineering of Minnesota, LLC

13605 1st AVENUE NORTH, SUITE 100, PLYMOUTH, MN 55441  
TEL (763) 412-4000 FAX (763) 412-4090  
www.ae-mn.com



N ATIONAL  
C EMETERY  
A DMINISTRATION

Drawing Title <b>VEHICLE STORAGE BLDG FLOOR PLAN - HVAC</b>		Project Title REPLACE ADMINISTRATION AND MAINTENANCE BUILDING AND SITE IMPROVEMENTS		Date 7-1-2011
Approved: Director, Office of Construction Management		Building Number <b>3003</b>	Checked <b>DavBod</b>	Drawn <b>JamTho</b>
Approved: Director, Project Management Service		Location EAGLE POINT NATIONAL CEMETERY 2763 RILEY ROAD EAGLE POINT, OR 97524		DRAWING NO. <b>H-3003-21</b> Dwg. 168 OF 181