

LUMINAIRE SCHEDULE		
MOUNTING: (MTG) RE - RECESSED SP - SUSPENDED CL - CEILING SURFACE WL - WALL UC - UNDER CABINET CV - COVE PL - POLE O - OTHER (SEE DESCRIPTION)	LAMP TYPE: FL - FLUORESCENT CF - COMPACT FLUORESCENT HL - HALOGEN IN - INCANDESCENT LED - LIGHT EMITTING DIODE HS - HIGH PRESSURE SODIUM MH - METAL HALIDE SMH - SUPER METAL HALIDE PSMH - PULSE START METAL HALIDE CMH - CERAMIC METAL HALIDE O - OTHER (SEE DESCRIPTION) XL - EXTENDED LIFE XLP - EXTENDED LIFE & OUTPUT	LENS/LOUVER: (L/L) A - .125" ACRYLIC B - BLACK BAFFLE C - CLEAR ALZAK D - PARABOLIC F - FRESNEL G - TEMPERED GLASS H - WALL WASHER P - POLYCARBONATE K - KSH12 .125" ACRYLIC K19 - KSH19 .156" ACRYLIC L - LOW IRIDESCENT SPECTULAR ALUM. N - NONE R - HIGH IMPACT DR ACRYLIC O - OTHER (SEE DESCRIPTION)
DOOR: FA - FLAT ALUMINUM FS - FLAT STEEL RA - REGRESSED ALUMINUM RS - REGRESSED STEEL	BALLAST: (BLS) DIM - DIMMING BALLAST EB - ELECTRONIC BALLAST EM - EMERGENCY BATTERY/BALLAST DALI - DIGITAL DIMMING BALLAST	##BF - BALLAST FACTOR HL - HIGH / LOW LEVEL BALLAST HP - HIGH PERFORMANCE ML - MULTI-LEVEL SWITCHING MV - MULTI-VOLTAGE ELECTRONIC
FINISH: PAF - PAINT AFTER FABRICATION CSA - FINISH SELECTION BY ARCHITECT		

ALL LAMPS FOR THIS PROJECT SHALL BE FURNISHED AND INSTALLED BY THE ELECTRICAL CONTRACTOR UNLESS OTHERWISE NOTED.
FLUORESCENT LAMP CORRELATED COLOR TEMPERATURE 3500°, COLOR RENDERING INDEX (CRI) AT OR ABOVE 80, UNLESS NOTED OTHERWISE.

TYPE: BOLT-ON

MOUNTING: SURFACE

FED FROM: UTILITY TRANSFORMER VIA FDS-100R

SCCR: 42,000

NOTES:

</

PH	LEFT	RIGHT
A	1.3	1.8
B	0.7	1.3
C	1.0	0.0
A	0.0	0.8
B	0.4	1.0
C	1.0	1.0
A	0.6	2.9
B	0.0	2.9
C	0.8	2.9
A	0.8	0.7
B	0.8	1.6
C	0.8	2.3
A	0.8	1.0
B	0.8	0.0
C	0.8	0.0
A	0.0	0.0
B	0.0	0.0
C	0.0	0.0
A	0.0	0.0
B	0.0	0.0
C	0.0	0.0

Drawing Title ELECTRICAL LUMINAIRE SCHEDULE - VEHICLE STOR.		Project Title REPLACE ADMINISTRATION AND MAINTENANCE BUILDING AND SITE IMPROVEMENTS		Date 7-1-2011
Approved: Director, Office of Construction Management		Building Number 3003	Checked JOHMcG	Drawn BRAWIT
		<div>DRAWING NO. E-3003-61</div> <div>Dwg. 175 Of 181</div>		
Approved: Director, Project Management Service		Location EAGLE POINT NATIONAL GEMETRY 2763 RILEY ROAD EAGLE POINT, OR 97524		