

589-CA3-370 CONSTRUCT PARKING GARAGE, KCVA

AMENDMENT P00003

GLMV ARCHITECTURE, INC.  
9229 Ward Parkway, Suite 210  
Kansas City, MO 64114

Inpatient Parking Garage  
Kansas City VA Medical Center  
Kansas City, Missouri  
Solicitation Number VA255-15-R-0640

ARCHITECT'S PROJECT 11052.010

Thursday, April 14, 2016

The original Project Manual and Drawings, dated October 28, 2014, for the Project noted above, are amended as indicated on this Amendment 3.

This Amendment consists of 1 page.

Manufacturers approved by this Amendment shall not be relieved of the responsibility to comply with the specifications stated or, if not stated, the standard specifications and accessories supplied with the item specified.

ITEM NO.

CHANGES TO PRIOR ADDENDA (No changes)

CHANGES TO SPECIFICATIONS

- AMD 3-1 In Sections 22 05 11, 23 05 93 and 23 23 00, and anywhere else it may be found, delete references to Section 23 07 11, HVAC, Plumbing and Boiler Plant Insulation. No duct or pipe insulation is required.
- AMD 3-2 Section 32 12 16, Paragraph 2.4 states that, "Recycled asphaltic concrete pavement mixes shall not be used." Amend this sentence to read, "Up to 50% recycled asphaltic concrete may be used in the base course."

CHANGES TO DRAWINGS (No changes)

-- END --