


- GENERAL NOTES:
1. REFER TO MEP000 FOR ADDITIONAL NOTES.

2. THE PNEUMATIC TUBE SYSTEM INFRASTRUCTURE DESIGN HEREIN BASED ON SWISSLOG HEALTHCARE SOLUTIONS EQUIPMENT. THE VA RESERVES THE RIGHT FOR APPROVAL OF ALTERNATE PNEUMATIC TUBE SYSTEMS MANUFACTURER.


3. CONTRACTOR SHALL RE-ROUTE ANY DUCTWORK, MECHANICAL OR PLUMBING PIPING, DAMPERS OR TERMINAL BOXES LOCATED IN THE CEILING PLENUM AS REQUIRED TO ACCOMMODATE NEW PNEUMATIC OR ASSOCIATED EQUIPMENT.
- NOTES BY SYMBOL: "⬡"
1. THE PNEUMATIC TUBE SYSTEM SHALL HAVE THE ELECTRICAL CONSUMPTION MONITORED USING AN ELECTRICAL METER THAT WILL COMMUNICATE WITH THE EXISTING AUTOMATIC METER READING (AMR) SYSTEM IN THE HOSPITAL. THE METER(S) SHALL COMMUNICATE VIA R5485 MOD BUS TO THE MAIN (AMR) SYSTEM LOCATED IN THIS ROOM. THE EXISTING SYSTEM IS ACQUISITE 8812 MANUFACTURE BY OBVIOUS. THE PROPOSED METER SHALL BE ON THE LIST OF SUPPORTED DEVICES WITH CURRENT DRIVERS. LIST CAN BE FOUND ON THE OBVIOUS WEB SITE: [HTTP://WWW.OBVIOUS.COM/SUPPORT/SUPPORTED-DEVICES](http://www.obvious.com/support/supported-devices).

2. APPROXIMATE LOCATION OF TRANSFER UNIT. PROVIDE RECEPTACLE WITH 120V, 20A NORMAL CIRCUIT FOR POWER. REFER TO DRAWINGS E109 THRU E111 FOR PANEL LOCATIONS.


Revisions	Date



2201 N Collins, Suite 295
Arlington, Texas 76011-2691
(817) 461-6337 Fax: (817) 461-1025
P: 110
MECHANICAL-ELECTRICAL-PLUMBING
FEI PROJECT # 13069




FEI Project No.: 13069



Architecture ■ Planning ■ Interior Design
4949 Addison Circle ■ Addison, Texas 75001

MPI Project No.: 8130707

Seal



04/24/2015

BUILDINGS CC, CLC & PRC
GROUND FLOOR PLAN

Approved: Area Project Manager

Project Title
AUDIE L. MURPHY VA HOSPITAL
PNEUMATIC TUBING SYSTEM

Building Number
CC, CLC, PRC

Checked
SLT

Drawn
AOP


Location
7400 Merton Minter
San Antonio, TX 78229

Date
04/24/15

Project No.
671-13-104

Drawing No.
E101

Dwg. of



South Texas
Veterans
Health Care
System

STVHCS
San Antonio, Texas