

0 6 1 0 2 0 6 0 2 0 6 0 4 0 4 0 8 0 4 0 12 0 24

three inches = one foot
one and one-half inches=one foot
one inch=one foot
three-quarters inch = one foot
one-half inch = one foot
three-eighths inch = one foot
one-quarter inch = one foot
one-eighth inch = one foot

A
B
C
D
E
F

Computer Filenames:



- GENERAL NOTES:
1. REFER TO MEP000 FOR ADDITIONAL NOTES.

2. THE PNEUMATIC TUBE SYSTEM INFRASTRUCTURE DESIGN HEREIN BASED ON SWISSLOG HEALTHCARE SOLUTIONS EQUIPMENT. THE VA RESERVES THE RIGHT FOR APPROVAL OF ALTERNATE PNEUMATIC TUBE SYSTEMS MANUFACTURER.

3. CONTRACTOR SHALL RE-ROUTE ANY DUCTWORK, MECHANICAL OR PLUMBING PIPING, DAMPERS OR TERMINAL BOXES LOCATED IN THE CEILING PLENUM AS REQUIRED TO ACCOMMODATE NEW PNEUMATIC OR ASSOCIATED EQUIPMENT.
- NOTES BY SYMBOL: "⬡"
1. APPROXIMATE LOCATION OF TRANSFER UNIT. PROVIDE RECEPTACLE WITH 120V, 20A NORMAL CIRCUIT FOR POWER. REFER TO DRAWINGS E109 THRU E111 FOR PANEL LOCATIONS.

123456789

VA FORM 08-6231A, JAN 1990

Revisions

Date

FEI ENGINEERING INC

2201 N Collins, Suite 295
Arlington, Texas 76011-2691
(817) 461-0337 Fax: (817) 461-1025
E: info@fei-engineering.com
MECHANICAL • ELECTRICAL • PLUMBING
FEI PROJECT # 13069

FEI Project No.: 13069

MPI Architects

Architecture ■ Planning ■ Interior Design
4949 Addison Circle ■ Addison, Texas 75001

MPI Project No.: 8130707

Seal

Seal

04/24/2015

BUILDINGS CC, & PRC
SECOND FLOOR PLAN

Approved: Area Project Manager

Project Title
AUDIE L. MURPHY VA HOSPITAL
PNEUMATIC TUBING SYSTEM

Building Number
CC, PRC

Checked
SLT

Drawn
AOP

Location
7400 Merton Minter
San Antonio, TX 78229

Date
04/24/15

Project No.
671-13-104

Drawing No.
E103

Dwg. of

South Texas
Veterans
Health Care
System

STVHCS
San Antonio, Texas