

F1 FIFTH FLOOR PLAN, BLDG. CC

SCALE: 1" = 10'-0"

NORTH

FIFTH FLOOR

GENERAL NOTES:

1. REFER TO MEP000 FOR ADDITIONAL NOTES.
2. THE PNEUMATIC TUBE SYSTEM INFRASTRUCTURE DESIGN HEREIN BASED ON SWISSLOG HEALTHCARE SOLUTIONS EQUIPMENT. THE VA RESERVES THE RIGHT FOR APPROVAL OF ALTERNATE PNEUMATIC TUBE SYSTEMS MANUFACTURER.
3. CONTRACTOR SHALL RE-ROUTE ANY DUCTWORK, MECHANICAL OR PLUMBING PIPING, DAMPERS OR TERMINAL BOXES LOCATED IN THE CEILING PLENUM AS REQUIRED TO ACCOMMODATE NEW PNEUMATIC OR ASSOCIATED EQUIPMENT.

NOTES BY SYMBOL: "⬡"

1. APPROXIMATE LOCATION OF TRANSFER UNIT. PROVIDE RECEPTACLE WITH 120V, 20A NORMAL CIRCUIT FOR POWER. REFER TO DRAWINGS E109 THRU E111 FOR PANEL LOCATIONS.

100% CONSTRUCTION ISSUE

Revisions	Date

Computer Filename:

FRATTO ENGINEERING INC
2201 N Collins, Suite 295
Arlington, Texas 76011-2698
(817) 461-2337 Fax: (817) 461-1025
F-1166
MECHANICAL - ELECTRICAL - PLUMBING
FEI PROJECT # 13069

FEI Project No.: 13069

MPI Architects
Architecture ■ Planning ■ Interior Design
4949 Addison Circle ■ Addison, Texas 75001

MPI Project No.: 8130707

Seal

Seal: STATE OF TEXAS, MARK S. FRATTO, 60977, REGISTERED PROFESSIONAL ENGINEER, 04/24/2015

Drawing Title: BUILDING CC FIFTH FLOOR PLAN

Approved: Area Project Manager

Project Title: AUDIE L. MURPHY VA HOSPITAL PNEUMATIC TUBING SYSTEM

Building Number: CC | Checked: SLT | Drawn: AOP

Location: 7400 Merton Minter San Antonio, TX 78229

Date: 04/24/15

Project No.: 671-13-104

Drawing No.: E106

Dwg. of

South Texas Veterans Health Care System

STVHCS San Antonio, Texas

VA FORM 08-6231A, JAN 1990