


- PARTITION NOTES - CMU**
- INTERIOR PARTITIONS OF CONCRETE MASONRY UNITS (CMU) ARE SPECIFICALLY INDICATED ON FLOOR PLANS. ALL PARTITIONS TO BE 8" CMU UNLESS OTHERWISE NOTED. ALL METAL FRAMING TO BE 3/8" UNLESS OTHERWISE NOTED. METAL STUDS TO BE PLACED 16" ON CENTER. WHERE REQUIRED STUD WIDTH CANNOT BE INSTALLED, PROVIDE STUD WIDTH, FRAMING OF SUITABLE GAGE AND STYLE TO SUIT JOB CONDITION.
 - PROVIDE JOINT REINFORCEMENT EVERY TWO COURSES, 16" O.C. PROVIDE VERTICAL ROD REINFORCEMENT IN GROUTED CORES WHERE INDICATED BY STRUCTURAL SPECIFICATIONS AND DRAWINGS AND AT ALL WALL INTERSECTIONS AND OPENINGS (DOORS, WINDOWS, NICHEs, PASSAGES, ETC.). ALL PARTITIONS TO EXTEND FULL HEIGHT TO UNDERSIDE OF DECK UNLESS OTHERWISE NOTED. PROVIDE PARTITION TOP ANCHORS, 24" O.C. WHERE PARTITIONS ARE NOT BRACED BY STRUCTURAL FRAMING (HOHMANN BARDARD PTA SERIES TO SUIT JOB CONDITION OR EQUAL) TO STABILIZE PARTITIONS AT TOP OF WALL.
 - PROVIDE FIRE RATED PARTITIONS WHERE INDICATED. FIRE STOP/FIRE SAFE AND SMOKE STOP ALL PENETRATIONS THROUGH PARTITIONS, GAPS AND JOINTS. ALL FIRE RATED PARTITION ASSEMBLIES SHALL EXTEND FULL HEIGHT FROM FLOOR TO UNDERSIDE OF METAL DECK ABOVE. ALL OTHER PARTITIONS TO EXTEND FULL HEIGHT UNLESS OTHERWISE NOTED. FIRE RATED PARTITION TERMINATIONS SHALL BE FIRE STOPPED/FIRE SAFED TO PROVIDE THE SCHEDULED FIRE RESISTANCE RATING. REFER TO BUILDING CODE REVIEW PLANS.
 - PROVIDE ACOUSTICAL SEALANT AT ALL ELECTRICAL OUTLETS, PENETRATIONS, CAPS AND OPENINGS.
 - ALL EXPOSED CMU CORNERS TO BE BULL-NOSED UNLESS OTHERWISE NOTED.
 - ALL MASONRY OPENINGS TO RECEIVE LINTELS. SEE LINTEL SCHEDULE FOR TYPES. SEE ARCHITECTURAL, MECHANICAL, PLUMBING AND ELECTRICAL DRAWINGS FOR OPENING LOCATIONS.

- PARTITION NOTES - GWB**
- ALL DIMENSIONS ARE NOMINAL TO FACE OF GWB. WHERE CERAMIC TILE IS SCHEDULED, DIMENSIONS ARE TO FACE OF GWB.
 - ALL METAL FRAMING TO BE 3/8" UNLESS OTHERWISE NOTED. METAL STUDS TO BE PLACED 16" ON CENTER. WHERE REQUIRED STUD WIDTH CANNOT BE INSTALLED, PROVIDE STUD WIDTH, FRAMING OF SUITABLE GAGE AND STYLE TO SUIT JOB CONDITION.
 - ALL GYPSUM BOARD (GWB) TO BE 5/8" TYPE-X. AT SHOWER, TUB, LOCKER ROOM OR WET AREAS ALL GWB (CEILINGs OR PARTITIONS) TO BE MOISTURE RESISTANT TYPE. AT CERAMIC TILE AREAS PROVIDE CEMENT BACKER UNIT (CEMENT BOARD) IN LIEU OF GWB TO RECEIVE CERAMIC TILE.
 - PROVIDE ACOUSTICAL SEALANT AT ALL PARTITIONS, PERIMETERS, RUNNERS, ELECTRICAL OUTLETS, PENETRATIONS AND OPENINGS, TO MINIMIZE SOUND TRANSMISSION. ELECTRICAL OUTLETS SHALL BE SEPARATED BY MINIMUM ONE STUD, BACK TO BACK RECEPTACLES ARE NOT ACCEPTABLE.
 - ALL PARTITIONS TO RECEIVE 3" SOUND ATTENUATION BLANKET UNLESS INDICATED IN PARTITION REMARKS SECTION OF PARTITION SYMBOL.
 - PROVIDE FIRE RATED PARTITIONS WHERE INDICATED. FIRE STOP/FIRE SAFE AND SMOKE STOP ALL PENETRATIONS THROUGH PARTITIONS, GAPS AND JOINTS. ALL FIRE RATED PARTITION ASSEMBLIES SHALL EXTEND FULL HEIGHT UNLESS OTHERWISE NOTED. FIRE RATED PARTITION TERMINATIONS SHALL BE FIRE STOPPED/FIRE SAFED TO PROVIDE THE SCHEDULED FIRE RESISTANCE RATING. REFER TO BUILDING CODE REVIEW PLANS.
 - WHERE GWB PARTITION EDGE ALIGNS WITH CMU PARTITION EDGE, ADJUST ALIGNMENT SO THAT GWB SURFACE LAMINATES OVER CMU, EXTEND GWB TO CORNER.
 - METAL STUDS IN CHASE PARTITIONS TO BE BRACED TO EACH OTHER AT 1/3 POINTS.
 - PROVIDE SOLID BLOCKING AT ALL WALLS RECEIVING WALL MOUNTED EQUIPMENT AND/OR ACCESSORIES. COORDINATE WITH ALL TRADES AND OWNERS EQUIPMENT/FURNITURE LAYOUTS.
 - ALL RECESSED ITEMS SUCH AS ELECTRICAL PANELS, FIRE HOSE AND EXTINGUISHER CABINETS, ETC., LOCATED IN FIRE RATED PARTITION ASSEMBLIES SHALL BE BACKED W/ GWB AS REQUIRED TO MAINTAIN FIRE RESISTANCE RATING.
 - WHERE INSULATION EXTENDS FULL HEIGHT AND IS NOT CONCEALED BY GYPSUM BOARD, PROVIDE COMPRESSION RODS OR SUITABLE FRAMING TO SUPPORT INSULATION.
 - GWb CONSTRUCTION SHALL BE ISOLATED WITH CONTROL JOINTS WHERE:
 - PARTITIONS OR CEILINGs OF DISSIMILAR CONSTRUCTION MEET AND REMAIN IN THE SAME PLANE
 - WHERE WINGS OF "L", "U" & "T" SHAPED CEILING AREAS ARE JOINED
 - EXPANSION OR CONTROL JOINTS OCCUR IN THE BUILDING STRUCTURE OR WALL CONSTRUCTION. PROVIDE CONTROL JOINTS IN THE FACE OF GWB PARTITIONS AND CEILINGs WHEN THE SIZE OF THE SURFACE EXCEEDS THE FOLLOWING CONTROL JOINT SPACING.
 - PARTITIONS: 30' MAXIMUM IN EITHER DIRECTION.
 - INTERIOR CEILINGs: 50' MAX IN EITHER DIRECTION (W/PERIMETER RELIEF), 30' MAX IN EITHER DIRECTION (W/O PERIMETER RELIEF).
 - PARTITION TYPES ARE INDICATED ON FLOOR PLANS. EACH PARTITION TYPE SCHEDULED PROVIDES A COMPLETE ASSEMBLY DESCRIPTION INCLUDING METAL STUD SIZE, THICKNESS AND NUMBER OF LAYERS OF GWB REQUIRED. SOUND ATTENUATION BLANKET, AND OTHER DATA, WHERE PARTITION TYPES ARE NOT INDICATED ON FLOOR PLANS, PROVIDED THE FOLLOWING:
 - 3/8" METAL STUDS, (MIN GAUGE OF 20)
 - 1" LAYER 5/8" GWB (BOTH SIDES)
 - SOUND ATTENUATION BLANKET IN STUD CAVITY.



100% LEVEL 2 RFP SUBMISSION – NOT FOR CONSTRUCTION

<p>CONSULTANTS:</p>		<p>ARCHITECT/ENGINEERS:</p> <p>NKB</p> <p>N.K. BHANDARI, Architecture & Engineering, P.C. Architecture, Engineering, Construction Management Syracuse, NY 13204, West Fayette Street 315-428-1177</p>		<p>Drawing Title</p> <p>WALL TYPES</p>		<p>Project Title</p> <p>NEW PARKING STRUCTURE PHASE 4</p>		<p>Project Number</p> <p>672-085</p>		<p>Office of Construction and Facilities Management</p> <p>Department of Veterans Affairs</p>
<p>AMENDMENT #3 - 11/3/11</p> <p>11-03-2011</p>		<p>Approved: Project Director</p>		<p>Location</p> <p>SAN JUAN, PUERTO RICO</p>		<p>Drawing Number</p> <p>AE604</p>				
<p>Revisions:</p>		<p>Date</p> <p>06-03-2011</p>		<p>Checked</p> <p>CRR</p>		<p>Drawn</p> <p>JLH</p>		<p>Dwg. 100 of 169</p>		
<p>Date:</p>		<p>Date:</p>		<p>Date</p>		<p>Date</p>				