

1. Site Specific Installation Requirements, **Electrical Installation**: Install a new power disconnect box for each piece of equipment offered. Does the site require a new external power disconnect box for each Small Piece Folder?

- **For the electrical requirements, the small piece folders do not require an external disconnect box, the 110-100 washers and the 120 gas dryers do require an external disconnect box.**

2. B.6 Project Special Requirements, Item #7 All water piping, compressed air, steam/return connections for new equipment are to be new from nearest header, respectively. Does the site require new air lines to be run from the header or can the successful offereor utilize existing air drops?

- **For the project special requirements, new piping shall be furnished from the nearest header for water, air, steam and condensate returns.**