




1. FOR EXISTING ELEMENTS TO REMAIN NOT LABELED HERE, REFER TO DET-YAMC SHEET H7-12 FOR SIZES AND EQUIPMENT DESIGNATIONS.
2. REFER TO SHEET M-001 FOR GENERAL NOTES.
3. OFFSET NEW DUCT AND PIPING AS REQUIRED TO AVOID INTERFERENCE WITH EXISTING DUCTS AND PIPES.
4. FIRE DAMPER SHALL BE ACCESSIBLE FROM ABOVE THE FLOOR IT IS LOCATED IN.



1. FOR EXISTING ELEMENTS TO REMAIN NOT LABELED HERE, REFER TO DET-VAMC SHEET H7-12 FOR SIZES AND EQUIPMENT DESIGNATIONS.
2. REFER TO SHEET M-001 FOR GENERAL NOTES.
3. OFFSET NEW DUCT AND PIPING AS REQUIRED TO AVOID INTERFERENCE WITH EXISTING DUCTS AND PIPES.
4. FIRE DAMPER SHALL BE ACCESSIBLE FROM ABOVE THE FLOOR IT IS LOCATED IN.



1. FOR EXISTING ELEMENTS TO REMAIN NOT LABELED HERE, REFER TO DET-VAVC SHEET H7-4 FOR SIZES AND EQUIPMENT DESIGNATIONS.
2. REFER TO SHEET M-001 FOR GENERAL NOTES.
3. 120V TO 240V TRANSFORMER PANEL, TO SERVE TERMINAL UNITS TO BE PROVIDED BY CONTROLS CONTRACTOR. INSTALL ADJACENT TO EXISTING ECC (ENGINEERING CONTROL CENTER) SERVING TERMINAL UNITS. COORDINATE 120V POWER WITH ELECTRICAL CONTRACTOR.
4. OFFSET NEW DUCT AND PIPING AS REQUIRED TO AVOID INTERFERENCE WITH EXISTING DUCT AND PIPES.
5. FIRE DAMPPAL SHALL BE ACCESSIBLE FROM ABOVE THE FLOOR IT IS LOCATED IN.

VA FORM 08-6231

DETROIT, MI 48202



ALBERT KAHN JOB #: 03188-00.000

J. P. COLE

|       |
|-------|
| Drawn |
| PME   |

Dwg. 28 of 50



Department of  
Veterans Affairs