



DUCTBANK LEGEND

NOTE:
1. SEE DUCTBANK DETAILS SHEET ES501 FOR MORE INFORMATION.
2. DUCTBANKS TRANSITION FROM CONCRETE ENCASED TO DIRECT BURIAL CONDUIT 10'-0" FROM CONNECTION POINT. SEE PLAN FOR MORE DETAIL.

5

1

1

2

6

5

1

1

5

4

3

3

S

S

4

S

D10

D6

1

1

4

S

D4a

2

6

3

S

D4b

5

S

D2

1 = 400 PAIR COPPER TELEPHONE CABLE IN 6" CONDUIT.
2 = 300 PAIR COPPER TELEPHONE CABLE IN 6" CONDUIT.
3 = 200 PAIR COPPER TELEPHONE CABLE IN 6" CONDUIT.
4 = 4 INNERDUCT WITH 1-72, 3-48, & 1-12 STRAND FIBER IN 6" CONDUIT.
5 = INNERDUCT WITH 24 STRAND FIBER IN 3" CONDUIT.
6 = MISC #10 AND #12 AWG CABLE IN 6" CONDUIT.
S = SPARE CONDUIT.

LEGEND

UT

NEW TELECOMMUNICATIONS DUCTBANK. SEE DETAIL FOR ADDITIONAL INFORMATION.

UT

EXISTING TELECOMMUNICATIONS DUCTBANK TO REMAIN.

NEW TELECOMMUNICATIONS STRUCTURED CABLING ROUTED ABOVE CEILING.

NEW ELECTRICAL MANHOLE. SEE DETAIL FOR ADDITIONAL INFORMATION.

EXISTING ELECTRICAL MANHOLE TO REMAIN.

6F

SITE PLAN - TELECOMMUNICATIONS

1"=20'-0"

2	ADDENDUM #2	05/04/2016	<div><div>BES</div><div>DESIGN/BUILD</div></div> <div>Corporate Office: 766 Middle St, Fairhope, AL 36532 Phone: 251.990.5778 Fax: 251.990.3716</div>	Approved: Patient Safety Nurse			Approved: Energy Engineer			Approved: Safety Manager			Approved: Service Chief			Drawing Title SITE PLAN - RELOCATE AND EXPAND RENAL DIALYSIS			Project Title RELOCATE AND EXPAND RENAL DIALYSIS			Date 2016.01.22			Veterans Affairs
							Approved: Chief of Police			Approved: Infection Control Officer			Approved: Chief of Staff						Project No. 658-315						
							Approved: Chief of Mental Health Service			Approved: GEMS Coordinator			Approved: Associate Director			Approved: Chief of Facility Management Svc.			Building Number 2		Checked MCE	Drawn KRW	Drawing No. ES105 Sheet 125 of 144		
																Approved: Medical Center Director			Location SALEM VA MEDICAL CENTER						
Revisions:				Date																					