



NOTES BY SYMBOL 'O'

① EXISTING FIRE ALARM DEVICE. FIRE ALARM CONTRACTOR SHALL FIELD VERIFY INTEGRITY OF EXISTING SYSTEM AND COMPLIANCE WITH CURRENT LOCAL CODES. EXISTING FIRE ALARM DEVICES AND PANELS ARE TO BE BACK INTO NEW ELEVATOR CONTROLLERS. REFER TO DETAIL ON THIS SHEET FOR ASME A17.1 COMPLIANCE. TYPICAL LEVELS 1-5.

2 SHALL EXTEND CONTACTS UP TO ELEVATOR PENTHOUSE AS NOTED ON 1-MEP2.

1 BLDG. #1, 1ST-5TH FLOOR PLAN-MEP

100% CD15



**Office of
Construction
and Facilities
Management**

