

<b>AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT</b>			BPA NO.	1. CONTRACT ID CODE	PAGE 1	OF PAGES 4
2. AMENDMENT/MODIFICATION NO. A00001		3. EFFECTIVE DATE 05-18-2016	4. REQUISITION/PURCHASE REQ. NO. 675-16-2-2637-0169		5. PROJECT NO. (if applicable) none	
6. ISSUED BY Department of Veterans Affairs Orlando VA Medical Center 13800 Veterans Way  Orlando FL 32827		CODE 675	7. ADMINISTERED BY (If other than Item 6) Department of Veterans Affairs Network Contracting Activity 8 (NCO 8) Orlando VA Medical Center 13800 Veterans Way Orlando FL 32827		CODE 00675	
8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code)  To all Offerors/Bidders			(X)	9A. AMENDMENT OF SOLICITATION NO. VA248-16-Q-1022		
			X	9B. DATED (SEE ITEM 11) 05-18-2016		
				10A. MODIFICATION OF CONTRACT/ORDER NO.		
				10B. DATED (SEE ITEM 13)		
CODE		FACILITY CODE				
<b>11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS</b>						
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers <input checked="" type="checkbox"/> is extended, <input type="checkbox"/> is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing Items 8 and 15, and returning <u>1</u> copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified. <div style="text-align: right;">Tuesday May 31, 2016 at 2pm est.</div>						
12. ACCOUNTING AND APPROPRIATION DATA (If required)		675-3660160-2637-825500-2520 SPY0CP7A3				
<b>13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.</b>						
CHECK ONE	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.					
	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).					
	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:					
	D. OTHER (Specify type of modification and authority)					
<b>E. IMPORTANT:</b> Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.						
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)						
The purpose of this Amendment to RFQ# VA248-16-Q-1022 is to:						
1) Provide answers to properly submitted questions from contractors. Responses are attached. 2) Provide information for another contractor site visit to be held on May 23, 2016 at 9am. Instructions are attached. 3) Provide a final opportunity for contractors to submit questions. Instructions are attached.						
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.						
15A. NAME AND TITLE OF SIGNER (Type or print)			16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)			
			Edwin Roldan NCO8L2-72322 Contracting Officer			
15B. CONTRACTOR/OFFEROR		15C. DATE SIGNED		16B. UNITED STATES OF AMERICA		16C. DATE SIGNED
(Signature of person authorized to sign)				BY (Signature of Contracting Officer)		May 18, 2016

Question and Answers

- 1) Is this a follow-on requirement? If so, could you please provide the incumbent contract number for this opportunity?

Answer: This is not a follow on requirement.

- 2) If not, is this a new requirement?

Answer: Yes, this is a new requirement.

- 3) Which areas are conducive to work during normal business hours and which areas are not?

Answer: ICU is conducive for normal hours. The Radiology area will be best served to be completed during after hour and weekends.

- 4) Is it possible to obtain ceiling reflective drawings for the in the radiology section?

Answer: Yes, please see attached PDF's of drawings.

- 5) Has the scope of work have been revised in radiology from 7 long rails to X-Y systems due to gantry of the Radiology machine? This is for quote purposes.

Answer: Yes.

- 6) Please advise what pages of the contract need to be completed and returned?

Answer: Page 1 requires your company information, section B.1 (Acknowledgement of Amendments), section B.3 (Price/Cost Schedule), and section E.1 (clause 52.212-3) at a minimum need to be completed and returned.

- 7) Can the contract be printed, hand written and scanned and returned via email?

Answer: Yes, this is a suitable method of submitting your quote as long as it is legible and accurately calculated.

- 8) Is installer certification by the manufacturer (Tollos) required for this project?

Answer: No

- 9) Can another site visit be held?

Answer: Yes, please see site visit instructions attached.

- 10) Does the VA have drawings or measurements of what the new systems will look like?

Answer: No

- 11) Do you have any pictures of the ICU rooms?

Answer: No, pictures may be taken at the site visit.

- 12) What is the ceiling structure (concrete, steel joist...etc)?

Answer: Concrete

13) Will you need any additional track or motor for the reconfiguration or is the current system have both tracks and motor?

Answer: No, any additional components will be provided by the VA.

14) Who is responsible for electric outlets/power?

Answer: VA w

15) What is the length of the long and short rails?

Answer: 7 feet and 5 feet respectively.

16) Are the Radiology track systems a straight rail system or traverse (XY system)?

Answer: This will need to be a traverse XY system in Radiology.

17) Do you need to purchase a new ceiling lift motor?

Answer: Any additional components will be provided by the VA.

18) Do you need to purchase any more track?

Answer: Any additional components will be provided by the VA.

19) Are all motors 600lb capacity?

Answer: Yes

## RFQ Instructions and Evaluation Criteria

### 2. Site Visit

The Government will conduct a site visit, in accordance with FAR 52.237-1, during the solicitation period for this requirement on May 23, 2016 at 9:00 am est. at the Orlando Veterans Affairs Medical Center-Lake Nona Campus, at 13800 Veterans Way, Orlando, FL 32827. The purpose of the site visit is to provide an opportunity for interested quoters to ask questions, view the facilities, and for the Government to explain or clarify specifications and requirements.

All interested firms may attend with a limit of two (2) attendees per firm. Please submit, in writing, the names and organization of attendees to the Contracting Officer, Edwin Roldan via email at [edwin.roldan@va.gov](mailto:edwin.roldan@va.gov) no later than 2:00 PM EDT on May 19, 2016. The names provided will be used to admit personnel to the facility and for solicitation site visit.

All questions derived from the site visit shall be submitted in writing via email to [edwin.roldan@va.gov](mailto:edwin.roldan@va.gov) . Pertaining questions will be answered electronically and posted to the solicitation. Attendance is at the contractor's expense. Personnel should arrive to the tables next to the loading docks outside of Building #5 (Warehouse) no later than 5 minutes before the scheduled site visit, prevailing local time, to receive additional

instructions. Please address questions or inquiries regarding the solicitation site visit via email to [edwin.rolan@va.gov](mailto:edwin.rolan@va.gov). No paper copies of the pertaining solicitation will be made available during the site visit.

### **3. RFQ Question/Answer Period**

All prospective quoters may seek clarification of the requirement and pertaining solicitation by submitting questions via email ONLY to [edwin.rolan@va.gov](mailto:edwin.rolan@va.gov). The RFQ number (VA248-16-Q-1022) shall be referenced in the email subject line. Questions will be answered and emailed as part of the pertaining solicitation on a non-attribution basis. Under no circumstance shall any questions from any quoter be submitted directly to a technical point of contact in the VA. All questions must be submitted no later than May 23, 2016 at 5 pm EST. Questions received after this period may not be answered. Responses to questions will be distributed via an amendment to the RFQ no later than May 25, 2016.

See attached document: VOLUME 7A\_Ductwork Updated 07.23.13.

See attached document: VOLUME 7B\_Piping Updated 07.11.13.

See attached document: VOLUME 9B\_Med Gas Updated 07.08.13.

See attached document: VOLUME 10B\_Fire Suppression Updated 07.30.12.

See attached document: VOLUME 11C\_Lighting Plans Updated 07.08.13.