



Install New Packaged  
Gas/Electric RTU on New  
Concrete Pad

- Notes:
1. Install entire HVAC System as shown
  2. SA and RA Diffusers and Grilles to be located in an equally spaced symmetric pattern between existing ceiling joists. Contractor to lay out and submit dimensioned shop drawing for COR review and approval.
  3. Exterior Duct - Weatherproof Aluminum Jacket - with Weatherproof Flashing and Sealant at all Building Surfaces.

## B-134 AHU and Duct System

1  
A-2

1  
A-3

2  
A-3

1  
A-3

Project Title		Reference	Date
B134 HVAC UPGRADE			
Building		Checked	Date
134 PAVILION		WCC	
SHEET		Project No.	528A5-15-509
ATTIC SUPPLY AND RETURN		Drawn	A2
		Drawn	3 of 5