



Exterior Duct Notes:  
1. Weatherproof duct Insulation and Flashing @ Building.  
2. Install Vibration Separation Material to Match Duct profile @ Each Duct.  
3. Install Galvanized Steel Duct Supports to Slab below @ Each Duct.



- NOTES:
1. Locate East West Oriented Duct Between Existing Truss Framing - Do Not Alter or Cut Framing.
  2. Locate North South Oriented Duct Between Truss Chords - Do Not Cut Framing.



**B-134 AHU Attic Section Duct w/ Truss Reinforcing at Duct Intersections**

Project Title		Date	
B134 HVAC UPGRADE		REV 4-18-2016	
Project No.		528A5-15-509	
Building	Checked	WCC	
B134 PAVILION			
SHEET		A3	
TRUSS SECTIONS		4 of 5	