



GENERAL NOTES:

A. SUB-BASEMENT IS A CRAWL SPACE APPROXIMATELY FOUR (4) FEET HIGH WITH LIMITED SLOPE, ACCESS, AND LIGHTING. ACCESS TO SUB-BASEMENT CAN BE REACHED THROUGH STAIR NUMBER EIGHT (8) AND/OR STAIR NUMBER FIVE (5). ALL PIPING SHOWN IS LOCATED BELOW THE BASEMENT IN THE SUB BASEMENT.

B. CONTRACTOR SHALL BECOME FAMILIAR WITH THE EXISTING CONDITIONS OF THE SUB BASEMENT PRIOR TO DOING THIS WORK. THE LARGE QUANTITY OF EXISTING PIPE AND CONDUTIT WILL REQUIRE MULTIPLE OFFSETS AND CHANGES IN ELEVATION. THE CONTRACTOR SHALL INCORPORATE THESE INTO HIS BID AND COORDINATE THE EXACT ROUTING.

B. CONTRACTOR SHALL BECOME FAMILIAR WITH THE EXISTING CONDITIONS OF THE SUB BASEMENT PRIOR TO BIDDING THIS WORK. THE LARGE QUANTITY OF EXISTING PIPE AND CONDUIT WILL REQUIRE MULTIPLE OFFSETS AND CHANGES IN ELEVATION. THE CONTRACTOR SHALL INCORPORATE THESE INTO HIS BID AND COORDINATE THE EXACT ROUTING.

CODED NOTES:

- 1 2" SUPPLY AND RETURN VALVES CAPPED FOR FUTURE CONNECTION
- 2 2" BALANCE VALVE SET FOR 50 GPM (ADJUSTABLE).
- 3 SHUTTER AND RETURN VALVES CAPPED FOR FUTURE CONNECTION
- 4 NOT USED

CONSULTANTS:

ARCHITECT:

FULLY SPRINKLERED

PIPING PLAN - SE AREA

UPGRADES

Office of