

Project# 502-12-102/VA256-15-R-1083 Replace Obsolete HVAC Controls - RFI				
RFI	Item	Section	Para	Description
#1		01 32 16.13	1.9.C	Please define "SRE"
#2		01 35 26	1.12.B	Infection Control, states, "An AHA associated with infection control will be performed by VA personnel in accordance with FGI Guidelines (i.e. Infection Control Risk Assessment)" to determine risk classifications of different areas. The "primary project scope area for this project is Class II (tool mounted dust collectors, mist work surfaces while cutting, seal unused doors with duct tape, block off air vents, isolate HVAC system where work is performed). Have Class III areas been determined yet?
#3				Laydown Area - Will the Contractor have a laydown area(s)? If so, where?
#4				On-site Storage for Materials - Will the Contractor have a place to store materials on site within the existing facility? If so, where?
#5				On-site work trailer - Will the Contractor have a place for an on-site work trailer? If so, where?
#6				On-site Conex - Will the Contractor have a place to provide and store a conex container? If so, where?

Response
Senior Resident Eingineet
At this time there are only Class II.
Yes. Area will be shown to winning contractor
No. The contractor will have a laydown area to store material
Yes. Area will be shown to winning contractor
Yes. Area will be shown to winning contractor