



LOUVER ENCLOSURE - PROVIDE

- 1.SUBMIT PRODUCT DATA.
- 2.METAL FABRICATIONS SHALL BE HOT-DIPPED GALVANIZED.
- 3.WELDS SHALL BE MADE IN SHOP, NOT IN FIELD.
- 4.HURRICANE CLIPS:
 - a.SIMPSON H1Z ZMAX HURRICANE CLIP, OR VA-APPROVED EQUAL.
 - b.WHERE NAILS ARE CALLED FOR IN PRODUCT LITERATURE, USE GALVANIZED SCREWS.
 - c.PROVIDE FASTENERS INTO EVERY PLATE HOLE.
- 5.FASTENERS AND ANCHORS:
 - a.PER SPECIFICATIONS SECTIONS IN DIVISIONS 4, 5, AND 6.
 - b.SIMPSON OR VA-APPROVED EQUAL. SUBMIT PRODUCT DATA IF PROPOSING A SUBSTITUTION. BURDEN OF PROOF OF EQUAL IS ON CONTRACTOR.
 - c.WHERE NAILS ARE USED
 - d.WHERE DRAWING DETAILS CONFLICT WITH SPECIFICATIONS, USE STRONGER OF TWO.
 - e.GALVANIZED SHALL MEAN PRODUCTS ARE HOT-DIP GALVANIZED AFTER FABRICATION (14 GA. AND THICKER). MINIMUM AVERAGE COATING WEIGHT IS 2.0 OZ/SF (PER ASTM A123 TOTAL BOTH SIDES). HOT-DIP GALVANIZED FASTENERS SHALL MEET SPECIFICATIONS OF ASTM A153. ANCHOR BOLTS ARE HOT-DIP GALVANIZED PER ASTM F2329.
 - f.IN CONCRETE AND MASONRY, USE LAG SCREW EXPANSION SHIELD (LSES) DIE CAST ZINC ALLOY EXPANSION ANCHORS. DRILL HOLES TO ACCOMMODATE LSES.
 - g.HOLES IN MASONRY: DEPTH INTO SINGLE WYETH.
 - h.HOLES IN CONCRETE: DEPTH SHALL BE 6 INCHES.
- 6.AT WALL, PROVIDE VERTICAL 16GA. METAL FLASHING, CONTINUOUS TO TOP FLASHING.
- 7.AT CORNERS, PROVIDE TRIM PIECES RECOMMENDED BY MBCS, OR VA-APPROVED EQUAL. CAULK GAPS COMPLETELY.

AMENDMENT
002
05/20/2016

ENCLOSURE DETAILS BUILDING 102 UPGRADE MER EXHAUST FAN

DRAWING
NO.
A002-7