

1 MECHANICAL NEW WORK PLAN - PHASE 4 - RETURN AIR
SCALE: 1/8" = 1'-0"

2 MECHANICAL NEW WORK PLAN - PHASE 4 - SUPPLY AIR
SCALE: 1/8" = 1'-0"

CLEARY ZIMMERMANN
ENGINEERS
Texas Registration # F-9387

3415 S. Faint, Suite 200
San Antonio, Texas 78204
710.441.6100 / 710.441.6101
ClearyZimmernann.com

GENERAL NOTE - THIS SHEET ONLY

- THE EXISTING MECHANICAL LAYOUTS INDICATED ON THESE DOCUMENTS ARE BASED ON THE INFORMATION AVAILABLE AND MAY BE INCOMPLETE AND INACCURATE. IT SHALL BE THE CONTRACTOR'S RESPONSIBILITY TO VERIFY ACTUAL CONDITIONS AND MAKE NECESSARY ADJUSTMENTS AS NECESSARY TO ACCOMMODATE NEW WORK AT NO EXTRA COST TO THE OWNER. CONDITIONS DIFFERENT TO THOSE INDICATED SHALL BE INCORPORATED INTO THE CONSTRUCTION DOCUMENTS. NOTE THAT ANY UNCOVERED SYSTEMS MUST BE CAREFULLY IDENTIFIED PRIOR TO MODIFICATIONS.
- CONTRACTOR SHALL COORDINATE HIS WORK WITH THE OTHER TRADES AND INCLUDE ANY MODIFICATIONS NEEDED TO ACCOMMODATE THEIR WORK.

GENERAL DRAWING NOTE

- IN ORDER TO MINIMIZE OUTPATIENT PHARMACY DOWNTIME, THE HVAC SYSTEM REPLACEMENT SHALL BE PERFORMED IN STAGES AS FOLLOWS:
- 1) CHILLED WATER LINE RELOCATION
 - 2) INITIAL NEW AIR HANDLER INSTALLATION
 - 3) SUCCESSIVE ZONE DEAD AND NEW WORK AS NOTED ON DRAWINGS.

NOTE: THE RESIDENT ENGINEER MUST BE NOTIFIED 24 HOURS IN ADVANCE OF ANY COMPROMISE IN THE FIRE SUPPRESSION OR SMOKE DETECTION SYSTEMS. A COPY OF THE INTERIM LIFE SAFETY CODE MEASURES MUST BE OBTAINED AND FOLLOWED DURING CONSTRUCTION.

**Chesney
Morales ARCHITECTS/PLANNERS
& Associates, Inc.**

Approved: Service Chief	Approved: Service Chief
Concur: M & O	Approved: Service Chief
Concur: Bio-Med	Approved: Service Chief
Concur: Safety	Approved: Service Chief
Approved: Service Chief	Approved: Admin. Officer

Drawing Title
MECHANICAL FLOOR PLAN INTERSTITIAL RETURN/SUPPLY
Approved: Chief of Engineering
Approved: Associate Director

0' 5' 10' 20'
SCALE: 1/8" = 1'-0"
AS BUILT DRAWINGS 10-3-13



OUTPATIENT PHARMACY - APPROXIMATE AREA OF WORK
1ST FLOOR KEYPLAN
NOT TO SCALE

Project Title
EXPAND OUTPATIENT PHARMACY
Building Number
1
Checked
M.S.
Drawn
C.C.
Location
AUDIE L. MURPHY VETERANS MEMORIAL HOSPITAL - SAN ANTONIO, TEXAS

Date
10/09/09
Project No.
871-07-101
DRAWING NO.
H-11
Dwg. - of -

