

GENERAL NOTES:

- REFERENCE SHEET MH0.1 FOR LEGEND, SYMBOLS, ABBREVIATIONS AND FURTHER GENERAL NOTES.
- ALL ITEMS THAT REQUIRE ACCESS FOR OPERATING, CLEANING, SERVICING, MAINTENANCE, CALIBRATION ETC. SHALL BE EASILY AND SAFELY ACCESSIBLE BY PERSONS STANDING AT FLOOR LEVEL, OR STANDING ON PERMANENT PLATFORMS, WITHOUT THE USE OF PORTABLE LADDERS. EXAMPLES OF THESE ITEMS INCLUDE, BUT ARE NOT LIMITED TO: TERMINAL UNITS, ALL TYPES OF VALVES, FILTERS, STRAINERS, TRANSMITTERS, AND CONTROL DEVICES.
- THE CONTRACTOR SHALL COORDINATE THE INSTALLATION OF THE NEW DUCTWORK AND PIPING WITH THE EXISTING STRUCTURE. ADDITIONAL OFFSETS AND FITTINGS AS REQUIRED TO ACCOMMODATE ROUTING OF THE DUCTWORK AROUND EXISTING STRUCTURE IS CONSIDERED PART OF THIS WORK.




PARTIAL FOURTH FLOOR
INTERSTITIAL SPACE - 4A - NEW CONSTRUCTION -
SCALE: 3/16" = 1'-0"

KEYED NOTES:


- ROUTE THE DUCTWORK DOWN TO THE AIR DEVICE AND CONNECT. REFER TO SHEET MH2.1 AND MH2.2 FOR AIR DEVICE SIZE AND LOCATION. REFER TO DETAIL 8/MH3.1 FOR CONNECTION TO AIR DEVICE DETAIL.
- FINISH AND INSTALL A NEW 20 GA 44"WX12"D(X24"L) INSULATED OUTSIDE AIR PLENUM. CONNECT NEW OUTSIDE AIR PLENUM TO THE EXISTING ARCHITECTURAL GRILLE REFERENCE DETAIL 2/MH2.4. REMOVE THE BLANK OFF PLATE AND CLEAN THE GRILLE PRIOR TO INSTALLING PLENUM.
- FINISH AND INSTALL A NEW 20 GA 180"WX12"D(X24"L) EXHAUST AIR PLENUM. CONNECT NEW OUTSIDE AIR PLENUM TO THE EXISTING ARCHITECTURAL GRILLE REFERENCE DETAIL 2/MH2.4. REMOVE THE BLANK OFF PLATE AND CLEAN THE GRILLE PRIOR TO INSTALLING PLENUM.

- 4 FURNISH AND INSTALL A NEW CF-1X1-012-P-2GBSS CAMFIL/FARR HEPA FILTRATION SYSTEM OR APPROVED EQUAL. THE HEPA FILTRATION SYSTEM SHALL BE HUNG FROM STRUCTURE AND INSTALLED A MAXIMUM OF 6' FROM CATWALK HANDRAIL.
- 5 FURNISH AND INSTALL CATWALK BRIDGING TO PROTECT DUCTWORK CROSSING CATWALK.

2 INTERSTITIAL COORDINATION DETAIL
NOT TO SCALE



3 TYPICAL DUCTWORK ROUTING SECTION
NOT TO SCALE



		RECORD DRAWINGS		CONSULTANTS:		FINAL DOCUMENTS		ARCHITECT:		Drawing Title		Project Title		Project Number		Construction and Facilities Management			
		DATE: 03/07/12		DATE: MARCH 7, 2012		Barker & Associates, Inc		WESTEAST DESIGN GROUP		PARTIAL FOURTH FLOOR		WARD UPGRADES/ EXPANSION WARD		671-047C		Construction and Facilities Management			
		04/21/11		THIS DOCUMENT IS RELEASED FOR THE PURPOSE OF RECORD DRAWING PREPARATION UNDER THE AUTHORITY OF JON BARKER, P.E. LICENSE NO. 87963 ON 07 MARCH 2012. IT IS NOT TO BE USED FOR CONSTRUCTION, BIDDING, PERMIT, OR OTHER PURPOSES WITHOUT THE WRITTEN CONSENT OF THE ENGINEER OF RECORD. THE INFORMATION SHOWN ON THIS DOCUMENT WAS DEVELOPED FROM INFORMATION PROVIDED BY THE CONTRACTOR. BARKER AND ASSOCIATES DOES NOT GUARANTEE OR WARRANT THE CAPACITY, LOCATION, SIZE OR QUANTITY OF ITEMS SHOWN.		Consulting Engineers		1617 E. COMMERCE ST., SUITE 7102, SAN ANTONIO, TEXAS 78205 USA		INTERSTITIAL SPACE - 4A - NEW CONSTRUCTION - HVAC		WARD 4A		Building Number 1		Drawing Number			
		10/26/10				Firm Registration No. F-9213		210.530.0755 FAX 210.530.9427		Approved Project Director		Location		Checked DB		Drawn RM			
		09/30/10				824 Broadway St., Suite 201 San Antonio, Texas 78215				Melan Arhila		Andie L. Murphy Memorial Veterans Hospital		Date		MH2.3			
		09/22/10				Phone: (210) 826-9191 Fax: (210) 223-9194						San Antonio, Texas		21 JUNE 2010		Dwg. 46 of 82			
		06/11/09				Email: barkerassociates@barker-sa.com		These documents can not be copied or reproduced without written consent from WestEast Design Group								Department of Veterans Affairs			
GENERAL REVISIONS		Date																	
Revisions:																			
VA FORM 08-6231, OCT 1978																			