

Table III  
Compiled Summary Table of Asbestos Containing Materials

| Sample ID | Sampled By | Date Sampled | Material Type | Sample Description   | Building No. | Floor | Sample Location   | Result      | Asbestos (Y/N) |
|-----------|------------|--------------|---------------|--|--------------|-------|---|-------------|----------------|
| 4         | MECX       | 16-Oct-07    | Misc.         | Floor Tile & Mastic Granular Tile<br>Gummy Mastic Throughout<br>Second Floor of Central Wing         | 110          | 4     | Second Floor Central Wing<br>Doorway to West Wing         | 2-3 FT      | Y              |
| 5         | MECX       | 16-Oct-07    | Misc.         | TSI Crumbly Central Building<br>Western Restroom Domestic<br>Water Piper Chasse                      | 110          | 4     | Second Floor Womans Restroom<br>Pipe Chase                | 3-5         | Y              |
| 6         | MECX       | 16-Oct-07    | Misc.         | Soffit Granular/Fibrous Second<br>Level Soffit   | 110          | 4     | Outside of North Window of West<br>Wing                   | 10-15       | Y              |
| 7         | MECX       | 16-Oct-07    | Misc.         | Soffit Granular/Fibrous Second<br>Level Soffit   | 110          | 4     | East Wing Soffit  | 10-15       | Y              |
| 8         | MECX       | 16-Oct-07    | Misc.         | Soffit Granular/Fibrous Second<br>Level Soffit   | 110          | 4     | East Wing Soffit  | 10-15       | Y              |
| 10        | MECX       | 16-Oct-07    | Misc.         | Floor Tile & Mastic Granular Tile<br>Gummy Mastic Central Building<br>Third Floor Hallways & Offices | 110          | 4     | Central Building Third Floor<br>Eastern Stairwell Doorway | 1-2 FT      | Y              |
| 22        | MECX       | 16-Oct-07    | Misc.         | Floor Tile & Mastic Granular Tile<br>Gummy Mastic South Half of<br>Center Wing                       | 110          | 4     | NE Corner of South Half of Center<br>Wing                 | 8-10 Mastic | Y              |
| 23        | MECX       | 16-Oct-07    | Misc.         | Floor Tile & Mastic Granular Tile<br>Gummy Mastic South Half of<br>Center Wing                       | 110          | 4     | SW Corner of South Half of Center<br>Wing                 | 8-10 Mastic | Y              |
| 24        | MECX       | 16-Oct-07    | Misc.         | Floor Tile & Mastic Granular Tile<br>Gummy Mastic South Half of<br>Center Wing                       | 110          | 4     | South Wall of South Half of<br>Center Wing                | 8-10 Mastic | Y              |
| 25        | MECX       | 16-Oct-07    | Misc.         | Floor Tile & Mastic Granular Tile<br>Gummy Mastic Central Building<br>Second Floor Throughout        | 110          | 4     | Central Building Second Floor<br>Mechanical Room Doorway  | 2-3 FT      | Y              |
| 26        | MECX       | 16-Oct-07    | Misc.         | Floor Tile & Mastic Granular Tile<br>Gummy Mastic Central Building<br>Second Floor Throughout        | 110          | 4     | Central Building Second Floor<br>Room 211                 | 2-3 FT      | Y              |
| 27        | MECX       | 16-Oct-07    | Misc.         | Floor Tile & Mastic Granular Tile<br>Gummy Mastic Central Building<br>Second Floor Throughout        | 110          | 4     | Central Building Second Floor                             | 2-3 FT      | Y              |