

Contractor Note: The 3" x 20 gage composite steel floor deck is not required to be shored during concrete placement for two or more span conditions (one piece of decking bearing on 3 or more support beams). Shoring shall be required for single spans of decking where the clear span is 9'-0" or greater.

3rd FLOOR FLOOR FRAMING PLAN

1/8"=1'-0'

1 / S102

TOP OF SLAB EL. +37'-7 1/2"

FLOOR LIVE LOAD = 100 PSF U.N.O.

NORTH

100% REVIEW SUBMITTAL

Revisions	Date

Toland◆Mizell◆Molnar, LLC
590 MEANS STREET NW,
SUITE 200
ATLANTA, GA, 30318
404-214-9774

STATE OF LOUISIANA
ROBERT C. PADGETT
License No. 25450
PROFESSIONAL ENGINEER
5/31/11

PADGETT
Engineering Group
Consulting Structural Engineers
T 678 309 9070 ▪ F 678 309 0608

Drawing Title	3RD FLOOR FRAMING PLAN
Approved Project Engineer	
Project Title	2ND FLOOR OUTPATIENT MH VA SHREVEPORT

Building Number	---
Checked	BP
Drawn	AH
Location	---
Date	05-25-2011
Project No.	10049
DRAWING NO.	S102
Dwg.	– Of –

Veterans Administration

VA FORM 08-6231A, MAR 1984

U.S. GOVERNMENT PRINTING OFFICE:1984-440-467